

---

# **CITY OF OCALA**

## **CITY COUNCIL REPORT**

---

**Council Meeting Date: 04/06/21**

---

Subject: Engineered Sprayed Solutions, LLC Contract

Submitted By: Rusella Bowes-Johnson

Department: Water & Sewer

---

**STAFF RECOMMENDATION** (Motion Ready): Approve Agenda Item (ID # 15553) piggyback contract with Sarasota County to Engineered Spray Solutions, LLC for manhole rehabilitation coating in the amount not to exceed \$300,000

---

**OCALA'S RELEVANT STRATEGIC GOALS:** Operational Excellence, Quality of Place

---

**PROOF OF PUBLICATION:** N/A

---

### **BACKGROUND:**

Hydrogen sulfide (H<sub>2</sub>S) is a colorless gas generated in the sewer systems. Over time, this gas causes safety and maintenance problems including odors and corrosion. The corrosive nature of H<sub>2</sub>S compromises the integrity of the manholes by deteriorating the protective coating and exposing the concrete structure. This project consists of the preparation and installation of polyurethane coating coatings to protect the manholes concrete structures with a life expectancy of 15 years.

### **FINDINGS AND CONCLUSIONS:**

- The Water Resources Engineering Division recommends the use of a manhole coating system to maintain serviceability conditions and prolong the service life of the manholes.
- Engineered Spray Solutions, LLC offers a polyurethane coating product which meets the City of Ocala Standard Specifications for construction.
- After being the successful bidder for manholes and lift station rehabilitation, Engineered Spray Solutions was awarded a contract (Contract No. 2020-435) with Sarasota County on 06/03/2020.
- The term of the piggyback agreement between the City of Ocala and Engineered Spray Solutions shall commence upon signature of the agreement and terminate March of 2024 and shall include labor, services and materials.
- Staff recommends approval.

### **FISCAL IMPACT:**

There are sufficient funds available in the following FY 2021 Water Resources accounts: 455-030-300-535-53-46010 (\$150,000); and 455-030-303-535-53-46010 (\$150,000).

### **PROCUREMENT REVIEW:**

This purchase has been reviewed and approved for compliance with the City's procurement policies.

### **LEGAL REVIEW:**

The contract has been reviewed and approved for form and legality by the City Attorney, Robert W. Batsel, Jr.

### **ALTERNATIVE:**

- Approve
- Deny
- Table

### **SUPPORT MATERIALS:**

Piggyback Agreement Engineered Sprayed Solutions LLC (PDF)