



Addendum # 1

Date: January 21, 2025
To: All bidders
From: Brittany Craven, Buyer
Solicitation Number: RFI# WHS/250233
Solicitation Title: SOLE SOURCE POSTING - Vista Switch, S&C - SSP 232

SECTION 1. PRODUCTS AND SPECIFICATIONS – Additional Info.

1.

ItemID	E14260600
Revision Date	6/1/2016
Revised By	Mary Ann St. Laurent
Description	SWITCH, PADMOUNT - GAS POWERED #211
Specs/Remarks	Three (3) phase 600 amp load-interrupting, microprocessor controlled with vacuum fault interrupting capability with adjustable trip settings on 25 to 400 amps using standard "E" speed curves. The unit shall have six (6) 600 amp deadbreak elbow connectors enclosed (closed-open-grounded) manual load interrupter switch with a visible gap when open shall be provided. A microprocessor based programmable by use of personal computer. The standard tank to be made of mild steel and equipped with a pressure guage and a gas fill port. The enclosure shall meet the requirements of ANSI C57.12.28. The switch must fit a 70" X 50" pad.

2.

ItemID	E14261000
Revision Date	2/7/2024
Revised By	Frank Brown
Description	SWITCH, PADMOUNT GAS OPERATED #330/321 VISTA 600 AMP BUSHINGS
Specs/Remarks	Manufacturer's catalog number defines specifications. L2 - Potential Indicator M3 - 600A Bushings P4 - Metal Enclosure; mild green T1 - Single Pole Manual Fault Interrupter on all Fault Interrupting Ways

3.

ItemID	E14261600
Revision Date	6/1/2016
Revised By	Mary Ann St. Laurent
Description	SWITCH, PADMOUNT - SF6 NON-PROGRAMMABLE #210
Specs/Remarks	Three (3) phase with one gang operated load interrupting switch. Six hundred amp bushings in all positions. 12.5 ka, 15 KV. The enclosure shall meet the requirements of ANSI C57.12.28. The standard tank to be made of mild steel equipped with a pressure guage and a gas fill port.

ItemID E14267000
 Revision Date 9/2/2020
 Revised By Mary Ann St. Laurent

Description SWITCH, PADMOUNT GAS OPERATED #201 VISTA
 Specs/Remarks Manufacturer's catalog number defines specifications: L2 - Potential Indicator M3 - 600A Bushing with stud P2 - Metal Enclosure; mild green T1 - Three Pole Manual Fault Interrupter on one fault interrupting way

4.

ItemID E14268000
 Revision Date 2/6/2018
 Revised By Neville Bowen

Description SWITCH, PADMOUNT GAS OPERATED #422 VISTA
 Specs/Remarks Manufacturer's catalog number defines specifications.T0 INCLUDE (6)200 AMP FACTORY INSTALLED BUSHINGS INSERTS PER OCALA SPECS E14020010 L2 - Potential Indicator P4 - Metal Enclosure; mild green T0 - Single Pole Manual Fault Interrupter on all Fault Interrupting Ways.

5.

ItemID E14269000
 Revision Date 2/6/2018
 Revised By Neville Bowen

Description SWITCH, PADMOUNT GAS OPERATED #321 VISTA
 Specs/Remarks Manufacturer's catalog number defines specifications.T0 INCLUDE (3) 200 AMP FACTORY INSTALLED BUSHINGS INSERTS PER OCALA SPECS E14020010. L2 - Potential Indicator P4 - Metal Enclosure; mild green T0 - Single Pole Manual Fault Interrupter on all Fault Interrupting Ways

6.