OCALA ELECTRIC UTILITY OCALA, FLORIDA

FIRST REVISED SHEET NO. 19.0 CANCELS ORIGINAL SHEET NO. 19.0

## APPLICATION FOR INTERCONNECTION OF CUSTOMER-OWNED RENEWABLE GENERATION SYSTEMS

TIER 1 - Ten (10) kW or Less

1. Customer Information

TIER 2 - Greater than 10 kW and Less Than or Equal to 100 kW

TIER 3 - Greater than 100 kW and Less Than or Equal to Two (2) MW

Note: These customer-owned renewable generation system size limits may be subject to a cumulative enrollment limit on net-metering customers located in the area served by the City of Ocala Electric Utility. Please refer to the Ocala Electric Utility Net-Metering Rate Schedule.

Ocala Electric Utility customers who install customer-owned renewable generation systems (RGS) and desire to interconnect those facilities with the Ocala Electric Utility system are required to complete this application. When the completed application and fees are returned to Ocala Electric Utility, the process of completing the appropriate Tier 1, Tier 2 or Tier 3 Interconnection Agreement can begin. This application and copies of the Interconnection Agreements may be obtained at Ocala Electric Utility, located at 201 SE 3rd Street, Ocala, Florida 34471, or may be requested by email from OEU@ocalafl.org.

# Name: Deborah Baker Mailing Address: 13048 NE 7th Loop City: Silver Springs State: FL Zip Code: 34488 Phone Number: 607-346-0139 Alternate Phone Number: 607-341-2428 Email Address: kevinrappbaker@gmail.com Fax Number: Ocala Electric Utility Customer Account Number: 570584-260717 2. RGS Facility Information Facility Location: 13048 NE 7th Loop Silver Springs, FL. 34488 Ocala Electric Utility Customer Account Number: 570584-260717 RGS Manufacturer: Hanwha Q Cells America, Inc Manufacturer's Address: 300 Spectrum Center Drive Suite 500 Irvine, CA. 92618 Reference or Model Number: Q.Peak DUO BLK ML-G10+ (19-Modules 410W) Serial Number: Inverter-Solaredge SE7600H-US-U650 Optimizer

(Continued on Sheet No.19.1)

Effective: October 1, 2019

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continue from Sheet No. 19.0)

## FIRST REVISED SHEET NO. 19.1 CANCELS ORIGINAL SHEET NO. 19.1

## 3. Facility Rating Information

Gross Power Rating: <u>6.62kWac</u> ("Gross power rating" means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with Ocala Electric Utility's distribution facilities. For inverter-based systems, the AC nameplate generating capacity shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.)

Fuel or Energy Source: Solar	·PV
Anticipated In- Service Date:	TBD

## 4. Application Fee

The application fee is based on the Gross Power Rating and must be submitted with this application. The non-refundable application fee is \$375 for Tier 2 and \$750 for Tier 3 installations. There is no application fee for Tier 1 installations.

## 5. Interconnection Study Fee

For Tier 3 installations, a deposit in the amount of the estimated costs of the study (to be determined at time of application) must be paid along with this application in addition to the application fee referenced in Article 4 above. This deposit will be applied toward the cost of an interconnection study. The customer will be responsible for the actual costs of the study. Should the actual cost of the study be less than the deposit, the difference will be refunded to the customer. Customer agrees to comply with all interconnection requirements identified in the interconnection study report.

## 6. Required Documentation

Prior to completion of the Interconnection Agreement, the following information must be provided to the Ocala Electric Utility by the customer.

- A. Documentation demonstrating that the installation complies with (or most current version at time of inspection approval):
  - 1. IEEE 1547 (2018) Standard for Interconnecting Distributed Resources with Electric Power Systems.
  - 2. IEEE 1547.1 (2005) Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.
  - 3. UL 1741 (2010) Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources.

(Continued on Sheet No. 19.2)

Effective: October 1, 2019

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 19.1)

## FIRST REVISED SHEET NO. 19.2 CANCELS ORIGINAL SHEET NO. 19.2

Effective: October 1, 2019

B. Documentation that the customer-owned renewable generation has been inspected and approved by local code officials prior to its operation in parallel with the Ocala Electric Utility system to ensure compliance with applicable local codes. OEU will also require proof of commission testing by a qualified 3<sup>rd</sup> party testing company (not affiliated in any way with the manufacturer, vendor or installation contractor), for compliance with all required and applicable codes, standards, and interconnection study requirements, prior to setting of OEU metering equipment.

C. Proof of insurance in the amount of:

Tier 1 - \$100,000.00

Tier 2 - \$1,000,000.00

Tier 3 - \$2,000,000.00

Customer

By: Deborah Baker	Date: 6 23 25
Print Name)	
Delmala Bales	
Signature)	

OCALA ELECTRIC UTILITY OCALA, FLORIDA

FIRST REVISED SHEET NO. 20.0 CANCELS ORIGINAL SHEET NO. 20.0

## **Tri-Party Net-Metering Power Purchase Agreement**

This Tri-Party Net-Metering Power Purchase Agreement (this "Agreement") is entered into this
23rd day of, 20_25_, by and between the Florida Municipal Power Agency, a
governmental joint action agency created and existing under the laws of the State of Florida
(hereinafter "FMPA"), the City of Ocala doing business as Ocala Electric Utility, a body politi
(hereinafter "OEU"), and Deborah Baker , a reta
electric customer of OEU (hereinafter "Customer").

## Section 1. Recitals

- 1.01. OEU and Customer have executed OEU's Standard Interconnection Agreement for a Customer-Owned Renewable Generation System (RGS) pursuant to which OEU has agreed to permit interconnection of Customer's renewable generation to OEU's electric system at Customer's presently-metered location, and Customer has agreed to deliver excess electric energy generated by Customer's Renewable Generation System to OEU's electric distribution system;
- 1.02. The City of Ocala and FMPA have entered into the All-Requirements Power Supply Contract, dated as of May 1, 1986, (hereinafter the "ARP Contract") pursuant to which the City of Ocala has agreed to purchase and receive, and FMPA has agreed to sell and supply OEU with all energy and capacity necessary to operate the OEU electric system, which limits OEU's ability to directly purchase excess energy from customer-owned renewable generation.
- 1.03. In order to promote the development of small customer-owned renewable generation by permitting OEU to allow its customers to interconnect with OEU's electric system and to allow OEU's electric customers to offset their electric consumption with customer-owned renewable generation, FMPA, in accordance with the terms and conditions of this agreement, has agreed to purchase excess customer-owned generation from OEU's electric customers interconnected to OEU's electric system.

NOW THEREFORE, for and in consideration of the mutual covenants and agreements set forth herein, the Parties covenant and agree as follows:

## **Section 2. Interconnection**

2.01. Customer shall not begin parallel operations with the OEU electric distribution system until Customer has executed OEU's electric Standard Interconnection Agreement for Small Customer-Owned Renewable Generation and is in compliance with all terms and conditions

OEU requires that the customer install and operate the RGS in accordance with all applicable safety codes and standards. OEU shall establish and enforce terms and conditions of operation and disconnection of all interconnected customer-owned renewable generation as it relates to the effect of the RGS on OEU's electric distribution system.

(Continued on Sheet No. 20.1)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.0)

FIRST REVISED SHEET NO. 20.1 CANCELS ORIGINAL SHEET NO. 20.1

## **Section 3. Metering**

3.01 In accordance with the OEU's Standard Interconnection Agreement for Customer-Owned Renewable Generation, OEU shall install metering equipment at the point of delivery capable of recording two separate kWh meter readings: (1) the flow of electricity from OEU to the Customer (Delivered), and (2) the flow of excess electricity from the Customer to OEU. OEU shall take meter readings on the same cycle as the otherwise applicable rate schedule.

## Section 4. Purchase of Excess Customer-Owned Renewable Generation

- 4.01. Customer-owned renewable generation shall be first used for Customer's own load and shall offset Customer's demand for OEU's electricity. All electric power and energy delivered by OEU to Customer shall be received and paid for by Customer to OEU (Received) pursuant to the terms, conditions and rates of the OEU otherwise applicable rate schedule.
- 4.02. Excess customer-owned renewable generation shall be delivered to the OEU Electric distribution system. For purposes of this Agreement, the term "excess customer-owned renewable generation" means any kWh of electrical energy produced by the customer-owned renewable generation system that is not consumed by Customer and is delivered to the OEU electric distribution system. FMPA agrees to purchase and receive, and Customer agrees to sell and deliver, all excess customer-owned renewable generation at the energy rate established by FMPA, which shall be calculated in accordance with Schedule A. Excess customer-owned renewable generation shall be purchased in the form of a credit on Customer's monthly energy consumption bill from OEU.
- 4.03. In the event that a given monthly credit for excess customer-owned renewable generation exceeds the total billed amount for Customer's consumption in any corresponding month, then the excess credit shall be applied to the subsequent month's bill. Excess energy credits produced pursuant to the preceding sentence shall accumulate and be used to offset Customer's energy consumption bill for a period of not more than twelve (12) months. At the end of each calendar year, any unused excess energy credits shall be paid by OEU to the Customer in accordance with the OEU Electric Net-Metering Service Rate Schedule.

(Continued on Sheet No. 20.2)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.1)

FIRST REVISED SHEET NO. 20.2 CANCELS ORIGINAL SHEET NO. 20.2

- 4.04. FMPA and OEU shall not be required to purchase or receive excess customer-owned renewable generation, and may require Customer to interrupt or reduce production of customer-owned renewable generation, (a) when necessary in order to construct, install, maintain, repair, replace, remove, investigate, or inspect any OEU equipment or part of OEU's system; or (b) if either FMPA or OEU determine, in their sole judgment, that curtailment, interruption, or reduction is necessary because of emergencies, forced outages, force majeure, or compliance with any applicable electric code or standard.
- 4.05. Customer acknowledges that its provision of electricity to OEU hereunder is on a first-offered, first-accepted basis and subject to diminution and/or rejection in the event the total amount of electricity delivered to OEU pursuant to the Net-Metering Service Rate Schedule (as filed with the Florida Public Service Commission), from all participating OEU customers, exceeds two and one-half percent (2.5%) of the aggregate customer peak demand on the OEU electric system.

## **Section 5. Renewable Energy Credits**

- 5.01. Customer shall offer FMPA a first right of refusal before selling or granting to any third party the right to the Green Attributes associated with its customer-owned renewable generation that is interconnected to OEU electric distribution system. The term "Green Attributes" shall include any and all credits, certificates, benefits, environmental attributes, emissions reductions, offsets, and allowances, however entitled, attributable to the generation of electricity from the customer-owned-renewable generation and its displacement of conventional energy generation.
- 5.02. Any additional meter(s) installed to measure total renewable electricity generated by the Customer for the purposes of measuring Green Attributes, including and renewable energy certificates (or similarly titled credits for renewable energy generated), shall be installed at the expense of the Customer, unless determined otherwise during negotiations for the sale of the Customer's credits to FMPA.

## Section 6. Term and Termination

- 6.01. This Agreement shall become effective upon execution by all Parties, and shall remain in effect thereafter on a month-to-month basis until terminated by any Party upon thirty (30) days written notice to all other Parties.
- 6.02. This Agreement shall terminate immediately and without notice upon: (a) termination of the electric distribution service by OEU or (b) failure by Customer to comply with any of the terms and conditions of this Agreement or OEU's Standard Interconnection Agreement for Customer-Owned Renewable Generation.

(Continued on Sheet No. 20.3)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.2)

FIRST REVISED SHEET NO. 20.3 CANCELS ORIGINAL SHEET NO. 20.3

## **Section 7. Miscellaneous Provisions**

7.01. <u>Assignment</u>. It is understood and agreed that no party may transfer, sell, mortgage, pledge, hypothecate, convey, designate, or otherwise assign this Agreement, or any interest herein or any rights or obligations hereunder, in whole or in part, either voluntarily or by operation of law, (including, without limitation, by merger, consolidation, or otherwise), without the express written consent of the other parties (and any such attempt shall be void), which consent shall not be unreasonably withheld. Subject to the foregoing, this Agreement shall inure to the benefit of and be binding upon the parties and their respective successors and permitted assigns.

7.02 <u>Amendment</u>. It is understood and agreed that FMPA and OEU reserve the right, on no less than an annual basis, to change any of the terms and conditions, including pricing, in this Agreement on sixty (60) days advance written notice. FMPA and OEU may make such changes on an immediate basis in the event any applicable law, rule, regulation or court order requires them. In such event, FMPA and OEU will give Customer as much notice as reasonably possible under the circumstances.

7.03. <u>Indemnification</u>. To the fullest extent permitted by laws and regulations, and in return for adequate, separate consideration, Customer shall defend, indemnify, and hold harmless FMPA and OEU, their officers, directors, agents, guests, invitees, and employees from and against all claims, damages, losses to persons or property, whether direct, indirect, or consequential (including but not limited to fees and charges of attorneys, and other professionals and court and arbitration costs) arising out of, resulting from, occasioned by, or otherwise caused by the operation or misoperation of the customer-owned renewable generation, or the acts or omissions of any other person or organization directly or indirectly employed by the Customer to install, furnish, repair, replace or maintain the customer-owned renewable generation system, or anyone for whose acts any of them may be liable.

7.04. Governing Law. The validity and interpretation of this Agreement and the rights and obligations of the parties shall be governed and construed in accordance with the laws of the State of Florida without regard for any conflicts of law provisions that might cause the law of other jurisdictions to apply. All controversies, claims, or disputes arising out of or related to this Agreement or any agreement, instrument, or document contemplated hereby, shall be brought exclusively in the County or Circuit Court for Marion County, Florida, or the United States District Court sitting in Marion County, Florida, as appropriate.

(Continued on Sheet No. 20.4)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.3)

FIRST REVISED SHEET NO. 20.4 CANCELS ORIGINAL SHEET NO. 20.4

- 7.05. <u>Enforcement of Agreement</u>. In the event that either party is required to enforce this Agreement by court proceedings or otherwise, the prevailing party shall be entitled to recover all fees and costs incurred, including reasonable attorney's fees and costs for trial, alternative dispute resolution, and/or appellate proceedings.
- 7.06. <u>Severability</u>. To the extent any provision of this Agreement is prohibited by or invalid under applicable law, such provision shall be ineffective to the extent of such prohibition or invalidity, without invalidating the remainder of such provision or the remaining provisions of this Agreement.
- 7.07. Third Party Beneficiaries and Sovereign Immunity. This Agreement is solely for the benefit of FMPA, OEU, and Customer and no right nor shall any cause of action accrue upon or by reason, to or for the benefit of any third party not a formal party to this Agreement. Nothing in this Agreement, expressed or implied, is intended or shall be construed to confer upon any person or corporation other than FMPA, OEU, or Customer, any right, remedy, or claim under or by reason of this Agreement or any of the provisions or conditions of this Agreement; and, all provisions, representations, covenants, and conditions contained in this Agreement shall inure to the sole benefit of and be binding upon FMPA, OEU, and Customer and their respective representatives, successors, and assigns. Further, no term or condition contained in this Agreement shall be construed in any way as a waiver by either FMPA or OEU of the sovereign immunity applicable to either or both of them as established by Florida Statutes, 768.28.

(Continued on Sheet No. 20.5)

Effective: October 1, 2019

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.4)

## FIRST REVISED SHEET NO. 20.5 CANCELS ORIGINAL SHEET NO. 20.5

**IN WITNESS WHEREOF**, Customer and OEU have executed this Agreement the day and year first above written.

City of Ocala Electric Utility  By: Jania Mitall  Title: CFO	By:
Date: 11/6/2025	Date: 11/6/2025
Customer By: Deborah Baker  (Print Name) (Signature)	Date: 6/23/25
Customer's City of Ocala Electri	c Utility Account Number: 570584-260717
Approved as to form and legality	/ ♣ ✓─Signed by:
Robert W. Batsel, Jr. Assistant City Attorney	William E. Scrton, Esq. William E. Sexton, Esq. City Attorney

(Continued on Sheet No. 20.6)

Issued by: Michael Poucher, P.E. Electric Utility Director

Effective: October 1, 2019

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.5)

FIRST REVISED SHEET NO. 20.6 CANCELS ORIGINAL SHEET NO. 20.6

## Tri-Party Net-Metering Power Purchase Agreement Schedule A

## I. All-Requirements Project Calculation of Excess Customer-Owned Renewable Generation Credit

a) FMPA shall pay OEU for the excess kWh energy delivered by customer-owned renewable generation to OEU's electric system. Every month, OEU shall determine the total kWh of customer-owned renewable generation that is delivered to OEU's electric system, and shall send the information to FMPA as soon as it becomes available, but no later than the second working day of every month. FMPA will then provide a monthly payment to OEU in the form of a credit on the ARP power bill for the excess energy delivered to the distribution grid. The ARP Renewable Generation Credit will be calculated as follows:

ARP Renewable Generation Credit = Quarterly Energy Rate \* Monthly kWh of excess customer-owned renewable generation

Quarterly Energy Rate = 3 month average of ARP energy rate. FMPA will update the Quarterly Energy Rate every April 1, July 1, October 1 and January 1.

b) As part of the monthly bill adjustment, FMPA will also increase OEU's kWh billing amount by the same kWh amount as the customer-owned renewable generation purchased by FMPA. This adjustment is necessary because excess customer generation that flows onto OEU's electric system has been purchased by FMPA, but will remain on OEU's electric system and be used by OEU to meet its other customers' electric needs. As a result, OEU's monthly ARP bill will be adjusted accordingly to reflect FMPA's subsequent sale of this energy to OEU.

## II. Payment for Unused Excess Energy Credits

- a) Monthly excess energy credits shall accumulate and be used to offset the Customer's following month energy consumption bill for a period of not more than twelve (12) months.
- b) At the end of each calendar year, OEU shall pay the Customer for any unused excess energy credits in accordance with the OEU Electric Net-Metering Service Rate Schedule.

Issued by: Michael Poucher, P.E. Effective: October 1, 2019

Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA

FIRST REVISED SHEET NO. 21.0 CANCELS ORIGINAL SHEET NO. 21.0

## **Tier 1 – Standard Interconnection Agreement Customer-Owned Renewable Generation System**

This <b>Agreement</b> is made and er	ntered into this 23rd day of	June	_, 20 <u>25</u> , 1	by and
between <u>Deborah Baker</u>	, (hereina	fter called "Cus	tomer"), loc	ated at
13048 NE 7th Loop in _	Silver Springs , F	lorida, and the	City of Oc	ala doing
business as Ocala Electric Utili	ty (hereinafter called OEU)	, a body politic	. Customer	and OEU
shall collectively be called the "I	Parties". The physical locati	ion/premise whe	ere the interc	onnection
is taking place: 13048 NE 7th	Loop Silver Springs, FL. 3	34488		

## WITNESSETH

Whereas, a Tier 1 Renewable Generation System (RGS) is an electric generating system that uses one or more of the following fuels or energy sources: hydrogen, biomass, solar energy, geothermal energy, wind energy, ocean energy, waste heat, or hydroelectric power as defined in Section 377.803, Florida Statutes, rated at no more than ten (10) kilowatts (10 kW) alternating current (AC) power output and is primarily intended to offset part or all of the Customer's current electric requirements; and

Whereas, OEU operates an electric system serving the City of Ocala; and

Whereas, Customer has made a written Application to OEU, a copy being attached hereto, to interconnect its RGS with OEU' electrical supply grid at the location identified above; and

Whereas, the City of Ocala and the Florida Municipal Power Agency (hereinafter called "FMPA") have entered into the All-Requirements Power Supply Contract pursuant to which the City of Ocala has agreed to purchase and receive, and FMPA has agreed to sell and supply OEU with all energy and capacity necessary to operate the OEU electric system, which limits OEU' ability to directly purchase excess energy from customer-owned renewable generation; and

Whereas, in order to promote the development of small customer-owned renewable generation by permitting OEU to allow its customers to interconnect with OEU's electric system and to allow OEU customers to offset their electric consumption with customer-owned renewable generation, FMPA, in accordance with the terms and conditions of this agreement, has agreed to purchase excess customer-owned generation from OEU customers interconnected to OEU's electric system; and

Whereas, the OEU desires to provide interconnection of a RGS under conditions which will insure the safety of OEU customers and employees, reliability and integrity of its distribution system;

**NOW, THEREFORE**, for and in consideration of the mutual covenants and agreements herein set forth, the parties hereto covenant and agree as follows:

(Continued on Sheet No. 21.1)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.0)

FIRST REVISED SHEET NO. 21.1 CANCELS ORIGINAL SHEET NO. 21.1

- 1. The Customer shall be required to enter into a Tri-Party Net-Metering Purchase Power Agreement with FMPA and the City of Ocala Electric Utility (OEU).
- 2. "Gross power rating" (GPR) means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with OEU's distribution facilities. For inverter-based systems, the GPR shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.
- 3. This agreement is strictly limited to cover a Tier 1 RGS as defined above. It is the Customer's responsibility to notify OEU of any change to the GPR of the RGS by submitting a new application for interconnection specifying the modifications at least 30 days prior to making the modifications. Increase in GPR above the ten kilowatt (10 kW) limit would necessitate entering into a new agreement at either Tier 2 or Tier 3 which may impose additional requirements on the Customer. In no case does the Tier 1, Tier 2 or Tier 3 agreement cover increases in GPR above two megawatts (2MW).
- 4. The RGS GPR must not exceed 90 percent (90%) of the Customer's OEU calculated distribution service rating at the Customer's location (including shared electric facilities). If the GPR does exceed the 90 percent (90%) limit, the Customer shall be responsible to pay the cost of upgrades to the distribution facilities required to accommodate the GPR capacity and ensure the 90 percent (90%) threshold is not breached. OEU will not allow a RGS GPR greater than required to offset the customer's annual kWh energy consumption (based on customer's historical consumption data or by means of estimated usage of similar type of service as determined by OEU).
- 5. The Customer shall not be required to pay any special fees due solely to the installation of the RGS.
- 6. The Customer shall fully comply with OEU's Design Standards following NEC standards as those documents may be amended or revised by OUS from time to time.
- 7. The Customer certifies that its installation, its operation and its maintenance shall be in compliance with the following standards (or most current version at time of inspection approval):
  - a. IEEE-1547 (2018) Standard for Interconnecting Distributed Resources with Electric Power System;
  - b. IEEE-1547.1 (2005) Standard Conformance Test Procedures for Equipment Interconnection Distributed Resources with Electric Power Systems;
  - c. UL-1741 (2010) Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed *Energy Resources*.
  - d. The National Electric Code, state and/or local building codes, mechanical codes and/or electrical codes:
  - e. The manufacturer's installation, operation and maintenance instructions.

(Continued to Sheet No. 21.2)

Effective: October 1, 2019

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.1)

FIRST REVISED SHEET NO. 21.2 CANCELS ORIGINAL SHEET NO. 21.2

- 8. The Customer is not precluded from contracting for the lease, operation or maintenance of the RGS with a third party. Such lease may not provide terms or conditions that provide for any payments under the agreement to any way indicate or reflect the purchase of energy produced by the RGS. Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the customer-owned renewable generation. Notwithstanding this restriction, in the event that Customer is determined to have engaged in the retail purchase of electricity from a party other than OEU, then Customer shall be in breach of this Agreement and may be subject to the jurisdiction of the Florida Public Service Commission and to fines/penalties.
- 9. The Customer shall provide a copy of the manufacturer's installation, operation and maintenance instructions to OEU. If the RGS is leased to the Customer by a third party, or if the operation or maintenance of the RGS is to be performed by a third party, the lease and/or maintenance agreements and any pertinent documents related to these agreements shall be provided to OEU.
- 10. Prior to commencing parallel operation with OEU's electric system, Customer shall have the RGS inspected and approved by the appropriate code authorities having jurisdiction. Customer shall provide a copy of this inspection and approval to OEU.
- 11. The Customer agrees to permit OEU, if it should so choose, to inspect the RGS and its component equipment and the documents necessary to ensure compliance with this Agreement both before and after the RGS goes into service and to witness the initial testing of the RGS equipment and protective apparatus. OEU will provide Customer with as much notice as reasonably possible, either in writing, email, facsimile or by phone as to when OEU may conduct inspections and or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, Customer agrees to provide OEU access to the Customer's premises for any purpose in connection with the performance of the obligations required by this Agreement or, if necessary, to meet OEU's legal obligation to provide service to its customers. At least ten (10) business days prior to initially placing the customer-owned renewable generation system in service, Customer shall provide written notification to OEU advising of the date and time at which Customer intends to place the system in service, and OEU shall have the right to have personnel present on the in-service date in order to ensure compliance with the requirements of this Agreement.

(Continued on Sheet No. 21.3)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.2)

FIRST REVISED SHEET NO. 21.3 CANCELS ORIGINAL SHEET NO. 21.3

- 12. The Customer's RGS must have an appropriately sized grid-tie inverter system that includes applicable protective systems. Customer certifies that the RGS equipment includes an OEU interactive inverter or interconnection system equipment that ceases to interconnect with the OEU system upon a loss of OEU's electric power. The inverter shall be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing laboratory (NRTL) to comply with UL 1741. The NRTL shall be approved by the Occupational Safety & Health Administration (OSHA).
- 13. If Customer adds another RGS that (i) utilizes the same OEU interactive inverter for both systems, or (ii) utilizes a separate OEU interactive inverter for each system, Customer shall provide OEU with sixty (60) days advance written notice of the addition.
- 14. The Customer shall not energize the OEU system when OEU's system is deenergized. The Customer shall cease to energize the OEU system during a faulted condition on the OEU system and/or upon any notice from OEU that the deenergizing of Customer's RGS equipment is necessary. The Customer shall cease to energize the OEU system prior to automatic or non-automatic reclosing of OEU's protective devices. There shall be no intentional islanding, as described in IEEE 1547, between the Customer's and OEU' systems.
- 15. The Customer is responsible for the protection of its generation equipment, inverters, protection devices, and other system components from damage from the normal and abnormal operations that occur on OEU system in delivering and restoring system power. Customer agrees that any damage to any of its property, including, without limitation, all components and related accessories of its RGS system, due to the normal or abnormal operation of OEU system, is at Customer's sole risk and expense. Customer is also responsible for ensuring that the customer-owned renewable generation equipment is inspected, maintained, and tested regularly in accordance with the manufacturer's instructions to ensure that it is operating correctly and safely.
- 16. The Customer must install, at their expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the customer-owned renewable generation system and any Customer wiring connected to OEU's system, such that back feed from the customer-owned renewable generation system to OEU's system cannot occur when the switch is in the open position. The manual disconnect switch shall be mounted separate from the meter socket on an exterior surface adjacent to the meter. The switch shall be readily accessible to OEU and capable of being locked in the open position with an OEU padlock. When locked and tagged in the open position by OEU, this switch will be under the control of OEU.

(Continued on Sheet No. 21.4)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.3)

FIRST REVISED SHEET NO. 21.4 CANCELS ORIGINAL SHEET NO. 21.4

- 17. Subject to an approved inspection, including installation of acceptable disconnect switch, this Agreement shall be executed by OEU within thirty (30) calendar days of receipt of a completed application. Customer must execute this Agreement and return it to OEU at least thirty (30) calendar days prior to beginning parallel operations with OEU's electric system, subject to the requirements of Section 18, below, and within one (1) year after OEU executes this Agreement.
- 18. Once OEU has received Customer's written documentation that the requirements of this Agreement have been met, all agreements and documentation have been received and the correct operation of the manual switch has been demonstrated to an OEU representative, OEU will, within fifteen (15) business days, send written notice that parallel operation of the RGS may commence.
- 19. OEU requires the Customer to maintain general liability insurance for personal injury and property damage in the amount of not less than one hundred thousand dollars (\$100,000.00).
- 20. OEU will furnish, install, own and maintain metering equipment capable of measuring the flow of kilowatt-hours (kWh) of energy. The Customer's service associated with the RGS will be metered to measure the energy delivered by OEU to Customer, and measure the energy delivered by Customer to OEU. Customer agrees to provide safe and reasonable access to the premises for installation, maintenance and reading of the metering and related equipment. The Customer shall not be responsible for the cost of the installation and maintenance of the metering equipment necessary to measure the energy delivered by the Customer to OEU.
- 21. The Customer shall be solely responsible for all legal and financial obligations arising from the design, construction, installation, operation, maintenance and ownership of the RGS.
- 22. The Customer must obtain all permits, inspections and approvals required by applicable jurisdictions with respect to the generating system and must use a licensed, bonded and insured contractor to design and install the generating system. The Customer agrees to provide OEU with a copy of the local building code official inspection and certification of installation. The certification shall reflect that the local code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.

(Continued on Sheet No. 21.5)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.4)

FIRST REVISED SHEET NO. 21.5 CANCELS ORIGINAL SHEET NO. 21.5

- 23. In no event shall any statement, representation, or lack thereof, either express or implied, by OEU, relieve the Customer of exclusive responsibility for the Customer's system. Specifically, any OEU inspection of the RGS shall not be construed as confirming or endorsing the system design or its operating or maintenance procedures or as a warranty or guarantee as to the safety, reliability, or durability of the RGS. OEU's inspection, acceptance, or its failure to inspect shall not be deemed an endorsement of any RGS equipment or procedure. Further, as set forth in Sections 15 and 26 of this Agreement, Customer shall remain solely responsible for any and all losses, claims, damages and/or expenses related in any way to the operation or misoperation of its RGS equipment.
- 24. Notwithstanding any other provision of this Interconnection Agreement, OEU, at its sole and absolute discretion, may isolate the Customer's system from the distribution grid by whatever means necessary, without prior notice to the Customer. To the extent practical, however, prior notice shall be given. The system will be reconnected as soon as practical once the conditions causing the disconnection cease to exist. OEU shall have no obligation to compensate the Customer for any loss of energy during any and all periods when Customer's RGS is operating at reduced capacity or is disconnected from OEU' electrical distribution system pursuant to this Interconnection Agreement. Typical conditions which may require the disconnection of the Customer's system include, but are not limited to, the following:
  - a. OEU system emergencies, forced outages, uncontrollable forces or compliance with prudent electric OEU practice.
  - b. When necessary to investigate, inspect, construct, install, maintain, repair, replace or remove any OEU equipment, any part of OEU's electrical distribution system or Customer's generating system.
  - c. Hazardous conditions existing on OEU's system due to the operation of the Customer's generation or protective equipment as determined by OEU.
  - d. Adverse electrical affects (such as power quality problems) on the electrical equipment of OEU's other electric consumers caused by the Customer's generation as determined by OEU.
  - e. When Customer is in breach of any of its obligations under this Interconnection Agreement or any other applicable policies and procedures of OEU.
  - f. When the Customer fails to make any payments due to OEU by the due date thereof.
- 25. Upon termination of services pursuant to this Agreement, OEU shall open and padlock the manual disconnect switch and remove any additional metering equipment related to this Agreement. At the Customer's expense, within thirty (30) working days following the termination, the Customer shall permanently isolate the RGS and any associated equipment from OEU's electric supply system, notify OEU that the isolation is complete, and coordinate with OEU for return of OEU's lock.

(Continued to Sheet No. 21.6)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.5)

FIRST REVISED SHEET NO. 21.6 CANCELS ORIGINAL SHEET NO. 21.6

- 26. To the fullest extent permitted by law, and in return for adequate, separate consideration, Customer shall indemnify, defend and hold harmless OEU, any and all of their members of its governing bodies, and its officers, agents, and employees for, from and against any and all claims, demands, suits, costs of defense, attorneys fees, witness fees of any type, losses, damages, expenses, and liabilities, whether direct, indirect or consequential, related to, arising from, or in any way connected with:
  - a. Customer's design, construction, installation, inspection, maintenance, testing or operation of Customer's generating system or equipment used in connection with this Interconnection Agreement, irrespective of any fault on the part of OEU.
  - b. The interconnection of Customer's generating system with, and delivery of energy from the generating system to, OEU's electrical distribution system, irrespective of any fault on the part of OEU.
  - c. The performance or nonperformance of Customer's obligations under this Interconnection Agreement or the obligations of any and all of the members of Customer's governing bodies and its officers, agents, contractors (and any subcontractor or material supplier thereof) and employees.

Customer's obligations under this Section shall survive the termination of this Interconnection Agreement.

- 27. Customer shall not have the right to assign its benefits or obligations under this Agreement without OEU's prior written consent and such consent shall not be unreasonably withheld. If there is a change in ownership of the RGS, Customer shall provide written notice to OEU at least thirty (30) days prior to the change in ownership. The new owner will be required to assume, in writing, the Customer's rights and duties under this Agreement, or execute a new Standard Interconnection Agreement. The new owner shall not be permitted to net meter or begin parallel operations until the new owner assumes this Agreement or executes a new Agreement.
- 28. This Agreement supersedes all previous agreements and representations either written or verbal heretofore made between OEU and Customer with respect to matters herein contained. This Agreement, when duly executed, constitutes the only Agreement between parties hereto relative to the matters herein described. This Agreement shall continue in effect from year to year until either party gives sixty (60) days' notice of its intent to terminate this Agreement.

(Continued on Sheet No. 21.7)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.6)

FIRST REVISED SHEET NO. 21.7 CANCELS ORIGINAL SHEET NO. 21.7

29. This Agreement shall be governed by and construed and enforced in accordance with the laws, rules and regulations of the State of Florida and OEU's tariff as it may be modified, changed, or amended from time to time, including any amendments modification or changes to OEU's Net-Metering Service Rate Schedule, the schedule applicable to this Agreement. The Customer and OEU agree that any action, suit, or proceeding arising out of or relating to this Interconnection Agreement shall be initiated and prosecuted in the state court of competent jurisdiction located in Marion County, Florida, and OEU and the Customer irrevocably submit to the jurisdiction and venue of such court. To the fullest extent permitted by law, each Party hereby irrevocably waives any and all rights to a trial by jury and covenants and agrees that it will not request a trial by jury with respect to any legal proceeding arising out of or relating to this Interconnection Agreement.

None of the provisions of this Interconnection Agreement shall be considered waived by either Party except when such waiver is given in writing. No waiver by either Party of any one or more defaults in the performance of the provisions of this Interconnection Agreement shall operate or be construed as a waiver of any other existing or future default or defaults. If any one or more of the provisions of this Interconnection Agreement or the applicability of any provision to a specific situation is held invalid or unenforceable, the provision shall be modified to the minimum extent necessary to make it or its application valid and enforceable, and the validity and enforceability of all other provisions of this Interconnection Agreement and all other applications of such provisions shall not be affected by any such invalidity or unenforceability. This Interconnection Agreement does not govern the terms and conditions for the delivery of power and energy to non-generating retail customers of OEU's electrical distribution system.

- 30. This Agreement incorporates by reference the terms of the tariff filed with the Florida Public Service Commission by OEU, including OEU's Net-Metering Service Rate Schedule, and associated technical terms and abbreviations, general rules and regulations and standard electric service requirements (as may be applicable) are incorporated by reference, as amended from time to time. To the extent of any conflict between this Agreement and such tariff, the tariff shall control.
- 31. OEU and Customer recognize that the Florida Statutes and/or the Florida Public Service Commission Rules, including those directly addressing the subject of this Agreement, may be amended from time to time. In the event that such statutes and/or rules are amended that affect the terms and conditions of this Agreement, OEU and Customer agree to supersede and replace this Agreement with a new Interconnection Agreement, which complies with the amended statutes/rules.

(Continued on Sheet No. 21.8)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.7)

FIRST REVISED SHEET NO. 21.8 CANCELS ORIGINAL SHEET NO. 21.8

- 32. Customer acknowledges that its provision of electricity to OEU hereunder is on a first-offered, first-accepted basis and subject to diminution and/or rejection in the event the total amount of electricity delivered to OEU pursuant to the OEU's Net-Metering Service Rate Schedule, (as filed with the Florida Public Service Commission), from all participating OEU customers, exceeds two and one-half percent (2.5%) of the aggregate customer peak demand on the OEU system.
- 33. This Agreement is solely for the benefit of OEU and Customer and no right nor any cause of action shall accrue upon or by reason, to or for the benefit of any third party not a formal party to this Agreement. Nothing in this Agreement, expressed or implied, is intended or shall be construed to confer upon any person or corporation other than OEU or Customer, any right, remedy, or claim under or by reason of this Agreement or any of the provisions or conditions of this Agreement; and, all provisions, representations, covenants, and conditions contained in this Agreement shall inure to the sole benefit of and be binding upon OEU and Customer and their respective representatives, successors, and assigns. Further, no term or condition contained in this Agreement shall be construed in any way as a waiver by OEU of the sovereign immunity applicable to OEU as established by Florida Statutes, 768.28.

(Continued on Sheet No. 21.9)

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.8)

## FIRST REVISED SHEET NO. 21.9 CANCELS ORIGINAL SHEET NO. 21.9

Effective: October 1, 2019

**IN WITNESS WHEREOF**, Customer and OEU have executed this Agreement the day and year first above written.

City of Ocala Electric Utility:	Customer:
Signed by:  By: Jania Mitdell  55198B43858A4E1  Title: CFO	By: Deborah Baker  (Print Name)  (Signature)
Date: 11/6/2025	Date: (6/23/25
	City of Ocala Electric Utility Account Number:
	570584-260717
Approved as to form and legality:	Signed by:
Robert W. Batsel, Jr. Assistant City Attorney	William E. Scoton, Esq. William E. Sexton, Esq. City Attorney

Masonry

2024

AT4

**HOMEOWNERS POLICY** 

**Location of Residence Premises** 

H-19-6757-FB0E F H W

BAKER, DEBORAH & KEVIN 13048 NE 7TH LOOP SILVER SPGS FL 34488



## **DECLARATIONS**

AMOUNT DUE: None Payment is due by TO BE PAID BY MORTGAGEE

**Policy Number:** 79-ER-K497-8

Policy Period: 12 Months

Effective Dates: MAR 26 2025 to MAR 26 2026

The policy period begins and ends at 12:01 am standard

time at the residence premises.

Your State Farm Agent BRADLEY BLESSING 5612 SE ABSHIER BLVD BELLEVIEW FL 34420-4067

Phone: (352) 307-4471

Roof Material: Composition Shingle Roof Installation Year: 2024

Automatic Renewal

Construction:

Year Built:

13048 NE 7TH LOOP

SILVER SPGS FL 34488

If the **POLICY PERIOD** is shown as **12 MONTHS**, this policy will be renewed automatically subject to the premiums, rules, and forms in effect for each succeeding policy period. If this policy is terminated, we will give you and the Mortgagee/Lienholder written notice in compliance with the policy provisions or as required by law.

## **IMPORTANT MESSAGES**

Zone: 94

For questions, problems, or to obtain information about coverage call: 352-307-4471

### **PREMILIM**

ITILIMITORI		
Annual Premium		\$ 1,133.00
Covered Loss Due to		
Hurricane Event	254.00	(Included)
Other Covered Losses	879.00	(Included)
Res Credit HB 7073		\$ 19.84cr
FM Credit HB 7073		\$ 2.85cr
FIGA ASSESSMENT 5		\$ <b>11.</b> 33
FL EMPA ASSESSMENT		\$ 2.00
Home/Auto		
Utility Rating Cr		
Claim Record		
Bldg Code Rating		
Wind Mittigation		
Loyal Customer		

Total Premium \$ 1,123.64

Prepared APR 02 2025



## NAMED INSURED

## MORTGAGEE AND ADDITIONAL INTERESTS

BAKER, DEBORAH & KEVIN

Mortgagee CORNING FEDERAL CREDIT UNION ISAOA / ATIMA C/O LEE & MASON FINANCIAL SERVICES PO BOX 150 NORTHVILLE NY 12134-0150

Loan Number: 10025386

## **SECTION I - PROPERTY COVERAGES AND LIMITS**

Coverage	Limit of Liability
A Dwelling	\$ 331,000
Other Structures	\$ 33,100
B Personal Property	\$ 248,250
C Loss of Use	\$ 99,300
Additional Coverages	
Arson Reward	\$1,000
Credit Card, Bank Fund Transfer Card, Forgery, and Counterfeit Money	\$1,000
Debris Removal	Additional 5% available/\$1,000 tree debris
Fire Department Service Charge	\$500 per occurrence
Fuel Oil Release	\$10,000
Locks and Remote Devices	\$1,000
Trees, Shrubs, and Landscaping	5% of Coverage A amount/\$750 per item
OFOTION III. LIADIUTY COVERAGES AND LIBATO	

## SECTION II - LIABILITY COVERAGES AND LIMITS

Coverage	Limit	of Liability
L Personal Liability (Each Occurrence)	\$	500,000
Damage to the Property of Others	\$	1,000
M Medical Payments to Others (Each Person)	\$	5,000

## INFLATION


Inflation Coverage Index: 371.9


## **DEDUCTIBLES**

Section I Deductible	Deducti	ble Amount
Hurricane 2%	<b>\$</b>	<b>6,620</b>
Other Losses	\$	1,000

## LOSS SETTLEMENT PROVISIONS

A1 Replacement Cost - Similar Construction B1 Limited Replacement Cost - Coverage B





# SolarEdge Home Hub Inverter USA Domestic Content Eligible\* Single Phase, for North America

SE3800H-US / SE5700H-US / SE7600H-US / SE10000H-US /

**HOME BACKUP** 







# SolarEdge's USA-manufactured residential single phase inverter offering for storage and backup applications

- I Eligible for domestic content: SolarEdge USAmanufactured inverters\*, when paired with certain SolarEdge power optimizers, are intended to be eligible for the enhanced federal income tax credit for domestic
- The ultimate home energy manager in charge of PV production, battery storage, backup operation during a power outage\*, EV Charging, and smart energy devices Record-breaking 99% weighted efficiency with up
  - record-breaking 35% weighted elliciency will to 200% DC oversizing

Embedded revenue grade production data, ANSI C12.20

NEMA 4X-rated, for indoor and outdoor installations Embedded Power Control System (PCS) – install larger

Advanced reliability with automotive-grade component

protection and rapid shutdown for 690.11 and 690.12

Advanced safety features with integrated arc fault

needs through easy connection to a growing ecosystem

A scalable solution that supports future homeowner

Fast and easy installation – small and lightweight, with

- Able to start high LRA HVAC systems during backup
- Integrates seamlessly with the complete SolarEdge Home Smart Energy Ecosystem, through SolarEdge Home
- Module-level monitoring and visibility of battery status
   PV production, and self-consumption data

And the state of t

information, please contact your local SolarEdge sales representative.
\*\*\* Remines additional handware and firmware version contacts.

solaredge.com



# / SolarEdge Home Hub Inverter USA Domestic Content Eligible

# Single Phase, for North America

SE3800H-US / SE5700H-US / SE7600H-US / SE10000H-US / SE11400H-US

Applicable to inverters with part number		SExxxxxH-USN	INxBLx5 / USEx	SExxxxxH-USMNxBLx5 / USExxxxxH-USMNBL75		
Model Number <sup>(1)</sup>	SE3800H-US	SE5700H-US	SE7600H-US	SE10000H-US	SE11400H-US	
OUTPUT - AC ON GRID						
Maximum AC Power Output	3800 @ 240V	5760 @ 240V 5000 @ 208V	7600 @ 240V	10,000 @ 240V	11,400 @ 240V	3
AC Output Voltage (Nominal)			208 / 240	=		Vac
AC Output Voltage (Range)			183 - 264			Vac
AC Frequency Range (min - nom - max)			59.3 - 60 - 60.57			ZΗ
Maximum Continuous Output Current	16 @ 240V 16 @ 208V	24 @ 208V	32 @ 240V	42 @ 240V	47.5 @ 240V 48 @208V	4
GFDIThreshold			-	=		<
Total Harmonic Distortion (THD)			× 3			88
Power Factor			1, adjustable -0.85 to 0.85	0.85		
Utility Monitoring, Islanding Protection, Country Configurable Thresholds			Yes			
Charge Battery from AC (if allowed)			Yes			
Typical Nighttime Power Consumption			< 2.5			3
OUTPUT – AC STANDALONE (BACKUP)(3)						
Rated AC Power in Standalone Operation <sup>(4)</sup>			11,400			>
Maximum Continuous Output Current in Standalone Operation			48			⋖
Locked Rotor Amperage (LRA) <sup>(5)</sup>			Up to 106			⋖
AC L-L Output Voltage Range in Standalone Operation			211 – 264			Vac
AC L-N Output Voltage Range in Standalone Operation			105 - 132			Vac
AC Frequency Range in Standalone Operation (min - nom - max)			55-60-65			Ξ
GFDI			-			⋖
TED			< > ×			96
INPUT – DC (PV AND BATTERY)						
Transformer-less, Ungrounded			Yes			
Maximum Input Voltage			480			Vdc
Nominal DC Input Voltage			380			Vdc
Reverse-Polarity Protection			Yes			
Ground-Fault Isolation Detection			600kD Sensitivity			
Maximum Input Short Circuit Current			45			Adc
Maximum Inverter Efficiency			39.2			%
CEC Weighted Efficiency	98.	52		66	99 @ 240V 98.5 @ 208V	96
2-Pole Disconnection			Yes			
DC CONNECTION – PV						
Maximum Input Power	7600 @ 240V 6600 @ 208V	11,520 @ 240V 10,000 @ 208V	15,200 @ 240V	20,000 @ 240V	22,800 @ 240V 20,000 @ 208V	3
Maximum Input Current	20 @ 240V 17 @ 208V	30 @ 240V 26 @ 208V	40 @ 240V	53 @ 240V	60 @ 240V 53 @ 208V	Adc
Number of Ports			3			
Maximum Current per Port			40			Adc

e specifications apply to inverters with part number **SExxxot-USN/Neb.1.5** and **USExxxot-USN/Neb.7.5** and connection unit model number **DCD-(IPH-US-PAH-F-x** the recipied entities place refer to the State-Time Inverter; Power Control Collabora analyzition note.

(2) For drive regional settings passe refer to the <u>Supergram metrics, trought control Laterian application</u> in 70%. (3) Not designed for more applications and requires AC for commissioning, Sandalane, Beakup) functionalty is only apported for the 240V grid.

(4) For mode as block-to-and below, the hadren Kerlowelin Sahdalove Operation's computable terween (block with a Madmum Continuous Output Cut Confinitious Output Current of 464, from Timmare version is a continuous of the continuous Output Cut. The continuous Output Cut. The continuous Output Cut. The continuous of the cut of 464, from the Cut. The continuous of the cut of 464 of the cut of th

ion about LRA (Locked Rotor Amperage) values, see the <u>SclatEdge Home Hub Inverner LRA</u> application note.



# / SolarEdge Home Hub Inverter USA Domestic Content Eligible

# Single Phase, for North America

SE3800H-US / SE5700H-US / SE7600H-US / SE10000H-US / SE11400H-US

Model Number <sup>(1)</sup>			L		
	SE3800H-US	SE5700H-US SE760	SE7600H-US SE10000H-US	SE11400H-US	
DC CONNECTION – BATTERY					
Supported Battery Types		SolarEdge Hor	SolarEdge Home Battery 400V		
Number of Batteries per Inverter		dN	Up to 3		
Maximum Continuous Power (Charge and Discharge) <sup>(6)</sup>		117	11,400		≥
Number of Ports			2		
Maximum Current per Port		7	40		Ack
2-pole Disconnection		Up to the inverter's ra	Up to the inverter's rated standalone power		
SMART ENERGY CAPABILITIES					
Consumption Metering		Buil	Built-in <sup>(2)</sup>		
Standalone & Battery Storage	With Bac	cup Interface (purchased separate	With Backup Interface (purchased separately) for service up to 2004; up to 3 inverters	inverters	
EV Charging		Direct connection to the So	Direct connection to the SolarEdge Home EV Charger <sup>(8)</sup>		
ADDITIONAL FEATURES					
Supported Communication Interfaces	RS485, E	thernet, Cellular®, Wi-Fi <sup>(10)</sup> (option	RS485, Ethernet, Cellular <sup>(9)</sup> , Wi-Fi <sup>(70)</sup> (optional), SolarEdge Home Network <sup>(7))</sup> (optional)	optional)	
Revenue Grade Metering, ANSI C12.20		Buil	Built-in <sup>(2)</sup>		
Integrated AC, DC, and Communication Connection Unit		λ	(es		
Inverter Commissioning	With the S	etApp mobile application using b	With the SetApp mobile application using built-in Wi-Fi Access Point for local connection	connection	
DC Voltage Rapid Shutdown (PV and Battery)		Yes, NE	Yes, NEC 690.12		
STANDARD COMPLIANCE					
Safety	UL 1741, UL 1741	SA, UL 1741SB, UL 1699B, CSA 22	UL 1741, UL 1741SA, UL 1741SB, UL 1699B, CSA 22.2#107.1, C22,2#330, C22.3#9, ANSJ/CAN/UL 9540	SI/CAN/UL 9540	
Grid Connection Standards		IEEE1547-2018 and IEEE	IEEE1547-2018 and IEEE-1547.1 Rule 21, Rule 14H		
Emissions		FCC Part	FCC Part 15 Class B		
Power Control System (PCS)		M1170	UL 1741 PCS <sup>III</sup>		
INSTALLATION SPECIFICATIONS					
AC Terminals		L1, L2, N terminal blocks, PE I L1, L2 terminal blocks, PE busba	L1, L2, N terminal blocks, PE busbar for inverter connection L1, L2 terminal blocks, PE busbar for EV Charger AC connection		
DC Terminals	3×t	erminal block pairs for PV input, 2	3 x terminal block pairs for PV input, 2 x terminal block pair for battery input	nput	
AC Output and EV AC Output Conduit Size / AWG Range		1" maximum	1" maximum / 14 – 4 AWG		
DC Input (PV and Battery) Conduit Size / AWG Range		1" maximum	1" maximum / 14 – 6 AWG		
Dimensions with Connection Unit (H $\times$ W $\times$ D)		21.06 x 14.6 x 8.2	21.06 x 14.6 x 8.2 / 535 x 370 x 208		) III
Weight with Connection Unit		44.9	44.9 / 20.3		lb/kg
Noise		>	50		dBA
Cooling		NaturalC	NaturalConvection		
Operating Temperature Range		-40 to +140 /	-40 to +140 / -40 to +60 <sup>123</sup>		D, / J,
Protection Rating		NEW	NEMA 4X		

(6) Discharge power is limited up to the inverter's rated AC power for on-grid and standalone applications, as well as up to the installed batteries' rating.
(7) For consumption metering current transformers should be ordered separately, SECT-501-225A-T-20 or SEACT/250-(IQDNA-20, Revenue grade metering is only

(9) Information concerning the data plan terms & conditions is available in Salasticae Communication Plan Teams and Conditions.


(10) Solarcige Home Network Plugin ENET-HBNR-01 and Wi-Fi Antenna SE-ANT-ZBWFHATT purchased separately, For more information, reter to the <u>Solarcige Home Network Plugin</u> datastic Antenna for Wi-Fi and Zingkee Wireless Communications datastinet.

Antenna for VII-H and Littlee Wireless Communications datastived. Only part numbers SExxxxxiH-USMN kxx/IX and USExxxxxH-USMNxx/IX support the PCS meter.

power up to at least 12217 / 501°C; for power derating information refer to the <u>Temperature Derating for North America</u> technics



8. Subtage Techologia, Ltd. Alinghis reserved, SCA-REDGE, this Schaefage logy, CPTM/LED BY SCLAREDGE are tradomate or registered tradomate of Schaefage Technologies, Inc. All other tradematis mentioned herein are trademarks of their respective owners. Date Schember 12, 2024 DS-CO2229-AMM, Subject to change without notice.




# Residential Power Optimizer **USA Domestic Content Eligible\***

**U650** 

For North America





# Solar Edge's USA-manufactured residential offering for PV power optimization at the module level

- USA-manufactured Power Optimizers\*, when paired with certain SolarEdge inverters, are intended to be eligible for the enhanced federal income tax credit Eligible for domestic content: SolarEdge for domestic content
- Specifically designed to work with SolarEdge residential inverters
- Superior efficiency (99.5%)
- Mitigates diverse types of module mismatch loss, from manufacturing tolerance to partial shading

solaredge.com

- management and easy assembly using a single bolt Faster installations with simplified cable
- Flexible system design for maximum space
- Compatible with a wide range of modules, including high-powered and bifacial PV modules
- Advanced safety:
- to automatically detect and prevent potential electric arcs at the connector level before an arc is created Patented Sense Connect technology, designed
- Patented SafeDCTM module-level voltage shutdown, for installer and firefighter safety
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System





## **USA Domestic Content Eligible for North America** / Residential Power Optimizer **U650**

	0650	Units
INPUT		
Rated Input DC Power <sup>()</sup>	059	×
Absolute Maximum Input Voltage (Voc)	09	Vdc
MPPT Operating Range	09=8	Vdc
Maximum Input Current (Maximum Isc of Connected PV Module)	15	Adc
Maximum Input Short Circuit Current <sup>(2)</sup>	18.75	Adc
Maximum Efficiency	5'66	38
Weighted Efficiency	986	%
Overvoltage Category	=	
OUTPUT DURING OPERATION (POWER	OUTPUT DURING OPERATION (POWER OPTIMIZER CONNECTED TO OPERATING SOLAREDGE INVERTER)	
Maximum Output Current	15	Adc
Maximum Output Voltage	09	Vdc
OUTPUT DURING STANDBY (POWER OF	OUTPUT DURING STANDBY (POWER OPTIMIZER DISCONNECTED FROM SOLAREDGE INVERTER OR INVERTER OFF)	
Safety Output Voltage per Power Optimizer	1±0,1	Vdc
STANDARD COMPLIANCE		
Photovoltaic Rapid Shutdown System	CSA C22.2#330, NEC 2014 = 2023	
EMC	FCC Part 15 Class B, IEC 61000-6-2, IEC 61000-6-3	
Safety	CSA C22,2#107.1, IEC 62109-1 (Class II safety), UL 1741	
Material	UL 94 V=0, UV Resistant	
RoHS	Yes	
Fire Safety	VDE-AR-E 2100-712;2013-05	
INSTALLATION SPECIFICATIONS		
Maximum Allowed System Voltage	0001	Vdc
Dimensions (W $\times$ L $\times$ H)	129 × 155 × 30 / 5.07 × 6.10 × 1.18	ni/mm
Weight	720 / 1.6	gr/b
Input Connector	MC4	
Input Wire Length	0.1/0.32	m/ft
Output Connector	MC4	
Output Wire Length	(+) 2.3, (-) 0.10 / (+) 7.54, (-) 0.32	m/ft
Operating Temperature Range <sup>(3)</sup>	-40 to +85	٠, د
Protection Rating	IP68 / NEMA6P	
Relative Humidity	0=100	3%

PV System Design Using a SolarEdge Inverter <sup>(4)</sup>	Jsing a	SolarEdge Home Wave / Hub Single Phase	Three Phase for 208V Grid	Three Phase for 277/480V Grid	Units
Minimum String Length (Power Optimizers)	wer Optimizers)	8	01	81	
Maximum String Length (Power Optimizers)	ower Optimizers)	25		508	
Maximum Usable Power Delivered per String	elivered per String	0025	0009	12,750	М
	Inverters with Rated AC Power ≤ 5700W	Per the inverter's maximum input DC power?			
Connected Power per	Inverters with Rated AC Power of 6000W	2,400	One string: 7200 Two strings or more: 7800	15,000	3
Stringware	Inverters with Rated AC Power ≥ 7600W	6800, only when connected to at least two strings			3
Parallel Strings of Different Lengths or Orientations	Lengths or		Yes		

## **Q.PEAK DUO BLK** ML-G10+ SERIES

21.1% Maximum Module Efficiency 395-415 Wp | 132 Cells

Domestic Content Option Available

MODEL





## 

## Includes Domestic Content

This product contains U.S. manufactured components which can controlled to qualifying for the 10% domestic content bonus to applicable tax credits under the Inflation Reduction Act of 2022.



# Q.ANTUM DUO Z Technology with zero gap cell layout boosts module efficiency up to 211%.

Breaking the 21% efficiency barrier



## A reliable investment

Inclusive 25-year product warranty and 25-year linear performance warranty.<sup>2</sup>



## Enduring high performance

Long-term yield security with Anti LeTID Technology, Anti PID Technology<sup>3</sup> and Hot-Spot Protect.



## Extreme weather rating

High-tech aluminum alloy frame, certified for high snow (5400 Pa) and wind loads (4000 Pa).



## Far beyond the standard

Qcells' comprehensive quality program ensures high long-term yields and the reliability of your solar system.



Assistances revolved not be held on the chemical control properties and change based on change made to the heldson feed-control sits surplementing tubes and regulations. Heave consult a qualified tax professional for specific guldanow. As the data shared more for them fermion medical.

As the stronditions according to ECT 75 (2004-2005, method 4—2500V, 590).





DCA 17 module has material code 'MD06G100A-017' printed on the module power label.

Rooftop arrays on residential buildings The ideal solution for:

\*DCA Module Option:



# Q.PEAK DUO BLK ML-G10+ SERIES


## Mechanical Specification

a comment	/+/VIII > +LIIII > LZOIII (IIICIUIII) II dilie)	_	
	(18/9 mm × 1045 mm × 3.2 mm)		
Weight	48.5 lbs (22.0 kg)	_	
Front Cover	0.13 in (3.2 mm) thermally pre-stressed glass with anti-reflection technology	4	1 - Grounding points e 0.12" (4.5 mm) 272.04" (850 mm)
Back Cover	Composite film		_
Frame	Black anodized aluminum		o
Cell	6 × 22 monocrystalline Q.ANTUM solar half cells		111000000000000000000000000000000000000
Junction box	2.09-3.98 in x 1.26-2.36 in x 0.59-0.71 in (53-101 mm x 32-60 mm x 15-18 mm), lP67, with bypass diodes		
Cable	4 mm² Solar cable; (+) ≥72.04 in (1830 mm), (−) ≥72.04 in (1830 mm)	<u></u>	a i Magazong gada daelah, Al
Connector	Stäubli MC4; IP68	- (20')22 mg	THE DESIGNATION OF THE PERSON

## ■ Electrical Characteristics

Manual Percentant Carrier Condition	Manual Harmon	8	POWER CLASS			395	400	405	410	415
Proves at MMPP	Short I MMP    Part   NY    355   400   405   410	Σ	IMUM PERFORMANCE AT STANDARD TEST	T CONDITIONS, ST	C' (POWER TOLERANCE +5 W/	/-0w)				
Short Clouck Current*         I <sub>c</sub>  A          110         114         117         1120           Open Clouck Current of Mode         I <sub>c</sub>  A           A          452         453         454         356         453         454         356         356         356         356         356         356         356         356         356         356         356         353         364         357         4276         4279	Short Cloude Current   I <sub>c</sub>   A    110   1114   1117   1120   1		Power at MPP¹	P <sub>see</sub>	[w]	395	400	405	410	415
Open Clicuit Voltage*         V <sub>c</sub> IVI         45.27         45.30         45.34         45.37 <td>Open Clicuit Voltage         V<sub>c</sub>         IVI         45.27         45.30         45.34         45.37</td> <th>·</th> <td>Short Circuit Current¹</td> <td>_8</td> <td>[A]</td> <td>11.10</td> <td>11.14</td> <td>11.17</td> <td>11.20</td> <td>11.23</td>	Open Clicuit Voltage         V <sub>c</sub> IVI         45.27         45.30         45.34         45.37	·	Short Circuit Current¹	_8	[A]	11.10	11.14	11.17	11.20	11.23
Counsent at MPP         Law         [A]         1071         1077         1083         1089         1           Efficiency         V <sub>coo</sub> [V]         3.688         3.713         3.739         3.764         3.764         3.764         3.764         3.764         3.764         3.764         3.764         3.769         3.764         3.769         3.764         3.769         3.764         3.769         3.764         3.709         3.764         3.709         3	Comment of MIPP         Lip.         [A]         1071         1077         1089         1           Voltage at MIPP         Vicing III         Voltage at MIPP         Vicing III         17         1089         3713         3739         3764         378           Filt cleancy         Vicing III         III         III         III         3201         2204         2206         2209         378           FINAL MA PERFORMANCE AT NORMAL DRESATING CONDITIONS, NINGTY         Page 1         2963         3001         3038         3076         2209         3076           Power of MAP Closel Connection Websige         Lip.         [A]         8.85         8.87         300         903         403           Contract at MIPP         Lip.         [A]         8.45         8.87         300         903         403           Contract at MIPP         Lip.         [A]         8.45         8.87         300         903         403           Contract at MIPP         Lip.         [A]         8.45         8.51         8.62         8.93           Contract at MIPP         Lip.         [A]         8.46         8.51         8.57         8.62         9.03           Contract at MIPP         Lip.	แทน	Open Circuit Voltage¹	Voc	N	45.27	45.30	45.34	45.37	45.41
Vulnage at MPP         V <sub>vv</sub> (V)         36.88         37.39         37.64         3           Efficiency         I         [8]         2.201         2.204         2.206         2.209         3           Power at MPP         I         [8]         3.9         3.9         3.0         3           Power at MPP         I         [8]         3.9         3.0         3.0         3           Short Clear to Unrent         V <sub>c</sub> [A]         8.95         8.97         9.0         9.3           Open Clear to Where the MPP         V <sub>c</sub> [A]         4.269         4.276         4.279         4           Vic         [A]         8.89         8.97         9.0         9.03         9.0           Open Clical to Value         [A]         8.89         8.97         9.0         9.03         9.0           Income at MPP         [A]         8.89         8.97         9.0         9.03         9.0           Income at MPP         [A]         8.89         8.9         8.2         8.9         9.3           Income at MPP         [A]         8.6         8.9         8.6         8.8         8.8           Income at MPP	Vollage at MPP         V <sub>ve</sub> IVI         S6.88         37.39         37.54         3           Efficiency         I         [8]         2.00         2.004         2.004         2.00         2.00         3           INMAUM PERFORMAZINCE AT NORMAL OPERATING CONDITIONS. NIMOTE         Power at MPP         Power         [VI         296.3         300.1         303.8         307.6         0.09         3           Short Clicuit Current         I <sub>C</sub> [A]         8.95         8.97         9.00         9.03         9.05<	ijui).	Current at MPP	lam	[A]	10.71	10.77	10.83	10.89	10.95
Fifticiency   1   [8]   2201   2204   2206   2209   2209   2201   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2204   2206   2204   2206   2204   2206   2204   2206   2204   2206   2204   2206   2204   2206   2204   2206	Fifticiency   1   [%]   2201   2204   2206   2209   2201   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209   2204   2206   2209	N	Voltage at MPP	V <sub>NPP</sub>	Σ	36.88	37.13	37.39	37.64	37.89
Power at MPP Depositive AT NORMAL OPERATING CONDITIONS, NMOT?         296.3         300.1         303.8         307.6           Power at MPP Depositive Current At MPP Control Current At MPP Depositive Current At MPP Depositive Current At MPP Nump (A) 8.6         8.95         8.97         9.00         9.03           Current at MPP Nump Nump Nump Nump Nump Nump Nump Nump	NIVIDAD   PERFORMANCE AT NORMAL OPERATING CONDITIONS, NIMOTF   Power at MPP   296.3   300.1   303.8   3076		Efficiency <sup>1</sup>	c	[%]	≥20.1	>20.4	≥20.6	≥20.9	>211
Power at MPP         Page 104         296.3         300.1         303.8         307.6           Short Clicuit Current         I <sub>c</sub> [A]         8.85         8.97         9.00         9.03           Open Circuit Voltage         V <sub>cc</sub> [V]         42.69         4.272         4.276         4.279         4           Current at MPP         I <sub>c</sub> [A]         8.46         8.51         8.57         8.2         4           Vision In Miles at MPP         V <sub>cc</sub> [V]         35.03         35.26         35.46         35.68         3	Power at Mathe         Part of Mathematic Mathematics (Mathematics Proceedings)         Part of Mathematics Procedured (Mathematics Procedured Mathematics Procedured	ž	NIMUM PERFORMANCE AT NORMAL OPER	ATING CONDITIONS	S, NMOT <sup>2</sup>					
Short Circuit Current	Short Cloud Current   Le   A    8.85   8.97   9.00   9.03		Power at MPP	P <sub>see</sub>	[w]	296.3	300.1	303.8	307.6	311.3
Open Circuit Veltage         V <sub>c</sub> [V]         4.269         4.272         4.279         4.29           Lower at MPP         Low (V)         (A)         8.46         8.81         8.57         8.62           Voltage at MPP         V <sub>c</sub> (V)         85.03         85.45         8.62         8.82	Open Circuit Vehage         V <sub>cc</sub> (V)         4.269         4.272         4.276         4.279	uir	Short Circuit Current	_8	[A]	8.95	8.97	9:00	9.03	9.05
Current at MPP         I <sub>lym</sub> (A)         (A)         8.46         8.51         8.62           Voltage at MPP         V <sub>lyps</sub> (V)         35.03         35.25         35.46         35.68         3	Connents MPP         Light         (A)         8.46         8.51         8.57         8.62           Voltage at MPP         V <sub>con</sub> = 10.         V <sub>con</sub> = 10.         8.50         35.03         35.	ıwjı	Open Circuit Voltage	Λ	Σ	42.69	42.72	42.76	42.79	42.83
V <sub>NPP</sub> [V] 35.03 35.25 35.46 35.68	89	IIM.	Current at MPP	5495	[A]	8.46	8.51	8.57	8.62	89.8
	Wessurement tolerances P <sub>rop</sub> ±3%; I <sub>5</sub> : V <sub>sr</sub> = 5% at STC: 1000 W/m², 25±2°C, AM 15 according to IEC 60904-3 • <sup>2</sup> 800 W/m², NMOT spectrum AM 15		Voltage at MPP	V <sub>NPP</sub>	Σ	35.03	35.25	35.46	35.68	35.89

At least 98% of nomi during first year. The 0.5% degradation pe least 93.5% of nomir up to 10 years. At lea	All date within meast tolerances. Full warra accordance with the terms of the Qcells s organization of your	2
	Al n	
) Constant	R	
y shareful	ą	
	9	
	8	
8 8 8		
[5] BEMOJ TVNIK		



PERFORMANCE AT LOW IRRADIANCE

**Qcells PERFORMANCE WARRANTY** 

Typical module perform comparison to STC con	
28	

\*Standard terms of guarantee for the 5 PV companies highest production capacity in 2021 (February 2021)

TEMPERATURE COEFFICIENTS
Temperature Coefficient of I<sub>sc</sub> Temperature Coefficient of P

+0.04 Temperature Coefficient of V <sub>oc</sub>	Nominal Module Operating Temperature
Temperat	Nomina
+0.04	-0.34

[%/K] [%/K]

[%/K] E Class II TYPE 2 -40 °F up to +185 °F (-40 °C up to +85 °C)

## ■ Properties for System Design Maximum System Voltage V<sub>svs</sub> [V] Maximum Series Fuse Rating [A DC]

Maximum System Voltage	V <sub>svs</sub>	Σ	1000 (JEC)/1000 (UL)	1000 (EC)/1000 (UL) PV module classification
Maximum Series Fuse Rating		[A DC]	20	Fire Rating based on ANSI/UL 61730
Max. Design Load, Push/Pull <sup>3</sup>		[bs/ft <sup>2</sup> ]	75 (3600 Pa)/55 (2660 Pa)	
Max. Test Load, Push/Pull <sup>3</sup>		[bs/ft <sup>2</sup> ]	113 (5400 Pa) / 84 (4000 Pa)	on Continuous Duty
<sup>3</sup> See Installation Manual				
:				
<ul> <li>Qualifications and Certificates</li> </ul>	Certif	icates		
UL6730-1 & UL6730-2, CE-compliant, Quality Controlled PV - TÜV Rheinland, IEC 67215.2016, IEC 6730-2016, U.S. Patent No. 9,893,215 (solar cells),			C Tuberdalia	
		,		

) ڙ

ocells



## **Certificate Of Completion**

Envelope Id: 4BF0FF1C-32E0-417F-8D55-9F3215AA285D

Subject: FOR SIGNATURES-Net Metering Agreement (Baker) (ELE/260179)

Source Envelope:

Document Pages: 28 Signatures: 5 **Envelope Originator:** Initials: 0 Certificate Pages: 5 Patricia Lewis

AutoNav: Enabled

Envelopeld Stamping: Enabled

Time Zone: (UTC-05:00) Eastern Time (US & Canada)

110 SE Watula Avenue

Status: Completed

City Hall, Third Floor Ocala, FL 34471

plewis@ocalafl.org

IP Address: 216.255.240.104

## **Record Tracking**

**Signer Events** 

Status: Original Holder: Patricia Lewis Location: DocuSign

plewis@ocalafl.org 11/4/2025 11:44:06 AM

Security Appliance Status: Connected Pool: StateLocal

Storage Appliance Status: Connected Pool: City of Ocala - Procurement & Contracting Location: Docusign

Signature

Signed by:

## **Timestamp**

William E. Sexton, Esq. wsexton@ocalafl.gov City Attorney

Security Level: Email, Account Authentication

(None)

William E. Sexton, Esq. 4A55AR8A8ED04E3

Signature Adoption: Pre-selected Style Using IP Address: 216.255.240.104

Sent: 11/4/2025 11:49:08 AM Viewed: 11/6/2025 9:57:02 AM Signed: 11/6/2025 10:02:52 AM

## **Electronic Record and Signature Disclosure:**

Accepted: 9/15/2023 9:02:35 AM

ID: 313dc6f2-e1d0-44c3-8305-6c087d6cdf0b

Janice Mitchell jmitchell@Ocalafl.org

**CFO** City of Ocala

Security Level: Email, Account Authentication

(None)

Jania Mitchell

Signature Adoption: Pre-selected Style Using IP Address: 216.255.240.104

Sent: 11/6/2025 10:02:55 AM Viewed: 11/6/2025 3:37:40 PM Signed: 11/6/2025 3:38:35 PM

Sent: 11/6/2025 3:38:37 PM

Viewed: 11/6/2025 4:01:54 PM

Signed: 11/6/2025 4:02:05 PM

### **Electronic Record and Signature Disclosure:**

Accepted: 11/6/2025 3:37:40 PM

ID: 48e08c0c-2df2-4254-a227-40b1c1c89453

Chris Gowder

chris.gowder@fmpa.com Chief Sys Ops & Tech Officer

Security Level: Email, Account Authentication

(None)

DocuSigned by: 087F58EBB34B474..

Signature Adoption: Uploaded Signature Image

Using IP Address: 38.77.131.2

## **Electronic Record and Signature Disclosure:**

Accepted: 11/6/2025 4:01:54 PM

ID: 0a51e251-8de8-44e3-a1b7-337121c02056

In Person Signer Events	Signature	Timestamp
Editor Delivery Events	Status	Timestamp
Agent Delivery Events	Status	Timestamp
Intermediary Delivery Events	Status	Timestamp

Certified Delivery Events	Status	Timestamp
Carbon Copy Events	Status	Timestamp
Witness Events	Signature	Timestamp
Notary Events	Signature	Timestamp
Envelope Summary Events	Status	Timestamps
Envelope Summary Events Envelope Sent	Status Hashed/Encrypted	Timestamps 11/4/2025 11:49:08 AM
•		•
Envelope Sent	Hashed/Encrypted	11/4/2025 11:49:08 AM
Envelope Sent Certified Delivered	Hashed/Encrypted Security Checked	11/4/2025 11:49:08 AM 11/6/2025 4:01:54 PM
Envelope Sent Certified Delivered Signing Complete	Hashed/Encrypted Security Checked Security Checked	11/4/2025 11:49:08 AM 11/6/2025 4:01:54 PM 11/6/2025 4:02:05 PM

## ELECTRONIC RECORD AND SIGNATURE DISCLOSURE

From time to time, City of Ocala - Procurement & Contracting (we, us or Company) may be required by law to provide to you certain written notices or disclosures. Described below are the terms and conditions for providing to you such notices and disclosures electronically through the DocuSign system. Please read the information below carefully and thoroughly, and if you can access this information electronically to your satisfaction and agree to this Electronic Record and Signature Disclosure (ERSD), please confirm your agreement by selecting the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

## **Getting paper copies**

At any time, you may request from us a paper copy of any record provided or made available electronically to you by us. You will have the ability to download and print documents we send to you through the DocuSign system during and immediately after the signing session and, if you elect to create a DocuSign account, you may access the documents for a limited period of time (usually 30 days) after such documents are first sent to you. After such time, if you wish for us to send you paper copies of any such documents from our office to you, you will be charged a \$0.00 per-page fee. You may request delivery of such paper copies from us by following the procedure described below.

## Withdrawing your consent

If you decide to receive notices and disclosures from us electronically, you may at any time change your mind and tell us that thereafter you want to receive required notices and disclosures only in paper format. How you must inform us of your decision to receive future notices and disclosure in paper format and withdraw your consent to receive notices and disclosures electronically is described below.

## Consequences of changing your mind

If you elect to receive required notices and disclosures only in paper format, it will slow the speed at which we can complete certain steps in transactions with you and delivering services to you because we will need first to send the required notices or disclosures to you in paper format, and then wait until we receive back from you your acknowledgment of your receipt of such paper notices or disclosures. Further, you will no longer be able to use the DocuSign system to receive required notices and consents electronically from us or to sign electronically documents from us.

## All notices and disclosures will be sent to you electronically

Unless you tell us otherwise in accordance with the procedures described herein, we will provide electronically to you through the DocuSign system all required notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you during the course of our relationship with you. To reduce the chance of you inadvertently not receiving any notice or disclosure, we prefer to provide all of the required notices and disclosures to you by the same method and to the same address that you have given us. Thus, you can receive all the disclosures and notices electronically or in paper format through the paper mail delivery system. If you do not agree with this process, please let us know as described below. Please also see the paragraph immediately above that describes the consequences of your electing not to receive delivery of the notices and disclosures electronically from us.

## How to contact City of Ocala - Procurement & Contracting:

You may contact us to let us know of your changes as to how we may contact you electronically, to request paper copies of certain information from us, and to withdraw your prior consent to receive notices and disclosures electronically as follows:

To contact us by email send messages to: contracts@ocalafl.org

## To advise City of Ocala - Procurement & Contracting of your new email address

To let us know of a change in your email address where we should send notices and disclosures electronically to you, you must send an email message to us at contracts@ocalafl.org and in the body of such request you must state: your previous email address, your new email address. We do not require any other information from you to change your email address.

If you created a DocuSign account, you may update it with your new email address through your account preferences.

## To request paper copies from City of Ocala - Procurement & Contracting

To request delivery from us of paper copies of the notices and disclosures previously provided by us to you electronically, you must send us an email to contracts@ocalafl.org and in the body of such request you must state your email address, full name, mailing address, and telephone number. We will bill you for any fees at that time, if any.

## To withdraw your consent with City of Ocala - Procurement & Contracting

To inform us that you no longer wish to receive future notices and disclosures in electronic format you may:

i. decline to sign a document from within your signing session, and on the subsequent page, select the check-box indicating you wish to withdraw your consent, or you may;

ii. send us an email to contracts@ocalafl.org and in the body of such request you must state your email, full name, mailing address, and telephone number. We do not need any other information from you to withdraw consent.. The consequences of your withdrawing consent for online documents will be that transactions may take a longer time to process..

## Required hardware and software

The minimum system requirements for using the DocuSign system may change over time. The current system requirements are found here: <a href="https://support.docusign.com/guides/signer-guide-signing-system-requirements">https://support.docusign.com/guides/signer-guide-signing-system-requirements</a>.

## Acknowledging your access and consent to receive and sign documents electronically

To confirm to us that you can access this information electronically, which will be similar to other electronic notices and disclosures that we will provide to you, please confirm that you have read this ERSD, and (i) that you are able to print on paper or electronically save this ERSD for your future reference and access; or (ii) that you are able to email this ERSD to an email address where you will be able to print on paper or save it for your future reference and access. Further, if you consent to receiving notices and disclosures exclusively in electronic format as described herein, then select the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

By selecting the check-box next to 'I agree to use electronic records and signatures', you confirm that:

- You can access and read this Electronic Record and Signature Disclosure; and
- You can print on paper this Electronic Record and Signature Disclosure, or save or send this Electronic Record and Disclosure to a location where you can print it, for future reference and access; and
- Until or unless you notify City of Ocala Procurement & Contracting as described above, you consent to receive exclusively through electronic means all notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you by City of Ocala Procurement & Contracting during the course of your relationship with City of Ocala Procurement & Contracting.