

230202
11/20/23 EIM
Contracts

OCALA ELECTRIC UTILITY
OCALA, FLORIDA

FIRST REVISED SHEET NO. 19.0
CANCELS ORIGINAL SHEET NO. 19.0

**APPLICATION FOR INTERCONNECTION OF
CUSTOMER-OWNED RENEWABLE
GENERATION SYSTEMS**

- TIER 1 - Ten (10) kW or Less
- TIER 2 - Greater than 10 kW and Less Than or Equal to 100 kW
- TIER 3 - Greater than 100 kW and Less Than or Equal to Two (2) MW

Note: These customer-owned renewable generation system size limits may be subject to a cumulative enrollment limit on net-metering customers located in the area served by the City of Ocala Electric Utility. Please refer to the Ocala Electric Utility Net-Metering Rate Schedule.

Ocala Electric Utility customers who install customer-owned renewable generation systems (RGS) and desire to interconnect those facilities with the Ocala Electric Utility system are required to complete this application. When the completed application and fees are returned to Ocala Electric Utility, the process of completing the appropriate Tier 1, Tier 2 or Tier 3 Interconnection Agreement can begin. This application and copies of the Interconnection Agreements may be obtained at Ocala Electric Utility, located at 201 SE 3rd Street, Ocala, Florida 34471, or may be requested by email from OEU@ocalafl.org.

1. Customer Information

Name: MICHAEL J. MORRIS

Mailing Address: 2720 SW 18TH AVE

City: Ocala State: Fl Zip Code: 34471

Phone Number: 757-574-9001 Alternate Phone Number: _____

Email Address: morrismj82@gmail.com Fax Number: _____

Ocala Electric Utility Customer Account Number: 520745 - 240263

2. RGS Facility Information

Facility Location: 2720 SW 18TH AVE

Ocala Electric Utility Customer Account Number: 520745 - 240263

RGS Manufacturer: Mission Solar Energy

Manufacturer's Address: 8303 S. New Braunfels Ave., San Antonio, TX 78235

Reference or Model Number: MSE Perc 72 430W

Serial Number: _____

(Continued on Sheet No.19.1)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

3. Facility Rating Information

Gross Power Rating: 12.48 kWAC ("Gross power rating" means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with Ocala Electric Utility's distribution facilities. For inverter-based systems, the AC nameplate generating capacity shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.)

Fuel or Energy Source: solar

Anticipated In- Service Date: 12/28/22

4. Application Fee

The application fee is based on the Gross Power Rating and must be submitted with this application. The non-refundable application fee is \$375 for Tier 2 and \$750 for Tier 3 installations. There is no application fee for Tier 1 installations.

5. Interconnection Study Fee

For Tier 3 installations, a deposit in the amount of the estimated costs of the study (to be determined at time of application) must be paid along with this application in addition to the application fee referenced in Article 4 above. This deposit will be applied toward the cost of an interconnection study. The customer will be responsible for the actual costs of the study. Should the actual cost of the study be less than the deposit, the difference will be refunded to the customer. Customer agrees to comply with all interconnection requirements identified in the interconnection study report.

6. Required Documentation

Prior to completion of the Interconnection Agreement, the following information must be provided to the Ocala Electric Utility by the customer.

- A. Documentation demonstrating that the installation complies with (or most current version at time of inspection approval):
1. IEEE 1547 (2018) Standard for Interconnecting Distributed Resources with Electric Power Systems.
 2. IEEE 1547.1 (2005) Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.
 3. UL 1741 (2010) Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources.

(Continued on Sheet No. 19.2)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

OCALA ELECTRIC UTILITY
OCALA, FLORIDA
(Continued from Sheet No. 19.1)

FIRST REVISED SHEET NO. 19.2
CANCELS ORIGINAL SHEET NO. 19.2

B. Documentation that the customer-owned renewable generation has been inspected and approved by local code officials prior to its operation in parallel with the Ocala Electric Utility system to ensure compliance with applicable local codes. OEU will also require proof of commission testing by a qualified 3rd party testing company (not affiliated in any way with the manufacturer, vendor or installation contractor), for compliance with all required and applicable codes, standards, and interconnection study requirements, prior to setting of OEU metering equipment.


C. Proof of insurance in the amount of:
Tier 1 - \$100,000.00
Tier 2 - \$1,000,000.00
Tier 3 - \$2,000,000.00

Customer

By: MICHAEL J. MORRIS
(Print Name)

Date: 30 JUN 22

SIGN HERE


(Signature)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

PHOTOVOLTAIC ROOF MOUNT SYSTEM

35 MODULES-ROOF MOUNTED - 14.53 kWDC, 13.30 kWAC

2720 SW 18TH AVENUE, OCALA, FL 34471 USA



SOLAR LIGHT & MORE
5640 SW 6TH PLACE, SUITE 400,
OCALA, FL 34474 USA
PHONE: 3522686661
EMAIL: Kelly@solarlighthe.com

SYSTEM SUMMARY:

- (N) 35 - MISSION SOLAR MSE415SX6W (415W) MODULES
- (N) 35 - ENPHASE ENERGY IQBH-240-72-2-US MICRO-INVERTERS
- (N) JUNCTION BOX
- (E) 200A MAIN SERVICE PANEL WITH (E) 200A MAIN BREAKER
- (N) 100A FUSED AC DISCONNECT
- (N) 125A SOLAR LOAD CENTER
- (N) PRODUCTION METER

DESIGN CRITERIA:

- ROOF TYPE: - COMP SHINGLE
- NUMBER OF LAYERS: - 01
- ROOF FRAME: - 2"x4" RAFTERS @24" O.C.
- STORY: - TWO STORY
- SNOWLOAD: - 0 PSF
- WIND SPEED: - 130 MPH
- WIND EXPOSURE: - C

GOVERNING CODES:


- 2020 7TH EDITION FLORIDA BUILDING CODE: BUILDING
- 2020 7TH EDITION FLORIDA BUILDING CODE: RESIDENTIAL
- 2020 7TH EDITION FLORIDA BUILDING CODE: MECHANICAL
- 2020 7TH EDITION FLORIDA BUILDING CODE: PLUMBING
- 2020 7TH EDITION FLORIDA BUILDING CODE: FUEL GAS
- 2020 7TH EDITION FLORIDA BUILDING CODE: ENERGY CONSERVATION
- 2020 7TH EDITION FLORIDA BUILDING CODE: EXISTING BUILDING
- 2020 7TH EDITION FLORIDA BUILDING CODE: ACCESSIBILITY
- 2017 NATIONAL ELECTRIC CODE (NEC)

SHEET INDEX

- PV-0 COVER SHEET
- PV-1 SITE PLAN WITH MODULES
- PV-2 ROOF ZONING AND ATTACHMENT PLAN
- PV-3 BRANCH LAYOUT
- PV-4 ELECTRICAL LINE DIAGRAM
- PV-5 ELECTRICAL CALCULATION
- PV-6 PLACARDS & WARNING LABELS
- PV-7 ADDITIONAL NOTES
- PV-8 EQUIPMENT SPEC SHEETS

GENERAL NOTES

- ALL ELECTRICAL WORK SHALL BE PERFORMED BY A QUALIFIED LICENSED ELECTRICIAN AND/OR APPRENTICES WORKING UNDER THE DIRECT SUPERVISION OF THE LICENSED CONTRACTOR.
- ALL WORK CARRIED OUT SHALL COMPLY WITH THE SPECIFICATIONS, APPLICABLE MUNICIPAL AND UTILITY COMPANY SPECIFICATIONS AND LOCAL JURISDICTIONAL CODES, ORDINANCES, AND APPLICABLE REGULATIONS. PRIOR TO COMMENCEMENT OF ANY WORK, THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCIES NOTED AMONG SITE CONDITIONS, MANUFACTURER RECOMMENDATIONS, OR AUTHORITY HAVING JURISDICTION. IF THE SPECIFIED EQUIPMENT CANNOT BE INSTALLED AS SHOWN ON THESE DRAWINGS, THE CONTRACTOR SHALL SUBMIT TO THE ENGINEER OF RECORD A WRITTEN "RFI"(REQUEST FOR INFORMATION) PROPOSING AN ALTERNATIVE OR SEEKING CLARIFICATION.
- THE CONTRACTOR SHALL MAINTAIN IN GOOD CONDITION ONE COMPLETE SET OF PLANS WITH ALL REVISIONS, ADDENDA, AND CHANGE ORDERS ON THE PREMISES AT ALL TIMES.
- UNLESS NOTED OTHERWISE, THE WORK SHALL INCLUDE FURNISHING MATERIALS, EQUIPMENT, ACCESSORIES, AND LABOR NECESSARY TO COMPLETE ALL INSTALLATIONS AS INDICATED ON THE DRAWINGS.
- ALL MATERIALS FURNISHED AND INSTALLED SHALL BE IN STRICT ACCORDANCE WITH ALL APPLICABLE CODES, REGULATIONS, AND ORDINANCES. CONTRACTOR SHALL ISSUE ALL APPROPRIATE NOTICES AND COMPLY WITH ALL LAWS, ORDINANCES, RULES, REGULATIONS, AND LAWFUL ORDERS OF ANY PUBLIC AUTHORITY REGARDING THE PERFORMANCE OF WORK.
- THE CONTRACTOR SHALL INSTALL ALL EQUIPMENT AND MATERIALS IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS UNLESS SPECIFICALLY STATED OTHERWISE.
- CONTRACTOR SHALL BE RESPONSIBLE FOR THE SAFETY OF WORK AREA, ADJACENT AREAS ARE LIKELY TO BE AFFECTED BY THE WORK UNDER THIS CONTRACT. WORK SHALL CONFORM TO ALL OSHA REQUIREMENTS AND THE LOCAL JURISDICTION.
- WHEN INSTALLING IN FIRE RATED AREAS, SEAL ALL PENETRATIONS WITH UL LISTED MATERIALS APPROVED BY LOCAL JURISDICTION. CONTRACTOR SHALL KEEP AREA CLEAN, HAZARD FREE, AND DISPOSE OF ALL DEBRIS. CONTRACTOR SHALL LEAVE PREMISES IN A CLEAN CONDITION. ALL DEBRIS AND OTHER REFUSE SHALL BE REMOVED FROM THE SITE AND DISPOSED OF IN A LAWFUL MANNER.
- THE CONTRACTOR SHALL PROTECT EXISTING IMPROVEMENTS, PAVEMENTS, CURBS, LANDSCAPING AND STRUCTURES NOT PART OF THE SCOPE OF WORK, AS IDENTIFIED IN THESE PLANS.
- DUE TO THE FACT THAT PV MODULES ARE ENERGIZED WHENEVER THEY ARE EXPOSED TO LIGHT, CONTRACTOR SHALL DISABLE THE ARRAY DURING INSTALLATION AND SERVICE BY SHORT CIRCUITING, OPEN CIRCUITING, OR COVERING ARRAY WITH AN OPAQUE COVER ACCORDING TO MANUFACTURER'S INSTRUCTION.



1 AERIAL PHOTO
SCALE: NTS
PV-0



2 VICINITY MAP
SCALE: NTS
PV-0

PROJECT NAME
MIKE MORRIS
2720 SW 18TH AVENUE
OCALA, FL 34471 USA
APN# R2358003021
UTILITY: OCALA ELECTRIC
AHJ: MARION COUNTY

SHEET NAME
COVER SHEET

SHEET SIZE
ANSI B
11" X 17"

SHEET NUMBER
PV-0

DESCRIPTION	DATE	REV
INITIAL RELEASE	07/10/2022	UR



SOLAR LIGHT & MORE
 5640 SW 6TH PLACE, SUITE 400,
 OCALA, FL 34471 USA
 PHONE: 352.666.6661
 EMAIL: kathy@solarlight.com

VERSION	DATE	REV
INITIAL RELEASE	07/02/2022	UR


PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 SITE PLAN WITH
 ROOF PLAN

SHEET SIZE
 ANSI B
 11" X 17"

SHEET NUMBER
 PV-1

ROOF ACCESS POINT SHALL BE LOCATED IN AREAS THAT DO NOT REQUIRE THE PLACEMENT OF GROUND LADDERS OVER OPENINGS SUCH AS WINDOWS OR DOORS, AND LOCATED AT STRONG POINTS OF BUILDING CONSTRUCTION IN LOCATIONS WHERE THE ACCESS POINT DOES NOT CONFLICT WITH OVERHEAD OBSTRUCTIONS SUCH AS TREE LIMBS, WIRES OR SIGNS.



NOTE:
 A. ALL ELECTRICAL EQUIPMENT, INVERTERS, DISCONNECTS, MAIN SERVICE PANELS, ETC. SHALL NOT BE INSTALLED WITHIN 3' OF THE GAS METERS' SUPPLY OR DEMAND PIPING.

BILL OF MATERIALS

EQUIPMENT	QTY	DESCRIPTION
RAIL	13	RAIL
SPLICE	10	SPLICE
MID CLAMP	50	MID CLAMP-UFO
END CLAMP	12	END CLAMP-STOPPER SLEEVES
ATTACHMENT	66	UNIRAC SFM INFINITY
GROUNDING LUG	66	XR-LUG

1 SITE PLAN WITH ROOF PLAN
 SCALE: 1/16" = 1'-0"

VERSION	DATE	REV
DESCRIPTION	DATE	REV
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
MIKE MORRIS
2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R2358003021
UTILITY: Ocala Electric
AHJ: MARION COUNTY

SHEET NAME
GROUND PLAN WITH
MODULES

SHEET SIZE
ANSI B
11" X 17"


SHEET NUMBER
PV-2

ARRAY AREA & ROOF AREA CALC'S

ROOF #	# OF MODULES	ARRAY AREA (Sq. Ft.)	ROOF AREA (Sq. Ft.)	ROOF AREA COVERED BY ARRAY (%)
#1	06	141.96	542.81	26.15
#2	29	686.16	1350.80	50.80


ROOF DESCRIPTION

ROOF TYPE	RAFTERS SIZE	RAFTERS SPACING
COMP SHINGLE ROOF	2"x4"	24" O.C.
UNIRAC SFM INFINITY	2"x4"	24" O.C.



LEGEND

- UM - UTILITY METER
- MSP - MAIN SERVICE PANEL
- ACD - AC DISCONNECT
- SIC - SOLAR LOAD CENTER
- JB - JUNCTION BOX
- VENT, ATTIC FAN (ROOF OBSTRUCTION)
- ROOF ATTACHMENT
- RAFTERS
- CONDUIT
- FIRE PATHWAY



MODULE TYPE, DIMENSIONS & WEIGHT

NUMBER OF MODULES = 35 MODULES
 MODULE TYPE = MISSION SOLAR MSE415SX6W (415W) MODULES
 MODULE WEIGHT = 51.6 LBS / 23.5 KG
 MODULE DIMENSIONS = 82.12" X 41.49" = 23.96 SF
 (E) 2"x4" RAFTERS @ 24" O.C. (TYP.)

PHOTOVOLTAIC MODULES
 MISSION SOLAR MSE415SX6W (415W)

(N) 47 COUPLINGS (TYP.)

ROOF #2
TILT - 28°
AZIMUTH - 270°

ROOF #2
(29) MISSION SOLAR MSE415SX6W (415W) MODULES

(N) 66 UNIRAC SFM INFINITY ATTACHMENTS SPACED AT 24" & 48" O.C.

(E) COMP SHINGLE ROOF (TYP.)

ROOF #1
TILT - 28°
AZIMUTH - 180°

ROOF #1
(06) MISSION SOLAR MSE415SX6W (415W) MODULES



1 ROOF PLAN WITH MODULES
 SCALE: 3/32" = 1'-0"

PLUMBING VENTS, SKYLIGHTS AND MECHANICAL VENTS SHALL NOT BE COVERED, MOVED, RE-ROUTED OR RE-LOCATED.

MODULE TYPE, DIMENSIONS & WEIGHT

NUMBER OF MODULES = 35 MODULES
 MODULE TYPE = MISSION SOLAR MSE415SX6W (415W) MODULES
 MODULE WEIGHT = 51.6 LBS / 23.5 KG.
 MODULE DIMENSIONS = 82.12" X 41.49" = 23.66 SF
 UNIT WEIGHT OF ARRAY = 2.18 PSF

ROOF LAYOUT NOTE

ROOF SOLAR PANEL LAYOUT IS CONCEPTUAL, BUT AS PROVIDED, CONFORMS WITH THE REQUIREMENTS SET IN SHEET PV-3. CONTRACTOR MAY ADJUST PANEL LOCATION, SOLID CORNERS (4'X4') SHOWN THE PLAN IS WIND ZONE 3. SEE 2020 FLORIDA RESIDENTIAL CODE (7TH EDITION) FOR MORE DETAILS.

APPLICABLE CODE: 2020 FLORIDA BUILDING CODE (7TH EDITION); ASCE 7-16 MINIMUM DESIGN LOADS FOR BUILDING AND OTHER STRUCTURES.

LAG SCREW DIAMETER AND EMBEDMENT LENGTHS ARE DESIGNED PER 2020 FLORIDA BUILDING CODE (7TH EDITION) REQUIREMENTS. ALL BOLT CAPACITIES ARE BASED ON A SOUTHERN YELLOW PINE (SP) RESIDENTIAL WOOD ROOF RAFTERS AS EMBEDMENT MATERIAL.

ALL WIND DESIGN CRITERIA AND PARAMETERS ARE FOR HIP AND GABLE RESIDENTIAL ROOFS, CONSIDERING FROM 7° TO A MAXIMUM 23° (7/12 TO A MAXIMUM 7/12 PITCH) ROOF IN SCHEDULE. CONTRACTOR TO FIELD VERIFY THAT MEAN ROOF HEIGHT DOES NOT EXCEED 30'-0".

ROOF SEALANTS SHALL CONFORM TO ASTM C920 AND ASTM 6511, AND IS THE RESPONSIBILITY OF THE CONTRACTOR TO PILOT DRILL AND FILL ALL HOLES.

ALL DISSIMILAR MATERIALS SHALL BE SEPARATED WITH NEOPRENE WASHERS, PADS, ETC OR SIMILAR.

ALL ALUMINUM COMPONENTS SHALL BE ANODIZED ALUMINUM 6105-T5 UNLESS OTHERWISE NOTED.

ALL LAG SCREW SHALL BE ASTM A276 STAINLESS STEEL UNLESS OTHERWISE NOTED.

ALL SOLAR RAILING AND MODULES SHALL BE INSTALLED PER MANUFACTURER INSTRUCTIONS.

CONTRACTOR SHALL ENSURE ALL ROOF PENETRATIONS TO BE INSTALLED AND SEALED PER 2020 FLORIDA BUILDING CODE (7TH EDITION) OR LOCAL GOVERNING CODE.

NOTE TO INSTALLER:
 NOTE FIELD ADJUSTMENTS CAN BE MADE TO THE LAYOUT OF THE ARRAY.


PLUMBING VENTS, SKYLIGHTS AND MECHANICAL VENTS SHALL NOT BE COVERED, MOVED, RE-ROUTED OR RE-LOCATED.

1 ROOF ZONING AND ATTACHMENT
 SCALE: 3/32" = 1'-0"

NOTE: ACTUAL ROOF CONDITIONS AND RAFTERS (OR SEAM) LOCATIONS MAY VARY. INSTALL PER MANUFACTURER(S) INSTALLATION GUIDELINES AND ENGINEERED SPANS FOR ATTACHMENTS

ROOF ZONES	UPLIFT (PSF)
WIND ZONE 1	36.31
WIND ZONE 2r	36.31
WIND ZONE 2a	36.31
CORNER WIND ZONE 3	-50.9

PHOTOVOLTAIC MODULES
 MISSION SOLAR
 MSE415SX6W (415W)



Solar Lights
 SOLAR ENERGY SYSTEMS & MORE

SOLAR LIGHT & MORE
 5640 SW 6TH PLACE, SUITE 400,
 OCALA, FL 34474 USA
 CSLBF: CVC5675D
 PHONE: 3522664661
 EMAIL: kathy@solarlightsinc.com

VERSION	DATE	REV
INITIAL RELEASE	01/16/2022	UR

PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: Ocala Electric
 AHJ: MARION COUNTY

SHEET NAME
 ROOF PLAN ZONING
 AND ATTACHMENT
 PLAN

SHEET SIZE
 ANSIB
 11" X 17"

SHEET NUMBER
 PV-3.1

VERSION	DESCRIPTION	DATE	REV
	INITIAL RELEASE	07/10/2022	UR


PROJECT NAME
2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R235800321
UTILITY: OCALA ELECTRIC
AHJ: MARION COUNTY

SHEET NAME
ATTACHMENT
DETAIL

SHEET SIZE
ANSI B
11" X 17"


SHEET NUMBER
PV-3

ROOF#1



MAX ATTACHMENT SPAN - 24" & 48" O.C. STAGGERED

ROOF#2



MAX ATTACHMENT SPAN - 24" & 48" O.C. STAGGERED

LEGEND




LEGEND

Module (Roof Zones)

- Zone 1
- Zone 2
- Zone 3

SFM Components

- SFM Microrail 2"
- SFM Splice 6.5"
- SFM Attached Splice 8"
- SFM Trim Attachment
- SFM Trim Univ Clip
- Full Trim Section



ROOF MOUNTING DETAILS
SCALE: NTS.


VERSION	DATE	REV
DESCRIPTION		
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
MIKE MORRIS
2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R2358003021
UTILITY: Ocala Electric
AHJ: MARION COUNTY


SHEET NAME
BRANCH LAYOUT

SHEET SIZE
ANSI B
11" X 17"

SHEET NUMBER
PV-4



FRONT YARD
SW 18TH AVENUE



(35) MISSION SOLAR MSE415SX6W (415W) MODULES
(35) ENPHASE ENERGY IQBH-240-72-2-US MICRO-INVERTER
(08) BRANCH OF 08 MODULES &
(03) BRANCHES OF 08 MODULES CONNECTED IN PARALLEL PER BRANCH

REAR YARD



1 BRANCH LAYOUT
SCALE: 3/32" = 1'-0"

DESCRIPTION	REV
INITIAL RELEASE	07/10/2022
UR	

VERSION

DATE

REV

PROJECT NAME

2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R2358003021
UTILITY: OCALA ELECTRIC
AHJ: MARION COUNTY

SHEET NAME

ELECTRICAL LINE
DIAGRAM

SHEET SIZE

ANSI B
11" X 17"


SHEET NUMBER

PV-5

EQUIPMENT	QTY	DESCRIPTION
SOLAR PV MODULE	35	MISSION SOLAR MSE415SX8W (415W) MODULES
INVERTER	35	ENPHASE ENERGY IQ8H-240-72-2-US MICRO-INVERTERS
JUNCTION BOX	02	600V, 55A MAX, 4 INPUTS, MOUNTED ON GROUND ARRAY FOR WIRE & CONDUIT TRANSITION
SOLAR LOAD CENTER	1	125A SOLAR LOAD CENTER
AC DISCONNECT	1	240VAC, 100A FUSED, NEMA 3R, UL LISTED
PRODUCTION METER	1	PRODUCTION METER

SYSTEM SIZE:- 35 x 415W = 14.53 kWDC
SYSTEM SIZE:- 35 x 380W = 13.30 kWAC

(35) MISSION SOLAR MSE415SX8W (415W) MODULES
(35) ENPHASE ENERGY IQ8H-240-72-2-US MICRO-INVERTER
(01) BRANCH OF 08 MODULES &
(03) BRANCHES OF 09 MODULES CONNECTED IN PARALLEL PER BRANCH



SERVICE INFO.

UTILITY PROVIDER: OCALA ELECTRIC
MAIN SERVICE VOLTAGE: 240V
MAIN PANEL BRAND: N/A
MAIN SERVICE PANEL: (E) 200A
MAIN CIRCUIT BREAKER RATING: (E) 200A
MAIN SERVICE LOCATION: SOUTH

1 ELECTRICAL LINE DIAGRAM
SCALE: NTS



SOLAR LIGHT & MORE
5640 SW 6TH PLACE, SUITE 400,
OCALA, FL 34474 USA
CSL#H CVC56750
PHONE 3522664661
EMAIL: Kathy@solarlightsnc.com

VERSION	DESCRIPTION	DATE	REV
	INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
MIKE MORRIS
2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R2358003021
UTILITY: Ocala Electric
AHJ: MARION COUNTY

SHEET NAME
ELECTRICAL
CALCULATION

SHEET SIZE
ANSI B
11" X 17"

SHEET NUMBER
PV-6

**AC CONDUCTOR AMPACITY CALCULATIONS:
FROM JUNCTION BOX TO COMBINER BOX 3:**

EXPECTED WIRE TEMP (°C): 34°
TEMP CORRECTION PER TABLE 310.15(B)(2)(a): 0.96
OF CURRENT CARRYING CONDUCTORS: 8
CONDUIT FILL CORRECTION PER NEC 310.15(B)(3)(a): 0.70
CIRCUIT CONDUCTOR SIZE: 10 AWG
CIRCUIT CONDUCTOR AMPACITY: 40A
REQUIRED CIRCUIT CONDUCTOR AMPACITY PER NEC 690.8(A&B):
1.25 X # MICRO-INVERTERS (MAX. BRANCH LENGTH) X MAX OUTPUT
CURRENT
1.25 X 09 X 1.58A = 18.00A

DERATED AMPACITY OF CIRCUIT CONDUCTOR PER NEC TABLE
310.15(B)(2)(a)
TEMP CORR. PER NEC TABLE 310.15(B)(2)(a) X
CONDUIT FILL CORR. PER NEC 310.15(B)(3)(a) X
CIRCUIT CONDUCTOR AMPACITY =
0.96 X 0.70 X 40 = 26.88A

RESULT SHOULD BE GREATER THAN 18.00A OTHERWISE LESS
THE ENTRY FOR CIRCUIT CONDUCTOR SIZE AND AMPACITY

**AC CONDUCTOR AMPACITY CALCULATIONS:
FROM COMBINER BOX TO INTERCONNECTION:**

OF INVERTERS: 35
EXPECTED WIRE TEMP (°C): 34°
TEMP CORRECTION PER TABLE 310.15(B)(2)(a): 0.96
OF CURRENT CARRYING CONDUCTORS: 3
CONDUIT FILL PER NEC 310.15(B)(3)(a): 1.0
CIRCUIT CONDUCTOR SIZE: 8 AWG
CIRCUIT CONDUCTOR AMPACITY: 75A

REQUIRED CIRCUIT CONDUCTOR AMPACITY PER NEC 690.8(B):
1.25 X # MICRO-INVERTERS X MAX OUTPUT CURRENT =
1.25 X 1.58 X 35 = 68.13A

DERATED AMPACITY OF CIRCUIT CONDUCTORS PER NEC TABLE 310.16
TEMP CORR. PER NEC TABLE 310.15(B)(2)(a) X
CONDUIT FILL CORR. PER NEC 310.15(B)(3)(a) X
CIRCUIT CONDUCTOR AMPACITY =
0.96 X 1.0 X 75 = 72.00A

RESULT SHOULD BE GREATER THAN 68.13A OTHERWISE LESS
THE ENTRY FOR CIRCUIT CONDUCTOR SIZE AND AMPACITY

ELECTRICAL NOTES

- 1.) ALL EQUIPMENT TO BE LISTED BY UL OR OTHER NRTL, AND LABELED FOR ITS APPLICATION.
- 2.) ALL CONDUCTORS SHALL BE COPPER, RATED FOR 600 V AND 90 DEGREE C WET ENVIRONMENT.
- 3.) WIRING, CONDUIT, AND RACEWAYS MOUNTED ON ROOFTOPS SHALL BE ROUTED DIRECTLY TO, AND LOCATED AS CLOSE AS POSSIBLE TO THE NEAREST RIDGE, HIP, OR VALLEY.
- 4.) WORKING CLEARANCES AROUND ALL NEW AND EXISTING ELECTRICAL EQUIPMENT SHALL COMPLY WITH NEC 110.26.
- 5.) DRAWINGS INDICATE THE GENERAL ARRANGEMENT OF SYSTEMS. CONTRACTOR SHALL FURNISH ALL NECESSARY OUTLETS, SUPPORTS, FITTINGS AND ACCESSORIES TO FULFILL APPLICABLE CODES AND STANDARDS.
- 6.) WHERE SIZES OF JUNCTION BOXES, RACEWAYS, AND CONDUITS ARE NOT SPECIFIED, THE CONTRACTOR SHALL SIZE THEM ACCORDINGLY.
- 7.) ALL WIRE TERMINATIONS SHALL BE APPROPRIATELY LABELED AND READILY VISIBLE.
- 8.) MODULE GROUNDING CLIPS TO BE INSTALLED BETWEEN MODULE FRAME AND MODULE SUPPORT RAIL PER THE GROUNDING CLIP MANUFACTURER'S INSTRUCTION.
- 9.) MODULE SUPPORT RAIL TO BE BONDED TO CONTINUOUS COPPER G.E.C. VIA WEBB LUG OR ILSCO GBL-4DBT LAY-IN LUG.
- 10.) THE POLARITY OF THE GROUNDED CONDUCTORS IS NEGATIVE

1 ELECTRICAL CALCULATION
SCALE: NTS

SOLAR MODULE SPECIFICATIONS	
MANUFACTURER / MODEL #	MISSION SOLAR MSE415SX6W (415W) MODULES
VMP	39.93
IMP	10.33
VOC	48.92
ISC	10.89
MODULE DIMENSION	82.12"L x 41.48"W x 1.57"D

INVERTER SPECIFICATIONS	
MANUFACTURER / MODEL #	ENPHASE ENERGY IQBH-240-72-2-US
NOMINAL OUTPUT VOLTAGE	240 VAC
NOMINAL OUTPUT CURRENT	1.58A

AMBIENT TEMPERATURE SPECS	
WEATHER STATION	OCALA MUNI (AWOS)
RECORD LOW TEMP	-6°
AMBIENT TEMP (HIGH TEMP 2%)	34°
CONDUCTOR TEMPERATURE RATE	90°
MODULE TEMPERATURE COEFFICIENT OF V _{oc}	-0.26 %/°C

PERCENT OF VALUES	NUMBER OF CURRENT CARRYING CONDUCTORS IN EMT
.80	4-5
.70	7-9
.50	10-20

DESCRIPTION	DATE	REV
INITIAL RELEASE	07/10/2022	UR

VERSION

PROJECT NAME
 2720 SW 18TH AVENUE,
 Ocala, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 WARNING LABELS

SHEET SIZE
 ANSI B
 11" X 17"

SHEET NUMBER
 PV-7

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN



LABEL LOCATION:
 AC DISCONNECT, DC DISCONNECT, POINT OF INTERCONNECTION
 (PER CODE: 695.11.3.1(1) & 690.56(C)(1)(a))

PHOTOVOLTAIC SYSTEM AC DISCONNECT RATED AC OPERATING CURRENT 35.3 AMPS AC NOMINAL OPERATING VOLTAGE 240 VOLTS

LABEL LOCATION:
 AC DISCONNECT & INVERTER
 (PER CODE: NEC690.54)

WARNING POWER SOURCE OUTPUT CONNECTION DO NOT RELOCATE THIS OVERCURRENT DEVICE

LABEL LOCATION:
 SERVICE PANEL IF SUM OF BREAKERS EXCEEDS PANEL RATING
 (PER CODE: NEC 705.12 (B)(2)(3)(b))

WARNING: PHOTOVOLTAIC POWER SOURCE

LABEL LOCATION:
 EMT / CONDUIT RACEWAYS
 (PER CODE: NEC 690.31(G)(3))

MAIN PHOTOVOLTAIC SYSTEM DISCONNECT

LABEL LOCATION:
 MAIN SERVICE DISCONNECT / UTILITY METER
 (PER CODE: NEC 690.13(B))

WARNING ELECTRIC SHOCK HAZARD TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL LOCATION:
 AC & DC DISCONNECT AND SUB PANEL
 (PER CODE: NEC 690.13(B))

WARNING DUAL-POWER SOURCE SECOND SOURCE IS PHOTOVOLTAIC SYSTEM


LABEL LOCATION:
 MAIN SERVICE PANEL & NET METER
 (PER CODE: NEC 705.12(D)(3), NEC 705.12(B)(3-4) & NEC 690.59)

PHOTOVOLTAIC AC DISCONNECT

LABEL LOCATION:
 AC DISCONNECT
 NEC 690.13(B)

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

LABEL LOCATION:
 RAPID SHUTDOWN
 (PER CODE: NEC 690.56(C)(3))



1. EACH MODULE TO BE GROUNDED USING THE SUPPLIED CONNECTION POINT PER MANUFACTURER'S REQUIREMENTS. ALL SOLAR MODULES, EQUIPMENT, AND METALLIC COMPONENTS ARE TO BE BONDED. IF THE EXISTING GROUNDING ELECTRODE SYSTEM CAN NOT BE VERIFIED OR IS ONLY METALLIC WATER PIPING, IT IS THE CONTRACTOR'S RESPONSIBILITY TO INSTALL A SUPPLEMENTAL GROUNDING ELECTRODE.
2. ALL PLAQUES AND SIGNAGE REQUIRED BY THE LATEST EDITION OF NATIONAL ELECTRICAL CODE. LABEL SHALL BE METALLIC OR PLASTIC, ENGRAVED OR MACHINE PRINTED IN A CONTRASTING COLOR TO THE PLAQUE. PLAQUE SHALL BE UV RESISTANT IF EXPOSED TO SUNLIGHT.
3. DC CONDUCTORS SHALL BE RUN IN EMT AND SHALL BE LABELED, "CAUTION DC CIRCUIT" OR EQUIV. EVERY 5 FT.
4. EXPOSED NON-CURRENT CARRYING METAL PARTS OF ELECTRICAL EQUIPMENT SHALL BE GROUNDED IN ACCORDANCE WITH 250.134 OR 250.136(A).
5. CONFIRM LINE SIDE VOLTAGE AT ELECTRIC UTILITY SERVICE PRIOR TO CONNECTING INVERTER. VERIFY SERVICE VOLTAGE IS WITHIN INVERTER VOLTAGE OPERATIONAL RANGE.
6. OUTDOOR EQUIPMENT SHALL BE NEMA-3R RATED OR BETTER.
7. ELECTRICAL CONTRACTOR TO PROVIDE CONDUIT EXPANSION JOINTS AND ANCHOR CONDUIT RUNS AS REQUIRED PER NEC.
8. ALL WIRING MUST BE PROPERLY SUPPORTED BY DEVICES OR MECHANICAL MEANS DESIGNED AND LISTED FOR SUCH USE, AND FOR GROUND-MOUNTED SYSTEMS, WIRING MUST BE PERMANENTLY AND COMPLETELY HELP OFF OF THE GROUND. NEC 110.2 - 110.4 / 300.4



SOLAR LIGHT & MORE
 3640 SW 18TH PLACE, SUITE 400,
 OCALA, FL 34471 USA
 CSL#R# CVCS58750
 PHONE: 3522664661
 EMAIL: kathy@solarlighting.com


VERSION			
DESCRIPTION	DATE	REV	
INITIAL RELEASE	07/10/2022	UR	

PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 ADDITIONAL NOTES
 SHEET SIZE
 ANSIB
 11" X 17"
 SHEET NUMBER
 PV-8

AMERICA'S MODULE COMPANY™

IMSE PERC 72



- CERTIFIED RELIABILITY**
 - Tested to UL 61730 & IEC standards
 - PID resistant
 - Resistance to salt mist corrosion
- ADVANCED TECHNOLOGY**
 - PERC and 6 busbar drive 19.1% module efficiency
 - Ideal for all applications
- EXTREME WEATHER RESILIENCE**
 - 5400 Pa front and 3600 Pa back load
 - Tested to UL 61730
 - 40mm frame

- BAA COMPLIANT FOR GOVERNMENT PROJECTS**
 - Buy American Act
 - American Recovery & Reinvestment Act



CLASS LEADING POWER OUTPUT

420 W

POSITIVE POWER TOLERANCE
-0 - +3 %

The True American Brand

Mission Solar Energy is headquartered in San Antonio, Texas, where we manufacture our modules. We produce American, high quality solar modules ensuring the highest in class power output and best in-class reliability. Our product line is tailored for residential, commercial and utility applications. Every Mission Solar Energy solar module is certified and surpasses industry standard regulations, proving excellent performance over the long-term. Demand the best, demand Mission Solar Energy.



FRAME-TO-FRAME WARRANTY

Degradation guaranteed not to exceed 2% in year one and 0.58% annually from year two to 30 with 84.08% guaranteed in year 25.

CERTIFICATIONS

UL 61730
IEC 61215
IEC 61701



Please contact Mission Solar Energy if you have questions or concerns about certification of our products in your area.

*Standard 12-year product warranty extendable to 25 years with registration: www.missionsolar.com/warranty/

© 2014 Mission Solar Energy, Inc. All rights reserved. Mission Solar Energy is a registered trademark of Mission Solar Energy, Inc.

PERC 72

CLASS LEADING 405-425 W

ELECTRICAL SPECIFICATION

Product Type	MSE	5400 Pa	3600 Pa	410	405	415	420	425
Power Output	P _{max}	W	W	184	186	189	191	193
Module Efficiency	%	%	%	0/-3	0/+3	0/+3	0/+3	0/+3
Tolerance	%	%	%	0/-3	0/+3	0/+3	0/+3	0/+3
Short Circuit Current	I _{sc}	A	A	10.99	10.99	10.99	11.05	11.09
Open Circuit Voltage	V _{oc}	V	V	48.56	48.71	48.92	49.14	49.38
Rated Current	I _{mp}	A	A	10.23	10.32	10.39	10.46	10.55
Rated Voltage	V _{mp}	V	V	39.59	39.73	39.93	40.14	40.27
Fuse Rating	A	A	A	20	20	20	20	20
System Voltage	V	V	V	1500	1500	1500	1500	1500


TEMPERATURE COEFFICIENTS

Normal Operating Cell Temperature (NOCT) 44.09°C (111.37°F)
 Temperature Coefficient of P_{max} -0.369%/°C
 Temperature Coefficient of V_{oc} -0.261%/°C
 Temperature Coefficient of I_{sc} 0.004%/°C

OPERATING CONDITIONS

Maximum System Voltage 1,500Vdc
 Operating Temperature Range -40°C (-40°F) to +85°C (185°F)
 Maximum Series Fuse Rating 20A
 Fire Safety Classification Type 1
 5400 Pa front and 3600 Pa back load
 Tested to UL 61730
 Hail Safety Impact Velocity 25mm at 23 m/s

BASIC DIMENSIONS (LIGHTS ONLY)



MECHANICAL DATA

Solar Cells P-type mono-crystalline silicon
 Cell Orientation 72 cells (6x12)
 Module 2066mm x 1054mm x 40mm
 Weight 23.4 kg (51 lbs)
 Front Glass 3.2mm tempered, low-iron, anti-reflective
 Frame Anodized
 Encapsulant Ethylene vinyl acetate (EVA)
 Junction Box Pre-circulation class (P67)
 Cables 1.2m, 4mm² (12AWG)
 Connector Reinforce 95-8

MSEA155K6W: 415WP, 72 CELL SOLAR MODULE CURRENT - VOLTAGE CURVE



Current-voltage characteristics with dependence on irradiance and module temperature

CERTIFICATIONS & TESTS

IEC 61215-61730, 61701
 UL 61730



SHIPPING INFORMATION

Container FT Pallets 420 W lin
 33 Most States 28 728 30576 kW
 Double-Stack California 25 350 27300 kW
 Weight Height Width Length
 1450 lbs 47.5 in 46 in 83.75 in
 (657 kg) (120.65 cm) (116.84 cm) (212.72 cm)

Mission Solar Energy | 18601 N. New Braunfels Ave., San Antonio, Texas, 78158
www.missionsolar.com | info@missionsolar.com

Solar Lights
 SOLAR ENERGY SYSTEMS & SUPPLIES
 SOLAR LIGHT & MORE
 5640 SW 6TH PLACE, SUITE 400,
 OCALA, FL 32767 USA
 PHONE: 352.866.6881
 EMAIL: kathy@solarglights.com


DESCRIPTION	DATE	REV
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 SPEC SHEETS

SHEET SIZE
 ANSIB
 11" X 17"

SHEET NUMBER
 PV-9



IQ8 Series Microinverters

Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. The chip is built in advanced 55nm technology with high-speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



IQ8 Series Microinverters combine reliability and performance, offering a 25-year cumulative hours of power-on testing, enabling an individual year-based limited warranty of up to 25 years.



IQ8 Series Microinverters are UL Listed as PV Rapid Shut Down Equipment and conform with voltage regulations, when installed according to manufacturer's instructions.



Convert PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-n-play MC4 connectors.

© 2021 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ8 microinverters, and other names are trademarks of Enphase Energy, Inc. Data subject to change.

IQ8SE-03-0001-01-EN-US-2021-10-19

ENPH-001-01-EN-US-2021-10-19

IQ8 Series Microinverters

Model	235-350	235-440	280-460	280-500	320-540	320-590*
Commonly used module packaging ¹	60-cell (2U) half-cell	60-cell (2U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell
Module compatibility	60-cell (2U) half-cell	60-cell (2U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell	60-cell (2U) half-cell and 72-cell (4U) half-cell
MPPT voltage range	27-37	29-45	33-45	35-45	38-45	38-45
Open-circuit voltage	25-48	25-48	25-48	25-48	25-48	25-48
Min/max start voltage	30/48	30/48	30/48	30/48	30/48	30/48
Max input DC voltage	50	50	50	50	50	50
Max DC current ² (module level)	A	A	A	A	A	A
Over-voltage class DC port	II	II	II	II	II	II
DC port backfeed current	0	0	0	0	0	0
PV array configuration	0	0	0	0	0	0

Parameter	235-350	235-440	280-460	280-500	320-540	320-590*
Peak output power	300	300	306	306	306	306
Max continuous output power	240	280	323	349	380	380
Nominal (L-L) voltage/range ³	240V/211-264	240V/211-264	240V/211-264	240V/211-264	240V/211-264	240V/211-264
Max continuous output current	1.0	1.21	1.35	1.45	1.58	1.73
Nominal frequency	60	60	60	60	60	60
Efficiency/frequency range	97.5-99.5	97.5-99.5	97.5-99.5	97.5-99.5	97.5-99.5	97.5-99.5
Max inverter 20 A (L-L) branch circuit ⁴	16	13	11	11	10	9
Total harmonic distortion	<5%	<5%	<5%	<5%	<5%	<5%
Overvoltage class AC port	III	III	III	III	III	III
AC port locked current	30	30	30	30	30	30
Power factor setting	1.0	1.0	1.0	1.0	1.0	1.0
Grid-tied power factor (adjustable)	0.85 leading - 0.85 lagging	0.85 leading - 0.85 lagging	0.85 leading - 0.85 lagging	0.85 leading - 0.85 lagging	0.85 leading - 0.85 lagging	0.85 leading - 0.85 lagging
Peak efficiency	97.5	97.5	97.5	97.5	97.5	97.5
CEC weighted efficiency	97	97	97	97	97	97
High-line power consumption	90	90	90	90	90	90

(*) Ungrounded array. No additional DC side protection required. AC side protection requires max 20A per branch circuit PV array configuration.

Parameter	235-350	235-440	280-460	280-500	320-540	320-590*
Relative humidity range	4% to 100% (condensing)	4% to 100% (condensing)	4% to 100% (condensing)	4% to 100% (condensing)	4% to 100% (condensing)	4% to 100% (condensing)
DC Connector type	MC4	MC4	MC4	MC4	MC4	MC4
Dimensions (HxWxD)	212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")	212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")	212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")	212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")	212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")	212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")
Weight	1.08 kg (2.38 lbs)	1.08 kg (2.38 lbs)	1.08 kg (2.38 lbs)	1.08 kg (2.38 lbs)	1.08 kg (2.38 lbs)	1.08 kg (2.38 lbs)
Cooling	Passive	Passive	Passive	Passive	Passive	Passive
Approved for vent locations	Yes	Yes	Yes	Yes	Yes	Yes
Acoustic noise at 1 m	<60 dBA	<60 dBA	<60 dBA	<60 dBA	<60 dBA	<60 dBA
Pollution category	PD3	PD3	PD3	PD3	PD3	PD3
Enclosure	Class II double-insulated, corrosion resistant polyamide enclosure	Class II double-insulated, corrosion resistant polyamide enclosure	Class II double-insulated, corrosion resistant polyamide enclosure	Class II double-insulated, corrosion resistant polyamide enclosure	Class II double-insulated, corrosion resistant polyamide enclosure	Class II double-insulated, corrosion resistant polyamide enclosure
Environment category / UV exposure rating	NEMA Type 0 / outdoor	NEMA Type 0 / outdoor	NEMA Type 0 / outdoor	NEMA Type 0 / outdoor	NEMA Type 0 / outdoor	NEMA Type 0 / outdoor

UL 1741, UL 1741-SA, UL 60909-1, UL 1741-REEV, FCC Part 15 Class B, ICES-0003 Class B, CMC/CSG-C22.2 NO. 107-P1

This product is UL Listed as PV Rapid Shut Down Equipment and conforms with NEC 2014, NEC 2017, and NEC 2020 section 690.32 and C22.2-508 Rule 64-208 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according to manufacturer's instructions.

(1) The IQ8SE-03-0001-01-EN-US-2021-10-19 model will be replaced by the IQ8SE-03-0001-01-EN-US-2021-10-19 model. See the replacement calculator at <https://www.enphase.com/support> for more information. (2) Maximum continuous input DC current is 10A (41.7A maximum voltage range can be assembled beyond this limit if specified by the utility). (3) Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

IQ8SE-03-0001-01-EN-US-2021-10-19



SOLAR LIGHT & MORE
5640 SW 18TH AVENUE, SUITE 400,
OCALA, FL 34471, USA
C.S. #147, C.V.#587251
PHONE: 352.664.6651
EMAIL: kathy@solarlightheinc.com

VERSION	DATE	REV
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
MIKE MORRIS
2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R235800321
UTILITY: OCALA ELECTRIC
AHJ: MARION COUNTY

SHEET NAME
SPEC SHEETS

SHEET SIZE
ANSI B
11" X 17"

SHEET NUMBER
PV-10



SOLAR LIGHT & MORE
 5640 SW 6TH PLACE, SUITE 400,
 OCALA, FL 34474 USA
 CSLB# CV256750
 PHONE: 352.266.6661
 EMAIL: Kathy@solarlightinc.com

VERSION	DATE	REV
DESCRIPTION		
INITIAL RELEASE	07/10/2022	UR


PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 SPEC SHEETS

SHEET SIZE
 ANSI B
 11" X 17"

SHEET NUMBER
 PV-12



P/N	DESCRIPTION
250030U	SFM ATTACHED SPLICE 8"



SFM ATTACHED SPLICE 8"

 1411 BROADWAY BLVD. NE ALBUQUERQUE, NM 87102 USA PHONE: 505.242.6411 WWW.UNIRAC.COM	PRODUCT LINE:	SFM INFINITY	DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL	SFM-A03	SHEET
	DRAWING TYPE:	PARTS ASSEMBLY			
	DESCRIPTION:	ATT SPLICE 8"	PRODUCT PROTECTED BY ONE OR MORE US PATENTS		
	REVISION DATE:	4/22/2019	LEGAL NOTICE		

P/N	DESCRIPTION
250010U	SFM SPLICE 6.5"



SFM SPLICE 6.5"


 1411 BROADWAY BLVD. NE ALBUQUERQUE, NM 87102 USA PHONE: 505.242.6411 WWW.UNIRAC.COM	PRODUCT LINE:	SFM INFINITY	DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL	SFM-A06	SHEET
	DRAWING TYPE:	PARTS ASSEMBLY			
	DESCRIPTION:	SPLICE 6.5"	PRODUCT PROTECTED BY ONE OR MORE US PATENTS		
	REVISION DATE:	4/22/2019	LEGAL NOTICE		

VERSION		
DESCRIPTION	DATE	REV
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 Ocala, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME SPEC SHEETS
SHEET SIZE ANSI B 11" X 17"
SHEET NUMBER PV-13

PART # TABLE	
P/N	DESCRIPTION
0942700	FLASHKIT SFM SLIDER COMP DARK



FLASHKIT SFM SLIDER

 1411 BROADWAY BLVD. NE ALBUQUERQUE, NM 87102 USA PHONE: 505.242.6411 WWW.UNIRAC.COM	PRODUCT LINE: SFM INFINITY DRAWING TYPE: PARTS ASSEMBLY DESCRIPTION: FLASHKIT SLIDER REVISION DATE: 4/22/2019	DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL PRODUCT PROTECTED BY ONE OR MORE US PATENTS LEGAL NOTICE	SFM-A05 SHEET
--	--	---	------------------



SOLAR LIGHT & MORE
 5640 SW 6TH PLACE, SUITE 400
 OCALA, FL 34474 USA
 CS: 888 632 8675
 PHONE: 352 266 6666
 EMAIL: kathy@sealights.com

VERSION	DATE	REV
DESCRIPTION		
INITIAL RELEASE	07/10/2022	UR


PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 SPEC SHEETS

SHEET SIZE
 ANSI B
 11" X 17"

SHEET NUMBER
 PV-14


PART # TABLE	
P/N	DESCRIPTION
250100U	SFM TRIMRAIL UNIV DARK




SFM TRIMRAIL UNIV

 1411 BROADWAY BLVD. NE ALBUQUERQUE, NM 87102 USA PHONE: 505.242.6411 WWW.UNIRAC.COM	PRODUCT LINE: SFM INFINITY DRAWING TYPE: PART	DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL	SFM-P01
	DESCRIPTION: TRIMRAIL UNIV REVISION DATE: 4/22/2019	PRODUCT PROTECTED BY ONE OR MORE US PATENTS LEGAL NOTICE	SHEET

PART # TABLE	
P/N	DESCRIPTION
008000U	SFM N/S BONDING CLAMP
008015S	SFM WIRE BONDING CLIP
008100U	SFM TRIM BONDING CLAMP



N/S BONDING CLAMP



WIRE BONDING CLIP

 1411 BROADWAY BLVD. NE ALBUQUERQUE, NM 87102 USA PHONE: 505.242.6411 WWW.UNIRAC.COM	PRODUCT LINE: SFM INFINITY DRAWING TYPE: PARTS ASSEMBLY	DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL	SFM-A12
	DESCRIPTION: BONDING ASSEMBLIES REVISION DATE: 4/22/2019	PRODUCT PROTECTED BY ONE OR MORE US PATENTS LEGAL NOTICE	SHEET



SOLAR LIGHT & MORE
 5640 SW 6TH PLACE, SUITE 400,
 OCALA, FL 34474 USA
 CSL#W CVC367530
 PHONE: 352.266.6661
 EMAIL: Kelly@solaringredients.com

VERSION	DATE	REV
DESCRIPTION		
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
 MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 SPEC SHEETS

SHEET SIZE
 ANSI B
 11" X 17"

SHEET NUMBER
 PV-15

PART # TABLE	
P/N	DESCRIPTION
250120U	SFM TRIM SPLICE ASSEMBLY DARK



SFM TRIMRAIL SPLICE


UNIRAC
 1411 BROADWAY BLVD. NE
 ALBUQUERQUE, NM 87102 USA
 PHONE: 505.242.6411
 WWW.UNIRAC.COM

PRODUCT LINE: SFM INFINITY
 DRAWING TYPE: PARTS ASSEMBLY
 DESCRIPTION: TRIMRAIL SPLICE
 REVISION DATE: 4/22/2019

DRAWING NOT TO SCALE
 ALL DIMENSIONS ARE
 NOMINAL
 PRODUCT PROTECTED BY
 ONE OR MORE US PATENTS
 LEGAL NOTICE

SFM-A10 SHEET

PART # TABLE	
P/N	DESCRIPTION
250110U	SFM UNIV TRIMRAIL CLIP DARK



UNIV TRIMRAIL CLIP

UNIRAC
 1411 BROADWAY BLVD. NE
 ALBUQUERQUE, NM 87102 USA
 PHONE: 505.242.6411
 WWW.UNIRAC.COM

PRODUCT LINE: SFM INFINITY
 DRAWING TYPE: PARTS ASSEMBLY
 DESCRIPTION: UNIV TRIMRAIL CLIP
 REVISION DATE: 4/22/2019

DRAWING NOT TO SCALE
 ALL DIMENSIONS ARE
 NOMINAL
 PRODUCT PROTECTED BY
 ONE OR MORE US PATENTS
 LEGAL NOTICE

SFM-A09 SHEET

Solar Lights
SOLAR ENERGY BY FEEL & THINK

SOLAR LIGHT & MORE
5640 SW 6TH PLACE, SUITE 400
OCALA, FL 34747 USA
CSLBN CVC3675D
PHONE: 3522664661
EMAIL: kathy@solarlights.com

TABLE OF CONTENTS

- A — TOOLS & SPECIFICATIONS
- B — SYSTEM COMPONENTS
- C — SYSTEM COMPONENTS
- D — SYSTEM COMPONENTS
- E — SYSTEM LAYOUTS
- F — THERMAL EXPANSION LIMITS
- G — FLASHING & SLIDERS
- H — LIST ROW INSTALLATION
- I — TRIMRAIL & MICROAIL INSTALLATION
- J — MODULE HOUSINGS
- K — HOUSING INSTALLATION
- L — MICROINVERTER & WIRE MANAGEMENT
- M — FINISHING TOUCHES
- N — SYSTEM BONDING & GROUNDING
- O — ALL CODE COMPLIANCE NOTES
- P — TESTED/CERTIFIED MODULE LIST
- Q — MODULE MAINTENANCE
- R — CONSIDERATIONS & MAINTENANCE



TECHNICAL SPECIFICATIONS:

Material Types

- Flashing: 6063 T6 Aluminum
- Hardware: Stainless Steel

Handling and Mounting: Integrated in MicroRail™ (Trimrail™ and Sun Rail™ are optional).

TOOLS REQUIRED OR RECOMMENDED FOR LAYOUT, FLASHING & ROOF ATTACHMENTS:

- Hammer
- Mallet / Crapan
- Drilling tool
- Drilling tape
- Pilot drill bit
- Pry bar
- String line

TOOLS FOR MODULE INSTALL:

- Drill and socket adapter or socket wrench
- 1/4" hex driver
- Torque wrench
- 1/2" socket (optional)


ROOF STRUCTURE:

- All SFM Hardware: 20 lbs. (unless otherwise noted)
- Grounding Lugs: Per Page Q'

SAFETY:

All applicable OSHA safety guidelines should be observed when working on a PV installation job site. The installation and handling of PV solar module electrical installation and PV wiring should be done in accordance with applicable potentially sharp metal edges. Rules regarding the use of gloves and other personal protective equipment should be observed.

PHOTO COURTESY




SUNFRAME Microrail™ - 2'

Sub-Components:

1. Base
2. Clamp Socket Head Cap Screw
3. DT Clamping Socket Head Cap Screw
4. High Adjustment Escrow
5. Torx
6. Direct Socket Head Cap Screw
7. 2.5" x 4" Adjustable Support & Connection
8. E-Clamp Module Mounting
9. 1/2" Spacing Chip
10. 1/2" Spacing Chip
11. 1/2" Spacing Chip
12. 1/2" Spacing Chip
13. 1/2" Spacing Chip
14. 1/2" Spacing Chip
15. 1/2" Spacing Chip
16. 1/2" Spacing Chip
17. 1/2" Spacing Chip
18. 1/2" Spacing Chip
19. 1/2" Spacing Chip
20. 1/2" Spacing Chip
21. 1/2" Spacing Chip
22. 1/2" Spacing Chip
23. 1/2" Spacing Chip
24. 1/2" Spacing Chip
25. 1/2" Spacing Chip
26. 1/2" Spacing Chip
27. 1/2" Spacing Chip
28. 1/2" Spacing Chip
29. 1/2" Spacing Chip
30. 1/2" Spacing Chip
31. 1/2" Spacing Chip
32. 1/2" Spacing Chip
33. 1/2" Spacing Chip
34. 1/2" Spacing Chip
35. 1/2" Spacing Chip
36. 1/2" Spacing Chip
37. 1/2" Spacing Chip
38. 1/2" Spacing Chip
39. 1/2" Spacing Chip
40. 1/2" Spacing Chip
41. 1/2" Spacing Chip
42. 1/2" Spacing Chip
43. 1/2" Spacing Chip
44. 1/2" Spacing Chip
45. 1/2" Spacing Chip
46. 1/2" Spacing Chip
47. 1/2" Spacing Chip
48. 1/2" Spacing Chip
49. 1/2" Spacing Chip
50. 1/2" Spacing Chip
51. 1/2" Spacing Chip
52. 1/2" Spacing Chip
53. 1/2" Spacing Chip
54. 1/2" Spacing Chip
55. 1/2" Spacing Chip
56. 1/2" Spacing Chip
57. 1/2" Spacing Chip
58. 1/2" Spacing Chip
59. 1/2" Spacing Chip
60. 1/2" Spacing Chip
61. 1/2" Spacing Chip
62. 1/2" Spacing Chip
63. 1/2" Spacing Chip
64. 1/2" Spacing Chip
65. 1/2" Spacing Chip
66. 1/2" Spacing Chip
67. 1/2" Spacing Chip
68. 1/2" Spacing Chip
69. 1/2" Spacing Chip
70. 1/2" Spacing Chip
71. 1/2" Spacing Chip
72. 1/2" Spacing Chip
73. 1/2" Spacing Chip
74. 1/2" Spacing Chip
75. 1/2" Spacing Chip
76. 1/2" Spacing Chip
77. 1/2" Spacing Chip
78. 1/2" Spacing Chip
79. 1/2" Spacing Chip
80. 1/2" Spacing Chip
81. 1/2" Spacing Chip
82. 1/2" Spacing Chip
83. 1/2" Spacing Chip
84. 1/2" Spacing Chip
85. 1/2" Spacing Chip
86. 1/2" Spacing Chip
87. 1/2" Spacing Chip
88. 1/2" Spacing Chip
89. 1/2" Spacing Chip
90. 1/2" Spacing Chip
91. 1/2" Spacing Chip
92. 1/2" Spacing Chip
93. 1/2" Spacing Chip
94. 1/2" Spacing Chip
95. 1/2" Spacing Chip
96. 1/2" Spacing Chip
97. 1/2" Spacing Chip
98. 1/2" Spacing Chip
99. 1/2" Spacing Chip
100. 1/2" Spacing Chip

Features:

- 1/2" Flashing support to hold all in track
- Anvil on top p.c. attached and ready for installation
- Cap indicates module height compatibility
- Backing brace that allows static module placement
- Lightening of hardware and connectors, with in track modules



SUNFRAME Microrail™ 6.5' Splice





Sub-Components:

1. Base
2. DT Clamping Socket Head Cap Screw
3. High Adjustment Escrow
4. Torx
5. Direct Socket Head Cap Screw
6. 2.5" x 4" Adjustable Support & Connection
7. E-Clamp Module Mounting
8. 1/2" Spacing Chip
9. 1/2" Spacing Chip
10. 1/2" Spacing Chip
11. 1/2" Spacing Chip
12. 1/2" Spacing Chip
13. 1/2" Spacing Chip
14. 1/2" Spacing Chip
15. 1/2" Spacing Chip
16. 1/2" Spacing Chip
17. 1/2" Spacing Chip
18. 1/2" Spacing Chip
19. 1/2" Spacing Chip
20. 1/2" Spacing Chip
21. 1/2" Spacing Chip
22. 1/2" Spacing Chip
23. 1/2" Spacing Chip
24. 1/2" Spacing Chip
25. 1/2" Spacing Chip
26. 1/2" Spacing Chip
27. 1/2" Spacing Chip
28. 1/2" Spacing Chip
29. 1/2" Spacing Chip
30. 1/2" Spacing Chip
31. 1/2" Spacing Chip
32. 1/2" Spacing Chip
33. 1/2" Spacing Chip
34. 1/2" Spacing Chip
35. 1/2" Spacing Chip
36. 1/2" Spacing Chip
37. 1/2" Spacing Chip
38. 1/2" Spacing Chip
39. 1/2" Spacing Chip
40. 1/2" Spacing Chip
41. 1/2" Spacing Chip
42. 1/2" Spacing Chip
43. 1/2" Spacing Chip
44. 1/2" Spacing Chip
45. 1/2" Spacing Chip
46. 1/2" Spacing Chip
47. 1/2" Spacing Chip
48. 1/2" Spacing Chip
49. 1/2" Spacing Chip
50. 1/2" Spacing Chip
51. 1/2" Spacing Chip
52. 1/2" Spacing Chip
53. 1/2" Spacing Chip
54. 1/2" Spacing Chip
55. 1/2" Spacing Chip
56. 1/2" Spacing Chip
57. 1/2" Spacing Chip
58. 1/2" Spacing Chip
59. 1/2" Spacing Chip
60. 1/2" Spacing Chip
61. 1/2" Spacing Chip
62. 1/2" Spacing Chip
63. 1/2" Spacing Chip
64. 1/2" Spacing Chip
65. 1/2" Spacing Chip
66. 1/2" Spacing Chip
67. 1/2" Spacing Chip
68. 1/2" Spacing Chip
69. 1/2" Spacing Chip
70. 1/2" Spacing Chip
71. 1/2" Spacing Chip
72. 1/2" Spacing Chip
73. 1/2" Spacing Chip
74. 1/2" Spacing Chip
75. 1/2" Spacing Chip
76. 1/2" Spacing Chip
77. 1/2" Spacing Chip
78. 1/2" Spacing Chip
79. 1/2" Spacing Chip
80. 1/2" Spacing Chip
81. 1/2" Spacing Chip
82. 1/2" Spacing Chip
83. 1/2" Spacing Chip
84. 1/2" Spacing Chip
85. 1/2" Spacing Chip
86. 1/2" Spacing Chip
87. 1/2" Spacing Chip
88. 1/2" Spacing Chip
89. 1/2" Spacing Chip
90. 1/2" Spacing Chip
91. 1/2" Spacing Chip
92. 1/2" Spacing Chip
93. 1/2" Spacing Chip
94. 1/2" Spacing Chip
95. 1/2" Spacing Chip
96. 1/2" Spacing Chip
97. 1/2" Spacing Chip
98. 1/2" Spacing Chip
99. 1/2" Spacing Chip
100. 1/2" Spacing Chip

Features:





- Anvil on top p.c. attached and ready for installation
- Cap indicates module height compatibility
- Backing brace that allows static module placement
- Lightening of hardware and connectors, with in track modules

SYSTEM COMPONENTS : **D** : **PAGE**
 INSTALLATION GUIDE





See the Design and Engineering Guide for details on regional itax spots and overhang

SYSTEM LAYOUT : **E** : **PAGE**
 INSTALLATION GUIDE




See the Design and Engineering Guide for details on regional itax spots and overhang

FLASHING & SLIDERS : **G** : **PAGE**
 INSTALLATION GUIDE



See the Design and Engineering Guide for details on regional itax spots and overhang

THERMAL EXPANSION LIMITS : **F** : **PAGE**
 INSTALLATION GUIDE



See the Design and Engineering Guide for details on regional itax spots and overhang

PROJECT NAME

MIKE MORRIS
 2720 SW 18TH AVENUE,
 OCALA, FL 34471 USA
 APN# R235800321
 UTILITY: Ocala Electric
 AHJ: MARION COUNTY

SHEET NAME
 SPEC SHEETS

SHEET SIZE
 ANSIB
 11" X 17"

SHEET NUMBER
 PV-17

VERSION	DATE	REV
D-DESCRIPTION	07/10/2022	UR
INITIAL RELEASE		

PROJECT NAME
MIKE MORRIS
2720 SW 18TH AVENUE,
OCALA, FL 34471 USA
APN# R2358003021
UTILITY: Ocala Electric
AHJ: MARION COUNTY

SHEET NAME
SPEC SHEETS

SHEET SIZE
ANSIB
11" X 17"

SHEET NUMBER
PV-18

SFM SUN FRAME MICROGRID™
TRIMRAIL + MICRORAIL INSTALLATION
INSTALLATION GUIDE : PAGE

ALIGN FRONT ROW:
Align front row Trimrail™ roof attachments with string line.
Use only 1/4" long line with back ends positioned at least 10' apart.

TIGHTEN SLIDERS:
Tighten 1/4" x 1/4" screw and Trimrail™ roof attachment (sliders) clamp socket head cap screw.

INSTALL TRIMRAIL SPICE:
Place Trimrail™ with front SFP up and front inset. It contacts, retent, stop tab of roof bonding clip.

VERIFY SPICE INSTALLATION:
Verify front engagement of splice fits at top of trim rail. Do not tug on Trimrail™ from top of trim rail.

VERIFY SPICE INSTALLATION:
Verify front engagement of splice fits at top of trim rail. Do not tug on Trimrail™ from top of trim rail.

ATTACH TRIMRAIL TO ROOF ATTACHMENT:
Secure Trimrail™ to roof attachment using SFP. SFP level across all Trimrail™ roof attachments. After roof is level, tighten crossbar clamp according to Microgrid™ Trimrail™ roof attachment to spec.

INSTALL MODULE CLIPS ON TRIMRAIL:
Install module clips on Trimrail™ using 1/4" x 1/4" screw and Trimrail™ roof attachment (sliders) clamp socket head cap screw. Minimum of two clips are required per module. Refer to SFM D&E guide and J-hub user for correct position and quantity of module clips.

POSITION MODULE CLIPS ACCORDING TO MODULE THICKNESS:
Align notch in module clip with a small rib according to module thickness (indicated in post-mount required location).

INSTALL MICRORAILS:
Install Microrails™ on the roof using 1/4" x 1/4" screw and Trimrail™ roof attachment (sliders) clamp socket head cap screw. Install Microrails™ into slots and push Microrails™ to top of Mike Morris. Ensure that cap remains in upper most (down) position.

TRIMRAIL PREPARATION:
Trimrail™ (Trimrail™) for roof row lengths required. When 2' or less attachment points are available at front of module, engage floating trim. Clamp may be required, see page 13 for details.

JOIN TRIMRAIL SECTION AT SPICE:
Join Trimrail™ sections in alignment, joint and vertical, stop tab in contact with both Trimrail™ sections.

LAY IN MODULES:
Install first two (2) modules in bottom row. Install downward end of module into the Trimrail™ and module clips first and then position upright 2' increments to support modules.

FASTEN MODULES:
Finish installing modules along top and tighten fastening bolts as necessary and splices to 20 ft. fit after each panel is installed.

TIGHTEN FASTENERS:
Tighten fasteners to 24 ft. fit.
NOTE: If you are using a 1/4" x 1/4" screw and Trimrail™ roof attachment (sliders) clamp socket head cap screw, ensure that cap remains in upper most (down) position.

ADJUST MICRORAIL CAP-DOWN TO ENGAGE WITH MODULE:
With microrail pressed against module 1, apply downward pressure to module side of cap with screw. 2. Separate microrail cap from module 1. 3. Simultaneously re-engage to base at corresponding module height location.

IMPORTANT: Microrail caps and splices must be installed with at least 2" engagement with module.

VERIFY CORRECT POSITION OF CAP:
Check position and verify cap on down slope. Splice is tight with no gap between cap and module after tightening but

SELF MODULES:
Ensure modules are properly seated in cap and base.

LAY IN MODULES:
Install first two (2) modules in bottom row. Install downward end of module into the Trimrail™ and module clips first and then position upright 2' increments to support modules.

FASTEN MODULES:
Finish installing modules along top and tighten fastening bolts as necessary and splices to 20 ft. fit after each panel is installed.

TIGHTEN FASTENERS:
Tighten fasteners to 24 ft. fit.
NOTE: If you are using a 1/4" x 1/4" screw and Trimrail™ roof attachment (sliders) clamp socket head cap screw, ensure that cap remains in upper most (down) position.

ADJUSTED SPICE ADJUSTMENT:
Tower and height adjustment feature may be required to alternate position as required to achieve first turn module engagement.

ADJUSTED SPICE ADJUSTMENT:
Tower and height adjustment feature may be required to alternate position as required to achieve first turn module engagement.

SFM SUN FRAME MICROGRID™
MODULE MOUNTING
INSTALLATION GUIDE : PAGE

WIRE MANAGEMENT IS PERFORMED AFTER EACH ROW OF MODULES IS INSTALLED. REFER TO WIRE MANAGEMENT SECTION (Pgs. 6 & 7) FOR DETAILED INSTRUCTIONS.

ATTACH SPICE:
Attach splice at intersection of two (2) modules.
• Use standard splice if required per SFM D&E.
• Ensure minimum module engagement using welder marks.

FASTEN MODULES:
Finish installing modules along top and tighten fastening bolts as necessary and splices to 20 ft. fit after each panel is installed.

TIGHTEN FASTENERS:
Tighten fasteners to 24 ft. fit.
NOTE: If you are using a 1/4" x 1/4" screw and Trimrail™ roof attachment (sliders) clamp socket head cap screw, ensure that cap remains in upper most (down) position.

ADJUSTED SPICE ADJUSTMENT:
Tower and height adjustment feature may be required to alternate position as required to achieve first turn module engagement.

ADJUSTED SPICE ADJUSTMENT:
Tower and height adjustment feature may be required to alternate position as required to achieve first turn module engagement.

ADJUSTED SPICE ADJUSTMENT:
Tower and height adjustment feature may be required to alternate position as required to achieve first turn module engagement.

ADJUSTED SPICE ADJUSTMENT:
Tower and height adjustment feature may be required to alternate position as required to achieve first turn module engagement.



SOLAR LIGHT & MORE
 5640 SW 18TH PLACE, SUITE 400
 OCALA, FL 34474 USA
 PHONE: 352.268.6881
 PHONE: 352.268.6881
 EMAIL: kathy@solarlighthe.com


VERSION	DATE	REV
DESCRIPTION		
INITIAL RELEASE	07/10/2022	UR

PROJECT NAME
 2720 SW 18TH AVENUE
 Ocala, FL 34471 USA
 APN# R2358003021
 UTILITY: OCALA ELECTRIC
 AHJ: MARION COUNTY

SHEET NAME
 SPEC SHEETS

SHEET SIZE
 ANSIB
 11" X 17"

SHEET NUMBER
 PV-21



Certificate: 70131735
 Project: 80111014

Master Contract: 266909
 Date Issued: 2022-02-28

SolarMount

The system listed is designed to provide bonding/grounding, and mechanical stability for photovoltaic modules. The system is secured to the roof with the L-Foot components through the roofing material to building structure. Modules are secured to the racking system with stainless steel or aluminum mid clamps and Aluminum end clamps. The modules are bonded to the racking system with the stainless-steel bonding mid clamps with piercing points. The system is grounded with 10 AWG copper wire to bonding/grounding legs. Fire ratings of Class A with Type 1, 2, 3 (with metallic frame), 10 (with metallic frame), 19, 22, 25, 29, or 30 for steep slope. Tested at 5" interstitial gap which allows installation at any stand-off height.

The grounding of the system is intended to comply with the latest edition of the National Electrical Code, to include NEC 250 & 690. Local codes compliance is required, in addition to national codes. All grounding/bonding connections are to be torqued in accordance with the Installation Manual and the settings used during the certification testing for the current edition of the project report.

The system may employ optimizers/micro-inverters and used for grounding when installed per installation instructions.

UL 2703 Mechanical Load ratings:

Downward Design Load (lb/ft ²)	113.5
Upward Design Load (lb/ft ²)	50.7
Down-Slope Load (lb/ft ²)	16.13

Test Loads:

Downward Load (lb/ft ²)	170.20
Upward Load (lb/ft ²)	76.07
Down-Slope Load (lb/ft ²)	24.2

Unirac Large Array

ULA is a ground mount system using the SolarMount (SM) platform for the bonding and grounding of PV modules. ULA aluminum components merge with SM rails and installer-supplied steel pipe. The SM rail system is secured to the horizontal Pipe using the Rail Bracket components. The Rear and Front cap secures the horizontal Pipe to the vertical Pipe. The Front cap is also used to secure the Cross brace. A Slider is attached to the vertical Pipe to secure the Cross brace. The SM rails, caps, slider, rail brackets, and cross braces materials are



Certificate of Compliance

Certificate: 70131735
 Project: 80111014

Master Contract: 266909
 Date Issued: 2022-02-28

Issued To:
 Unirac
 1411 Broadway NE
 Albuquerque, New Mexico, 87102
 United States
 Attention: Klaus Nicolaedis

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Michael Hoffmann*
 Michael Hoffmann

PRODUCTS

CLASS - C531302 - POWER SUPPLIES - PHOTOVOLTAICS-PV Racking and clamping systems
 CLASS - C531382 - POWER SUPPLIES - PHOTOVOLTAICS-PV Racking and clamping systems - Certified to US Standards

Models:	SM	SOLARMount Flush-to-Roof is an extruded aluminum rail PV racking system that is installed parallel to the roof in landscape or portrait orientations.
---------	----	---

1. Minimum Design Loads for Buildings and other Structures, ASCE/SEI 7-10, ASCE/SEI 7-16
2. 2020 Florida Building Code, by Florida Building Commission
3. 2006-2018 International Building Code, by International Code Council, Inc. w/ Provisions from SEAOC PV-2 2017.
4. 2006-2018 International Residential Code, by International Code Council, Inc. w/ Provisions from SEAOC PV-2 2017.
5. AC428, Acceptance Criteria for Modular Framing Systems Used to Support Photovoltaic (PV) Panels, November 1, 2012 by ICC-ES.

Following are typical specifications to meet the above code requirements:

Design Criteria:
 Ground Snow Load = 0 - 100 (psf)
 Basic Wind Speed = 90 - 180 (mph)
 Roof Mean Height = 0 - 60 (ft)
 Roof Pitch = 0 - 45 (degrees)
 Exposure Category = B, C & D

Attachment Spacing:
 Per U-builder Engineering report,
 Maximum cantilever length is L/3, where "L" is the span noted in the U-builder online tool.

Clearance:
 2" to 10" clear from top of roof to top of PV panel.

Tolerance(s):
 1.0" tolerance for any specified dimension in this report is allowed for installation.

Installation Orientation:
 See SFM Installation Guide
 Landscape - PV Panel long dimension is parallel to ridge/eave line of roof and the PV panel is mounted on the long side.
 Portrait - PV Panel short dimension is parallel to ridge/eave line of roof and the PV panel is mounted on the short side.
 Attachment shall be staggered where ground snow load exceeds 10 PSF.

Testing: Values were based on UTR-299 testing provided by Unirac.

1478 Stone Point Drive, Suite 190, Roseville, CA 95661
 916.961.3960 916.961.3965 www.pzse.com
[LinkedIn](#) [Instagram](#) [Facebook](#)



Components and Cladding Roof Zones:
 The Components and Cladding Roof Zones shall be determined based on ASCE 7-05, ASCE 7-10 & 7-16 Component and Cladding design.

Notes:
 1) U-builder Online tool analysis is only for Unirac SFM Sunframe Microrail system only and do not include roof capacity check.
 2) Risk Category II per ASCE 7-16.
 3) Topographic factor, k_{zt} is 1.0.
 4) Array Edge Factor $F_e = 1.5$
 5) Average parapet height is 0.0 ft.
 6) Wind speeds are LBED values.
 7) Attachment spacing(s) apply to a seismic design category 1 or less.

Design Responsibility:
 The U-builder design software is intended to be used under the responsible charge of a registered design professional where required by the authority having jurisdiction. In all cases, this U-builder software should be used under the direction of a design professional with sufficient structural engineering knowledge and experience to be able to:

- Evaluate whether the U-builder Software is applicable to the project, and
- Understand and determine the appropriate values for all input parameters of the U-builder software.

This letter certifies that the Unirac SFM Sunframe Microrail, when installed according to the U-builder engineering report and the manufacture specifications, is in compliance with the above codes and loading criteria.

This certification excludes evaluation of the following components:
 1) The structure to support the loads imposed on the building by the array, including, but not limited to: strength and deflection of structural framing members, fastening and/or strength of roofing materials, and/or the effects of snow accumulation on the structure.
 2) The attachment of the SFM 2" Microrail or 8" Attached Splice to the existing structure.
 3) The capacity of the solar module frame to resist the loads.

This requires additional knowledge of the building and is outside the scope of the certification of this racking system. If you have any questions on the above, do not hesitate to call.

Prepared by:
 PZSE, Inc. - Structural Engineers
 Roseville, CA



DIGITAL SIGNATURE
 12/31/2020

1478 Stone Point Drive, Suite 190, Roseville, CA 95661
 916.961.3960 916.961.3965 www.pzse.com
[LinkedIn](#) [Instagram](#) [Facebook](#)

THIS ITEM HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY PAUL K. ZACHER, PE ON 12/31/2020 USING A SHA-1 AUTHENTICATION CODE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SHA-1 AUTHENTICATION CODE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

VERSION	DESCRIPTION	DATE	REV
	INITIAL RELEASE	07/10/2022	01

PROJECT NAME	MIKE MORRIS 2720 SW 18TH AVENUE OCALA, FL 34471 USA APN# R2358003021 UTILITY: Ocala Electric AHJ: MARION COUNTY
SHEET NAME	SPEC SHEETS
SHEET SIZE	ANSI B 11" X 17"
SHEET NUMBER	PV-22

Tier 2
Standard Interconnection Agreement
Customer-Owned Renewable Generation System

This **Agreement** is made and entered into this 30 day of August, 2022, by and between MICHAEL J. MORRIS, (hereinafter called "**Customer**"), located at 2720 SW 18TH AVE in Ocala, Florida, and the City of Ocala doing business as Ocala Electric Utility (hereafter called "**OEU**"), a body politic. Customer and OEU shall collectively be called the "**Parties**". The physical location/premise where the interconnection is taking place: 2720 SW 18TH AVE, Ocala, Fl. 34471.

WITNESSETH

Whereas, a Tier 2 Renewable Generation System (RGS) is an electric generating system that uses one or of more of the following fuels or energy sources: hydrogen, biomass, solar energy, geothermal energy, wind energy, ocean energy, waste heat, or hydroelectric power as defined in Section 377.803, Florida Statutes, rated at more than 10 kilowatts (10 kW) but not greater than 100 kilowatts (100 kW) alternating current (AC) power output and is primarily intended to offset part or all of the customer's current electric requirements; and

Whereas, OEU operates an electric system serving parts of the City of Ocala and Marion County; and

Whereas, Customer has made a written Application to OEU, a copy being attached hereto, to interconnect its RGS with OEU's electrical supply grid at the location identified above; and

Whereas, the City of Ocala and the Florida Municipal Power Agency (hereinafter called "FMPA") have entered into the All-Requirements Power Supply Contract pursuant to which OEU has agreed to purchase and receive, and FMPA has agreed to sell and supply OEU with all energy and capacity necessary to operate OEU's electric system, which limits OEU's ability to directly purchase excess energy from customer-owned renewable generation; and

Whereas, in order to promote the development of small customer-owned renewable generation by permitting OEU to allow its customers to interconnect with OEU's electric system and to allow OEU customers to offset their electric consumption with customer-owned renewable generation, FMPA, in accordance with the terms and conditions of this agreement, has agreed to purchase excess customer-owned generation from OEU customers interconnected to OEU's electric system; and

Whereas, OEU desires to provide interconnection of a RGS under conditions which will insure the safety of OEU customers and employees, reliability and integrity of its distribution system;

(Continued on Sheet No. 22.1)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

OCALA ELECTRIC UTILITY
OCALA, FLORIDA
(Continued from Sheet No. 22.0)

FIRST REVISED SHEET NO. 22.1
CANCELS ORIGINAL SHEET NO. 22.1

NOW, THEREFORE, for and in consideration of the mutual covenants and agreements herein set forth, the parties hereto covenant and agree as follows:

1. The Customer shall be required to enter into a Tri-Party Net-Metering Purchase Power Agreement with FMPA and OEU.
2. "Gross power rating" (GPR) means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with OEU distribution facilities. For inverter-based systems, the GPR shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.
3. This agreement is strictly limited to cover a Tier 2 RGS as defined above. It is the Customer's responsibility to notify OEU of any change to the GPR of the RGS by submitting a new application for interconnection specifying the modifications at least 30 days prior to making the modifications. In no case should modifications to the RGS be made such that the GPR increases above the 100 kilowatts (100 kW) limit.
4. The RGS GPR must not exceed 90 percent (90%) of the Customer's OEU calculated distribution service rating at the Customer's location (including shared electric facilities). If the GPR does exceed the 90 percent (90%) limit, the Customer shall be responsible to pay the cost of upgrades to the distribution facilities required to accommodate the GPR capacity and ensure the 90 percent (90%) threshold is not breached. OEU will not allow a RGS GPR greater than required to offset the customer's annual kWh energy consumption (based on customer's historical consumption data or by means of estimated usage of similar type of service as determined by OEU).
5. The Customer shall be required to pay a non-refundable application fee of \$375 for the review and processing of the application.
6. The Customer shall fully comply with OEU's Rules and Regulations and Electric Service Specifications as those documents may be amended or revised by OEU from time to time.
7. The Customer certifies that its installation, its operation and its maintenance shall be in compliance with the following standards (or most current version at time of inspection approval):
 - a. IEEE-1547 (2018) Standard for Interconnecting Distributed Resources with Electric Power System;
 - b. IEEE-1547.1 (2005) Standard Conformance Test Procedures for Equipment Interconnection Distributed Resources with Electric Power Systems;
 - c. UL-1741 (2010) Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed *Energy Resources*.

(Continued on Sheet No. 22.2)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

- d. The National Electric Code, state and/or local building codes, mechanical codes and/or electrical codes;
- e. The manufacturer's installation, operation and maintenance instructions.

8. The Customer is not precluded from contracting for the lease, operation or maintenance of the RGS with a third party. Such lease may not provide terms or conditions that provide for any payments under the agreement to any way indicate or reflect the purchase of energy produced by the RGS. Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the customer-owned renewable generation. Notwithstanding this restriction, in the event that Customer is determined to have engaged in the retail purchase of electricity from a party other than OEU, then Customer shall be in breach of this Agreement and may be subject to the jurisdiction of the Florida Public Service Commission and to fines/penalties.

9. The Customer shall provide a copy of the manufacturer's installation, operation and maintenance instructions to OEU. If the RGS is leased to the Customer by a third party, or if the operation or maintenance of the RGS is to be performed by a third party, the lease and/or maintenance agreements and any pertinent documents related to these agreements shall be provided to OEU.

10. Prior to commencing parallel operation with OEU's electric system, Customer shall have the RGS inspected and approved by the appropriate code authorities having jurisdiction. Customer shall provide a copy of this inspection and approval to OEU.

11. The Customer agrees to permit OEU, if it should so choose, to inspect the RGS and its component equipment and the documents necessary to ensure compliance with this Agreement both before and after the RGS goes into service and to witness the initial testing of the RGS equipment and protective apparatus. OEU will provide Customer with as much notice as reasonably possible, either in writing, email, facsimile or by phone as to when OEU may conduct inspections and or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, Customer agrees to provide OEU access to the Customer's premises for any purpose in connection with the performance of the obligations required by this Agreement or, if necessary, to meet OEU's legal obligation to provide service to its customers. At least ten (10) business days prior to initially placing the customer-owned renewable generation system in service, Customer shall provide written notification to OEU advising OEU of the date and time at which Customer intends to place the system in service, and OEU shall have the right to have personnel present on the in-service date in order to ensure compliance with the requirements of this Agreement.

(Continued on Sheet No. 22.3)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

12. The Customer's RGS must have an appropriately sized grid-tie inverter system that includes applicable protective systems. Customer certifies that the RGS equipment includes a utility-interactive inverter or interconnection system equipment that ceases to interconnect with the OEU system upon a loss of OEU power. The inverter shall be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing laboratory (NRTL) to comply with UL 1741. The NRTL shall be approved by the Occupational Safety & Health Administration (OSHA).
13. If Customer adds another RGS which (i) utilizes the same utility-interactive inverter for both systems; or (ii) utilizes a separate utility-interactive inverter for each system, then Customer shall provide OEU with sixty (60) days advance written notice of the addition.
14. The Customer shall not energize the OEU system when OEU's system is deenergized. The Customer shall cease to energize the OEU system during a faulted condition on the OEU system and/or upon any notice from OEU that the deenergizing of Customer's RGS equipment is necessary. The Customer shall cease to energize the OEU system prior to automatic or non-automatic reclosing of OEU's protective devices. There shall be no intentional islanding, as described in IEEE 1547, between the Customer's and OEU's systems.
15. The Customer is responsible for the protection of its generation equipment, inverters, protection devices, and other system components from damage from the normal and abnormal operations that occur on OEU's electric system in delivering and restoring system power. Customer agrees that any damage to any of its property, including, without limitation, all components and related accessories of its RGS system, due to the normal or abnormal operation of OEU's electric system, is at Customer's sole risk and expense. Customer is also responsible for ensuring that the customer-owned renewable generation equipment is inspected, maintained, and tested regularly in accordance with the manufacturer's instructions to ensure that it is operating correctly and safely.
16. The Customer must install, at their expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the customer-owned renewable generation system and any Customer wiring connected to OEU's electric system such that back feed from the customer-owned renewable generation system to OEU's electric system cannot occur when the switch is in the open position. The manual disconnect switch shall be mounted separate from the meter socket on an exterior surface adjacent to the meter. The switch shall be readily accessible to OEU and capable of being locked in the open position with an OEU padlock. When locked and tagged in the open position by OEU, this switch will be under the control of OEU.

(Continued on Sheet No. 22.4)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

17. Subject to an approved inspection, including installation of acceptable disconnect switch, this Agreement shall be executed by OEU within thirty (30) calendar days of receipt of a completed application. Customer must execute this Agreement and return it to OEU at least thirty (30) calendar days prior to beginning parallel operations with OEU's electric system, subject to the requirements of Sections 18 and 19, below, and within one (1) year after OEU executes this Agreement.

18. Once OEU has received Customer's written documentation that the requirements of this Agreement have been met, all agreements and documentation have been received and the correct operation of the manual switch has been demonstrated to an OEU representative, OEU will, within fifteen (15) business days, send written notice that parallel operation of the RGS may commence.

19. OEU requires the Customer to maintain general liability insurance for personal injury and property damage in the amount of not less than one million dollars (\$1,000,000.00).

20. OEU will furnish, install, own and maintain metering equipment capable of measuring the flow of kilowatt-hours (kWh) of energy. The Customer's service associated with the RGS will be metered to measure the energy delivered by OEU to Customer, and also measure the energy delivered by Customer to OEU. Customer agrees to provide safe and reasonable access to the premises for installation, maintenance and reading of the metering and related equipment. The Customer shall not be responsible for the cost of the installation and maintenance of the metering equipment necessary to measure the energy delivered by the Customer to OEU.

21. The Customer shall be solely responsible for all legal and financial obligations arising from the design, construction, installation, operation, maintenance and ownership of the RGS.

22. The Customer must obtain all permits, inspections and approvals required by applicable jurisdictions with respect to the generating system and must use a licensed, bonded and insured contractor to design and install the generating system. The Customer agrees to provide OEU with a copy of the local building code official inspection and certification of installation. The certification shall reflect that the local code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.

23. In no event shall any statement, representation, or lack thereof, either express or implied, by OEU, relieve the Customer of exclusive responsibility for the Customer's system. Specifically, any OUS inspection of the RGS shall not be construed as confirming or endorsing the system design or its operating or maintenance procedures or as a warranty or guarantee as to the safety, reliability, or durability of the RGS. OEU's inspection, acceptance, or its failure to inspect shall not be deemed an endorsement of any RGS equipment or procedure. Further, as set forth in Sections 15 and 26 of this Agreement, Customer shall remain solely responsible for any and all losses, claims, damages and/or expenses related in any way to the operation or misoperation of its RGS equipment.

(Continued on Sheet No. 22.5)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

24. Notwithstanding any other provision of this Interconnection Agreement, OEU, at its sole and absolute discretion, may isolate the Customer's system from the distribution grid by whatever means necessary, without prior notice to the Customer. To the extent practical, however, prior notice shall be given. The system will be reconnected as soon as practical once the conditions causing the disconnection cease to exist. OEU shall have no obligation to compensate the Customer for any loss of energy during any and all periods when Customer's RGS is operating at reduced capacity or is disconnected from OEU's electrical distribution system pursuant to this Interconnection Agreement. Typical conditions which may require the disconnection of the Customer's system include, but are not limited to, the following:

- a. OEU utility system emergencies, forced outages, uncontrollable forces or compliance with prudent electric utility practice.
- b. When necessary to investigate, inspect, construct, install, maintain, repair, replace or remove any OEU equipment, any part of OEU's electrical distribution system or Customer's generating system.
- c. Hazardous conditions existing on OEU's utility system due to the operation of the Customer's generation or protective equipment as determined by OEU.
- d. Adverse electrical effects (such as power quality problems) on the electrical equipment of OEU's other electric consumers caused by the Customer's generation as determined by OEU.
- e. When Customer is in breach of any of its obligations under this Interconnection Agreement or any other applicable policies and procedures of OEU.
- f. When the Customer fails to make any payments due to OEU by the due date thereof.

25. Upon termination of services pursuant to this Agreement, OEU shall open and padlock the manual disconnect switch and remove any additional metering equipment related to this Agreement. At the Customer's expense, within thirty (30) working days following the termination, the Customer shall permanently isolate the RGS and any associated equipment from OEU's electric supply system, notify OEU that the isolation is complete, and coordinate with OEU for return of OEU's lock.

26. To the fullest extent permitted by law, and in return for adequate, separate consideration, Customer shall indemnify, defend and hold harmless OEU, any and all of their members of its governing bodies, and its officers, agents, and employees for, from and against any and all claims, demands, suits, costs of defense, attorneys' fees, witness fees of any type, losses, damages, expenses, and liabilities, whether direct, indirect or consequential, related to, arising from, or in any way connected with:

- a. Customer's design, construction, installation, inspection, maintenance, testing or operation of Customer's generating system or equipment used in connection with this Interconnection Agreement, irrespective of any fault on the part of OEU.

(Continued on Sheet No. 22.6)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

- b. The interconnection of Customer's generating system with, and delivery of energy from the generating system to, OEU's electrical distribution system, irrespective of any fault on the part of OEU.
- c. The performance or nonperformance of Customer's obligations under this Interconnection Agreement or the obligations of any and all of the members of Customer's governing bodies and its officers, contractors (and any subcontractor or material supplier thereof), agents and employees.

Customer's obligations under this Section shall survive the termination of this Interconnection Agreement.

27. Customer shall not have the right to assign its benefits or obligations under this Agreement without OEU's prior written consent and such consent shall not be unreasonably withheld. If there is a change in ownership of the RGS, Customer shall provide written notice to OEU at least thirty (30) days prior to the change in ownership. The new owner will be required to assume, in writing, the Customer's rights and duties under this Agreement, or execute a new Standard Interconnection Agreement. The new owner shall not be permitted to net meter or begin parallel operations until the new owner assumes this Agreement or executes a new Agreement.

28. This Agreement supersedes all previous agreements and representations either written or verbal heretofore made between OEU and Customer with respect to matters herein contained. This Agreement, when duly executed, constitutes the only Agreement between parties hereto relative to the matters herein described. This Agreement shall continue in effect from year to year until either party gives sixty (60) days notice of its intent to terminate this Agreement.

29. This Agreement shall be governed by and construed and enforced in accordance with the laws, rules and regulations of the State of Florida and OEU's tariff as it may be modified, changed, or amended from time to time, including any amendments modification or changes to OEU's Net-Metering Service Rate Schedule, the schedule applicable to this Agreement. The Customer and OEU agree that any action, suit, or proceeding arising out of or relating to this Interconnection Agreement shall be initiated and prosecuted in the state court of competent jurisdiction located in Marion County, Florida, and OEU and the Customer irrevocably submit to the jurisdiction and venue of such court. To the fullest extent permitted by law, each Party hereby irrevocably waives any and all rights to a trial by jury and covenants and agrees that it will not request a trial by jury with respect to any legal proceeding arising out of or relating to this Interconnection Agreement.

None of the provisions of this Interconnection Agreement shall be considered waived by either Party except when such waiver is given in writing. No waiver by either Party of any one or more defaults in the performance of the provisions of this Interconnection Agreement shall operate or be construed as a waiver of any other existing or future default or defaults. If any one or more of the provisions of this Interconnection Agreement or the applicability of any provision to a

(Continued on Sheet No. 22.7)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

specific situation is held invalid or unenforceable, the provision shall be modified to the minimum extent necessary to make it or its application valid and enforceable, and the validity and enforceability of all other provisions of this Interconnection and all other applications of such provisions shall not be affected by any such invalidity or unenforceability. This Interconnection Agreement does not govern the terms and conditions for the delivery of power and energy to non-generating retail customers of OEU's electrical distribution system.

30. This Agreement incorporates by reference the terms of the tariff filed with the Florida Public Service Commission by OEU, including OEU's Net-Metering Service Rate Schedule, and associated technical terms and abbreviations, general rules and regulations and standard electric service requirements (as may be applicable) are incorporated by reference, as amended from time to time. To the extent of any conflict between this Agreement and such tariff, the tariff shall control.

31. OEU and Customer recognize that the Florida Statutes and/or the Florida Public Service Commission Rules, including those directly addressing the subject of this Agreement, may be amended from time to time. In the event that such statutes and/or rules are amended that affect the terms and conditions of this Agreement, OEU and Customer agree to supersede and replace this Agreement with a new Interconnection Agreement which complies with the amended statutes/rules.

32. Customer acknowledges that its provision of electricity to OEU hereunder is on a first-offered first-accepted basis and subject to diminution and/or rejection in the event the total amount of electricity delivered to OEU pursuant to the OEU's Net-Metering Service Rate Schedule (as filed with the Florida Public Service Commission), from all participating OEU customers, exceeds 2.5 percent (%) of the aggregate customer peak demand on OEU's electric system.

33. This Agreement is solely for the benefit of OEU and Customer and no right nor any cause of action shall accrue upon or by reason, to or for the benefit of any third party not a formal party to this Agreement. Nothing in this Agreement, expressed or implied, is intended or shall be construed to confer upon any person or corporation other than OEU or Customer, any right, remedy, or claim under or by reason of this Agreement or any of the provisions or conditions of this Agreement; and, all provisions, representations, covenants, and conditions contained in this Agreement shall inure to the sole benefit of and be binding upon OEU and Customer and their respective representatives, successors, and assigns. Further, no term or condition contained in this Agreement shall be construed in any way as a waiver by OEU of the sovereign immunity applicable to OEU as established by Florida Statutes, 768.28.

(Continued on Sheet No. 22.8)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

OCALA ELECTRIC UTILITY
OCALA, FLORIDA
(Continued from Sheet No. 22.7)

FIRST REVISED SHEET NO. 22.8
CANCELS ORIGINAL SHEET NO. 22.8

IN WITNESS WHEREOF, Customer and OEU have executed this Agreement the day and year first above written.

OUS:

By: Ken Whitehead

Title: Ken Whitehead

Date: 01 / 30 / 2023

Customer:

By: MICHAEL J. MORRIS
(Print Name)

M. J. Morris
(Signature)



Date: 30 Nov 22

City of Ocala Electric Utility Account Number:

520745 - 240263

Approved as to form and legality:

William E. Sexton

~~Robert W. Batsel, Jr.~~ William E. Sexton
~~Assistant~~ City Attorney

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

Tri-Party Net-Metering Power Purchase Agreement

This Tri-Party Net-Metering Power Purchase Agreement (this "Agreement") is entered into this 30 day of August, 2022, by and between the Florida Municipal Power Agency, a governmental joint action agency created and existing under the laws of the State of Florida (hereinafter "FMPA"), the City of Ocala doing business as Ocala Electric Utility, a body politic (hereinafter "OEU"), and MICHAEL J. MORRIS, a retail electric customer of OEU (hereinafter "Customer").

Section 1. Recitals

1.01. OEU and Customer have executed OEU's Standard Interconnection Agreement for a Customer-Owned Renewable Generation System (RGS) pursuant to which OEU has agreed to permit interconnection of Customer's renewable generation to OEU's electric system at Customer's presently-metered location, and Customer has agreed to deliver excess electric energy generated by Customer's Renewable Generation System to OEU's electric distribution system;

1.02. The City of Ocala and FMPA have entered into the All-Requirements Power Supply Contract, dated as of May 1, 1986, (hereinafter the "ARP Contract") pursuant to which the City of Ocala has agreed to purchase and receive, and FMPA has agreed to sell and supply OEU with all energy and capacity necessary to operate the OEU electric system, which limits OEU's ability to directly purchase excess energy from customer-owned renewable generation.

1.03. In order to promote the development of small customer-owned renewable generation by permitting OEU to allow its customers to interconnect with OEU's electric system and to allow OEU's electric customers to offset their electric consumption with customer-owned renewable generation, FMPA, in accordance with the terms and conditions of this agreement, has agreed to purchase excess customer-owned generation from OEU's electric customers interconnected to OEU's electric system.

NOW THEREFORE, for and in consideration of the mutual covenants and agreements set forth herein, the Parties covenant and agree as follows:

Section 2. Interconnection

2.01. Customer shall not begin parallel operations with the OEU electric distribution system until Customer has executed OEU's electric Standard Interconnection Agreement for Small Customer-Owned Renewable Generation and is in compliance with all terms and conditions

OEU requires that the customer install and operate the RGS in accordance with all applicable safety codes and standards. OEU shall establish and enforce terms and conditions of operation and disconnection of all interconnected customer-owned renewable generation as it relates to the effect of the RGS on OEU's electric distribution system.

(Continued on Sheet No. 20.1)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

Section 3. Metering

3.01 In accordance with the OEU's Standard Interconnection Agreement for Customer-Owned Renewable Generation, OEU shall install metering equipment at the point of delivery capable of recording two separate kWh meter readings: (1) the flow of electricity from OEU to the Customer (Delivered), and (2) the flow of excess electricity from the Customer to OEU. OEU shall take meter readings on the same cycle as the otherwise applicable rate schedule.

Section 4. Purchase of Excess Customer-Owned Renewable Generation

4.01. Customer-owned renewable generation shall be first used for Customer's own load and shall offset Customer's demand for OEU's electricity. All electric power and energy delivered by OEU to Customer shall be received and paid for by Customer to OEU (Received) pursuant to the terms, conditions and rates of the OEU otherwise applicable rate schedule.

4.02. Excess customer-owned renewable generation shall be delivered to the OEU Electric distribution system. For purposes of this Agreement, the term "excess customer-owned renewable generation" means any kWh of electrical energy produced by the customer-owned renewable generation system that is not consumed by Customer and is delivered to the OEU electric distribution system. FMPA agrees to purchase and receive, and Customer agrees to sell and deliver, all excess customer-owned renewable generation at the energy rate established by FMPA, which shall be calculated in accordance with Schedule A. Excess customer-owned renewable generation shall be purchased in the form of a credit on Customer's monthly energy consumption bill from OEU.

4.03. In the event that a given monthly credit for excess customer-owned renewable generation exceeds the total billed amount for Customer's consumption in any corresponding month, then the excess credit shall be applied to the subsequent month's bill. Excess energy credits produced pursuant to the preceding sentence shall accumulate and be used to offset Customer's energy consumption bill for a period of not more than twelve (12) months. At the end of each calendar year, any unused excess energy credits shall be paid by OEU to the Customer in accordance with the OEU Electric Net-Metering Service Rate Schedule.

(Continued on Sheet No. 20.2)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

4.04. FMPA and OEU shall not be required to purchase or receive excess customer-owned renewable generation, and may require Customer to interrupt or reduce production of customer-owned renewable generation, (a) when necessary in order to construct, install, maintain, repair, replace, remove, investigate, or inspect any OEU equipment or part of OEU's system; or (b) if either FMPA or OEU determine, in their sole judgment, that curtailment, interruption, or reduction is necessary because of emergencies, forced outages, force majeure, or compliance with any applicable electric code or standard.

4.05. Customer acknowledges that its provision of electricity to OEU hereunder is on a first-offered, first-accepted basis and subject to diminution and/or rejection in the event the total amount of electricity delivered to OEU pursuant to the Net-Metering Service Rate Schedule (as filed with the Florida Public Service Commission), from all participating OEU customers, exceeds two and one-half percent (2.5%) of the aggregate customer peak demand on the OEU electric system.

Section 5. Renewable Energy Credits

5.01. Customer shall offer FMPA a first right of refusal before selling or granting to any third party the right to the Green Attributes associated with its customer-owned renewable generation that is interconnected to OEU electric distribution system. The term "Green Attributes" shall include any and all credits, certificates, benefits, environmental attributes, emissions reductions, offsets, and allowances, however entitled, attributable to the generation of electricity from the customer-owned-renewable generation and its displacement of conventional energy generation.

5.02. Any additional meter(s) installed to measure total renewable electricity generated by the Customer for the purposes of measuring Green Attributes, including and renewable energy certificates (or similarly titled credits for renewable energy generated), shall be installed at the expense of the Customer, unless determined otherwise during negotiations for the sale of the Customer's credits to FMPA.

Section 6. Term and Termination

6.01. This Agreement shall become effective upon execution by all Parties, and shall remain in effect thereafter on a month-to-month basis until terminated by any Party upon thirty (30) days written notice to all other Parties.

6.02. This Agreement shall terminate immediately and without notice upon: (a) termination of the electric distribution service by OEU or (b) failure by Customer to comply with any of the terms and conditions of this Agreement or OEU's Standard Interconnection Agreement for Customer-Owned Renewable Generation.

(Continued on Sheet No. 20.3)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

Section 7. Miscellaneous Provisions

7.01. Assignment. It is understood and agreed that no party may transfer, sell, mortgage, pledge, hypothecate, convey, designate, or otherwise assign this Agreement, or any interest herein or any rights or obligations hereunder, in whole or in part, either voluntarily or by operation of law, (including, without limitation, by merger, consolidation, or otherwise), without the express written consent of the other parties (and any such attempt shall be void), which consent shall not be unreasonably withheld. Subject to the foregoing, this Agreement shall inure to the benefit of and be binding upon the parties and their respective successors and permitted assigns.

7.02. Amendment. It is understood and agreed that FMPA and OEU reserve the right, on no less than an annual basis, to change any of the terms and conditions, including pricing, in this Agreement on sixty (60) days advance written notice. FMPA and OEU may make such changes on an immediate basis in the event any applicable law, rule, regulation or court order requires them. In such event, FMPA and OEU will give Customer as much notice as reasonably possible under the circumstances.

7.03. Indemnification. To the fullest extent permitted by laws and regulations, and in return for adequate, separate consideration, Customer shall defend, indemnify, and hold harmless FMPA and OEU, their officers, directors, agents, guests, invitees, and employees from and against all claims, damages, losses to persons or property, whether direct, indirect, or consequential (including but not limited to fees and charges of attorneys, and other professionals and court and arbitration costs) arising out of, resulting from, occasioned by, or otherwise caused by the operation or misoperation of the customer-owned renewable generation, or the acts or omissions of any other person or organization directly or indirectly employed by the Customer to install, furnish, repair, replace or maintain the customer-owned renewable generation system, or anyone for whose acts any of them may be liable.

7.04. Governing Law. The validity and interpretation of this Agreement and the rights and obligations of the parties shall be governed and construed in accordance with the laws of the State of Florida without regard for any conflicts of law provisions that might cause the law of other jurisdictions to apply. All controversies, claims, or disputes arising out of or related to this Agreement or any agreement, instrument, or document contemplated hereby, shall be brought exclusively in the County or Circuit Court for Marion County, Florida, or the United States District Court sitting in Marion County, Florida, as appropriate.

(Continued on Sheet No. 20.4)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

7.05. Enforcement of Agreement. In the event that either party is required to enforce this Agreement by court proceedings or otherwise, the prevailing party shall be entitled to recover all fees and costs incurred, including reasonable attorney's fees and costs for trial, alternative dispute resolution, and/or appellate proceedings.

7.06. Severability. To the extent any provision of this Agreement is prohibited by or invalid under applicable law, such provision shall be ineffective to the extent of such prohibition or invalidity, without invalidating the remainder of such provision or the remaining provisions of this Agreement.

7.07. Third Party Beneficiaries and Sovereign Immunity. This Agreement is solely for the benefit of FMPA, OEU, and Customer and no right nor shall any cause of action accrue upon or by reason, to or for the benefit of any third party not a formal party to this Agreement. Nothing in this Agreement, expressed or implied, is intended or shall be construed to confer upon any person or corporation other than FMPA, OEU, or Customer, any right, remedy, or claim under or by reason of this Agreement or any of the provisions or conditions of this Agreement; and, all provisions, representations, covenants, and conditions contained in this Agreement shall inure to the sole benefit of and be binding upon FMPA, OEU, and Customer and their respective representatives, successors, and assigns. Further, no term or condition contained in this Agreement shall be construed in any way as a waiver by either FMPA or OEU of the sovereign immunity applicable to either or both of them as established by Florida Statutes, 768.28.

(Continued on Sheet No. 20.5)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

OCALA ELECTRIC UTILITY
OCALA, FLORIDA
(Continued from Sheet No. 20.4)

FIRST REVISED SHEET NO. 20.5
CANCELS ORIGINAL SHEET NO. 20.5

IN WITNESS WHEREOF, Customer and OEU have executed this Agreement the day and year first above written.

City of Ocala Electric Utility
By: Ken Whitehead
Title: Asst. City Manager
Date: 01 / 30 / 2023

Florida Municipal Power Agency
By: [Signature]
Title: Bus Dev & Sys Ops Director
Date: 01 / 30 / 2023

Customer
By: MICHAEL J. MORRIS
(Print Name)
[Signature]
(Signature)

Date: 30 AUG 22



Customer's City of Ocala Electric Utility Account Number: 520745 - 240263

Approved as to form and legality:

William E. Sexton
~~Robert W. Batsel, Jr.~~ William E. Sexton
~~Assistant~~ City Attorney

(Continued on Sheet No. 20.6)

Issued by: Michael Poucher, P.E.
Electric Utility Director

Effective: October 1, 2019

**Tri-Party Net-Metering Power Purchase Agreement
Schedule A**

I. All-Requirements Project Calculation of Excess Customer-Owned Renewable Generation Credit

- a) FMPA shall pay OEU for the excess kWh energy delivered by customer-owned renewable generation to OEU's electric system. Every month, OEU shall determine the total kWh of customer-owned renewable generation that is delivered to OEU's electric system, and shall send the information to FMPA as soon as it becomes available, but no later than the second working day of every month. FMPA will then provide a monthly payment to OEU in the form of a credit on the ARP power bill for the excess energy delivered to the distribution grid. The ARP Renewable Generation Credit will be calculated as follows:

ARP Renewable Generation Credit = Quarterly Energy Rate * Monthly kWh of excess customer-owned renewable generation

Quarterly Energy Rate = 3 month average of ARP energy rate. FMPA will update the Quarterly Energy Rate every April 1, July 1, October 1 and January 1.

- b) As part of the monthly bill adjustment, FMPA will also increase OEU's kWh billing amount by the same kWh amount as the customer-owned renewable generation purchased by FMPA. This adjustment is necessary because excess customer generation that flows onto OEU's electric system has been purchased by FMPA, but will remain on OEU's electric system and be used by OEU to meet its other customers' electric needs. As a result, OEU's monthly ARP bill will be adjusted accordingly to reflect FMPA's subsequent sale of this energy to OEU.

II. Payment for Unused Excess Energy Credits

- a) Monthly excess energy credits shall accumulate and be used to offset the Customer's following month energy consumption bill for a period of not more than twelve (12) months.
- b) At the end of each calendar year, OEU shall pay the Customer for any unused excess energy credits in accordance with the OEU Electric Net-Metering Service Rate Schedule.

American Strategic Insurance Corp
 1 ASI Way
 St. Petersburg, FL 33702
 Phone: (727) 374-2502

PROGRESSIVE
UMBRELLA

Premises Only Liability Declarations Page

Agent:
 Brightway Insurance
 P.O. Box 5700
 Jacksonville, FL 32247

Agent Code: 414286
For Policy Service, Call: (888)254-5014

Total Policy Premium: \$202
Policy Number: FLU143546
Plan Type: UMB

Policy Period: From: 05/29/2022 To: 05/29/2023
 (At 12:01 AM Standard Time at the residence premises)

Effective Date of This Transaction: 05/29/2022
Transaction Type: New Business

Named Insured:
 MICHAEL MORRIS
 2720 SW 18TH AVE
 OCALA, FL 34471

Premises Location(s):
 2720 SW 18TH AVE, OCALA, FL 34471-7793

Coverage Limit: \$ 1,000,000

<u>Coverages</u>	<u>Limit</u>	<u>Premium</u>
Liability Base Premium	\$ 1,000,000	\$200.00
Surcharges & Discounts		
		<u>Premium</u>
Desired Coverage Limit		\$0.00
Increased Underlying Property Liability		\$0.00
Territory Factor (UIM)		\$0.00
Premises Only Credit		(\$59.00)
Swimming Pool/Spas		\$40.00
Minimum Limit Premium Adjustment		\$0.00
Managing General Agent Fee		\$25.00
Florida Insurance Guaranty Association Fee		\$1.23
e-Policy Discount		(\$5.00)
TOTAL POLICY PREMIUM:		\$202.00

All Insureds:
 Michael Morris

Policy Forms:
 Amendment of Policy Provisions - Florida ASI PUP FL SP 10 20
 Premises Liability ASI PUP 005 09 99
 Auto Liability Exclusion - Florida ASI PUP FL ALE 10 20
 Public Or Livery Conveyance Exclusion - Florida ASI PUP FL PCE 10 20
 Personal Umbrella Liability Policy DL 98 01 06 98

Additional Interest:



Countersigned by Authorized Representative

St. Petersburg, FL

Date: 05/28/2022

Required Retained Limits

All Automobiles, Motorcycles, Motorhomes, Mopeds, and All Road Licensed Vehicles:
Required Retained Limits (Does not apply for Premises Only Liability policies)
 \$250,000 / \$500,000 / \$100,000 or \$300,000 CSL for policies with any drivers age 22-79
 \$500,000 / \$500,000 / \$500,000 or \$500,000 CSL for policies with any drivers 21 and younger or 80 and older *

All Automobiles and Motorhomes Requesting UM Coverage:
Required Retained Limits
 UM: \$250,000 / \$500,000 / \$100,000 or \$300,000 CSL for policies with any drivers age 22-79
 UM: \$500,000 / \$500,000 / \$500,000 or \$500,000 CSL for policies with any drivers 21 and younger or 80 and older

Comprehensive Personal Liability, Homeowners, or Farm Comprehensive Personal Liability:
Required Retained Limits
 \$300,000

Residential Rental Properties Covered Under the Dwelling Fire Policy for 1-4 Family Residences:
Required Retained Limits
 \$300,000

Personal Injury Coverage Endorsed to the Homeowners Policy (whenever available):
Required Retained Limits (Does not apply for Premises Only Liability policies)
 \$300,000

All Recreational Vehicles Including Golf Carts, Utility Vehicles, Trail Bikes or Other Vehicles Not Required to be Licensed:
Required Retained Limits (Does not apply for Premises Only Liability policies)
 \$250,000 / \$500,000 / \$100,000 or \$300,000 CSL

Watercraft:
Required Retained Limits (Does not apply for Premises Only Liability policies)
 \$250,000 / \$500,000 / \$100,000 or \$300,000 CSL

* Required Retained Limits are reduced to \$250,000/\$500,000/\$100,000 or \$300,000 CSL when the Underlying Automobile Surcharge is applied.

Detailed Schedule

<u>Automobiles</u>				
<u>Make</u>	<u>Model</u>			
N/A	N/A			

<u>Motorcycles and Mopeds</u>				
<u>Make</u>	<u>Model</u>			
N/A	N/A			

<u>Watercraft</u>				
<u>Make</u>	<u>Model</u>	<u>Length (ft)</u>	<u>MPH</u>	
N/A	N/A	N/A	N/A	

<u>Golf Carts, Utility Vehicles or Recreational Vehicles</u>				
<u>Make</u>	<u>Model</u>			
N/A	N/A			

<u>Motorhomes</u>				
<u>Make</u>	<u>Model</u>			
N/A	N/A			

Policyholder: MICHAEL MORRIS

Policy ID: FLU143546

Important Message(s):

1. Failure to maintain the Required Retained Limits may prevent this policy from providing coverage. The Required Retained Limits shall apply regardless of any applicable sublimit or reduced limits for specified occurrences.
2. You must notify us of any change in your retained limits or coverage.
3. Your underlying insurance carrier must have an AM Best rating of B+ or better or a Demotech rating of A or better.

Notes:

Title	(URGENT) FOR SIGNATURES - Agreement for Interconnection of.....
File name	fs.pdf
Document ID	2402cb9864df23e10570af098065d495b35df4c9
Audit trail date format	MM / DD / YYYY
Status	● Signed

Document History

- 
 SENT

01 / 30 / 2023
07:21:11 UTC-5

Sent for signature to William E. Sexton (wsexton@ocalafl.org), Ken Whitehead (kwhitehead@ocalafl.org) and Florida Municipal Power Agency (chris.gowder@fmpa.com) from biverson@ocalafl.org
IP: 216.255.240.104
- 
 VIEWED

01 / 30 / 2023
09:04:04 UTC-5

Viewed by William E. Sexton (wsexton@ocalafl.org)
IP: 216.255.240.104
- 
 SIGNED

01 / 30 / 2023
09:04:33 UTC-5

Signed by William E. Sexton (wsexton@ocalafl.org)
IP: 216.255.240.104
- 
 VIEWED

01 / 30 / 2023
09:49:08 UTC-5

Viewed by Ken Whitehead (kwhitehead@ocalafl.org)
IP: 216.255.240.104
- 
 SIGNED

01 / 30 / 2023
09:51:13 UTC-5

Signed by Ken Whitehead (kwhitehead@ocalafl.org)
IP: 216.255.240.104

Title	(URGENT) FOR SIGNATURES - Agreement for Interconnection of.....
File name	fs.pdf
Document ID	2402cb9864df23e10570af098065d495b35df4c9
Audit trail date format	MM / DD / YYYY
Status	● Signed

Document History



01 / 30 / 2023
09:59:22 UTC-5

Viewed by Florida Municipal Power Agency
(chris.gowder@fmpa.com)
IP: 38.77.131.2



01 / 30 / 2023
09:59:54 UTC-5

Signed by Florida Municipal Power Agency
(chris.gowder@fmpa.com)
IP: 38.77.131.2



01 / 30 / 2023
09:59:54 UTC-5

The document has been completed.