220615

OCALA ELECTRIC UTILITY OCALA, FLORIDA

FIRST REVISED SHEET NO. 19.0 CANCELS ORIGINAL SHEET NO. 19.0

APPLICATION FOR INTERCONNECTION OF CUSTOMER-OWNED RENEWABLE GENERATION SYSTEMS

TIER 1 - Ten (10) kW or Less

TIER 2 - Greater than 10 kW and Less Than or Equal to 100 kW

TIER 3 - Greater than 100 kW and Less Than or Equal to Two (2) MW

Note: These customer-owned renewable generation system size limits may be subject to a cumulative enrollment limit on net-metering customers located in the area served by the City of Ocala Electric Utility. Please refer to the Ocala Electric Utility Net-Metering Rate Schedule.

Ocala Electric Utility customers who install customer-owned renewable generation systems (RGS) and desire to interconnect those facilities with the Ocala Electric Utility system are required to complete this application. When the completed application and fees are returned to Ocala Electric Utility, the process of completing the appropriate Tier 1, Tier 2 or Tier 3 Interconnection Agreement can begin. This application and copies of the Interconnection Agreements may be obtained at Ocala Electric Utility, located at 201 SE 3rd Street, Ocala, Florida 34471, or may be requested by email from OEU@ocalafl.org.

1. Customer Information
Name: Angel Dane
Mailing Address: 4885 NE 27TH CT
City: OCALA State: FL Zip Code: 34479
Phone Number: 786-359-3855 Alternate Phone Number: 786-760-7905
Email Address: legnadane@gmail.com Fax Number: N/A
Ocala Electric Utility Customer Account Number: 527518-226006
2. RGS Facility Information Facility Location: 4885 NE 27TH CT, OCALA FL 34479
Ocala Electric Utility Customer Account Number: 527518-226006
RGS Manufacturer: 34- HANWHA QCELLS- QPEAK DUO G6+/340W
RGS Manufacturer: https://www.q-cells.us/
Manufacturer's Address:
Reference or Model Number: HANWHA QCELLS- QPEAK DUO G6+/340W
Serial Number:
Bollar Harrison
(Continued on Sheet No.19.1) Effective: October 1, 2019

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continue from Sheet No. 19.0)

FIRST REVISED SHEET NO. 19.1 CANCELS ORIGINAL SHEET NO. 19.1

3.	Facility	Rating	Informa	tion
----	----------	--------	---------	------

	_										
Gross Power	Rating:	9.86	("Gross	power	rating"	means	the 1	total m	anufacture	r's A	\C
namenlate ger	nerating c	anacity o	f an on-site cu	stomer-c	owned re	newable	e gene	eration s	system that	t Will	be
mannopiato bo		mpurity o	. 11 1	41. 0 - 1.	- Diagtai	a I Itility	y'a di	otributi	on faciliti	oc F	or
interconnecte	d to and	operate	in parallel wi	th Ocala	a Electri	c omig	y S ui	Sillouti	JII laciliti	vo. 1	OI
inverter-based	d systems	. the AC	nameplate ge	nerating	capacity	shall b	e calc	ulated l	by multipl	yıng 1	the
total installed	DC nam	neplate g	enerating capa	acity by	0.85 in	order to	acco	unt for	losses au	ring	ine
conversion fr											
Fuel or Energ	gy Source	: SOLAF	3								

4. Application Fee

The application fee is based on the Gross Power Rating and must be submitted with this application. The non-refundable application fee is \$375 for Tier 2 and \$750 for Tier 3 installations. There is no application fee for Tier 1 installations.

5. Interconnection Study Fee

Anticipated In- Service Date: 03/16/2022

For Tier 3 installations, a deposit in the amount of the estimated costs of the study (to be determined at time of application) must be paid along with this application in addition to the application fee referenced in Article 4 above. This deposit will be applied toward the cost of an interconnection study. The customer will be responsible for the actual costs of the study. Should the actual cost of the study be less than the deposit, the difference will be refunded to the customer. Customer agrees to comply with all interconnection requirements identified in the interconnection study report.

6. Required Documentation

Prior to completion of the Interconnection Agreement, the following information must be provided to the Ocala Electric Utility by the customer.

- A. Documentation demonstrating that the installation complies with (or most current version at time of inspection approval):
 - 1. IEEE 1547 (2018) Standard for Interconnecting Distributed Resources with Electric Power Systems.
 - 2. IEEE 1547.1 (2005) Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.
 - 3. UL 1741 (2010) Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources.

(Continued on Sheet No. 19.2)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 19.1)

FIRST REVISED SHEET NO. 19.2 CANCELS ORIGINAL SHEET NO. 19.2

- B. Documentation that the customer-owned renewable generation has been inspected and approved by local code officials prior to its operation in parallel with the Ocala Electric Utility system to ensure compliance with applicable local codes. OEU will also require proof of commission testing by a qualified 3rd party testing company (not affiliated in any way with the manufacturer, vendor or installation contractor), for compliance with all required and applicable codes, standards, and interconnection study requirements, prior to setting of OEU metering equipment.
- C. Proof of insurance in the amount of:

Tier 1 - \$100,000.00


Tier 2 - \$1,000,000.00

Tier 3 - \$2,000,000.00

Customer

By: AN	GEL DANE	Date:	03/27/22	
(Print Nar	ne)		/ /	
	ND-			
(Signature				

Issued by: Michael Poucher, P.E. Electric Utility Director





EVIDENCE OF PROPERTY INSURANCE

We will provide the insurance described on this form in return of the premium and compliance by the insured with all applicable provisions of the policy for which application has been made. No insurance is provided by us unless the premium is paid when due. If this insurance is terminated after policy issuance, we will provide written notice to the insured and any Mortgagee/Lienholder in accordance with policy provisions and any applicable legal requirements. The coverage described is subject to the provisions of the policy and this form is subordinate to the provisions of any policy declarations issued.

Policy Number: 07601399 - 1

Policy Period:

07/17/2022 From

To 07/17/2023

Policy Type: HO-3

At 12:01 a.m. Eastern Time at the Location of the Residence Premises

Print Date: 06/17/2022

First Named Insured and Mailing

Location of Residence Premises:

Agent:

Address:

Angel Dane 4885 NE 27TH CT OCALA, FL 34479 4885 NE 27TH CT OCALA FL 34479-8879 **GLV INSURANCE AGENCY** KELSEY DIANE CONNER 2005 VISTA PARKWAY, STE 200

WEST PALM BEACH, FL 33411

Coverage is only provided where a premium and a limit of liability is shown

All Other Perils Deductible: \$2,500

Hurricane Deductible: \$3,580 (2%)

LIMIT OF LIABILITY PREMIUM \$1,182

SECTION I - PROPERTY COVERAGES A. Dwelling:

\$179,000 \$3,580 \$44,750

B. Other Structures: C. Personal Property: D. Loss of Use:

\$17,900

LIMIT OF LIABILITY SECTION II - LIABILITY COVERAGES

\$100,000

\$16

E. Personal Liability: F. Medical Payments: \$2,000

Included

OTHER COVERAGES

Replacement Cost Loss Settlement on Dwelling up to Coverage A amount

Ordinance or Law Limit (25% of Cov A)

(See Policy)

Included

TOTAL POLICY PREMIUM INCLUDING ASSESSMENTS AND ALL SURCHARGES

Included

\$1,043

(Total includes assessments, surcharges and other premium adjustments not itemized here; refer to Policy Declarations)

	Additional Named Insured(s)
Name	Address
Yoilet Arevalo Ramirez	4885 NE 27TH CT OCALA, FL 34479-8879

		Additional Interest(s)	
#	Interest Type	Name and Address	Loan Number
1	1st Mortgagee	US BANK NA ISAOA PO BOX 961045 FORT WORTH, TX 76161-0045	3300296619

CIT EOI 02 21	Page 1 of 1	

P-170978		SINGLE-LINE DIAGRAM SINGLE-LINE DIAGRAM CHICKED BY: STATE OF STA	PV-3
GENERAL ELECTRICAL	UTILITY HAS 24-HR UNRESTRICTED ACCESS TO ALL PHOTOVOLTAIC SYSTEM COMPONENTS LOCATED AT THE SERVICE ENTRANGE. CONDUCTORS EXPOSED TO SURLIGHT SHALL BE LISTED AS	2 SUMLICHT RESISTANT PER NEC 3 UCATION SHALL BE SUTABLE FOR ARTICLE 310.10]. CONDICTORS EX-ROSED TO WET LOCATIONS SHALL BE SUTABLE FOR ARTICLE 310.10 (C). GROUNDING NOTES ALL EQUIPMENT SHALL BE PROPERLY GROUNDED PER THE PROPERLY GROUNDED PER THE PROPERLY GROUNDED PER THE TECUIREMENTS OF NEC ARTICLES 256.4 650 IN SHALL BE GROUNDED TO MOUNTING SHALL BE GROUNDED OROUNDING CLAMPS AS ALLOWED BY LOCAL JURISDICTION ALL OTHER EX-OSED METAL PARTS SHALL BE GROUNDED LEINS UL-LISTED LAYIN ULGS. TO MOUNTING SYSTEM HAS BEEN MOUNTING SYSTEM HAS BEEN WOULLE. IF THE EXTSTING WANN SERVICE PARIEL DCES NOT HAVE A VERIFABLE GROUNDING ELECTRODE. ON TRACTOR'S RESPONSIBILITY TO INSTALL A SUPPLEMENTAL GROUNDING ELECTRODE ON TRACTOR'S RESPONSIBILITY TO INSTALL BE A MINIMUM SIZE #8AWG WHEN USED WITH SHANDE GROUNDING ELECTRODE GOUNDING SHALL BE USED WHEN EXPOSED TO DAMAGE GOUNDING SHALL BE USED WHEN EXPOSED TO EXPOSED TO DAMAGE AND BE A MINIMUM OF #10AWG GOONDUCTORS, IF INSULATED, SHALL SEPONSED TO DAMAGE GOONDUCTORS, IF INSULATED, SHALL TO BE SOUNDING SHALL BE USED WHEN EXPOSED TO EXPOSED TO CONDUCTOR GOONDUCTORS, IF INSULATED, SHALL TO BE SOUNDING SHALL BE USED WHEN EXPOSED TO CONDUCTORS, INSULATED, SHALL TO BE COLOR CODED GREEN, OR INSTALL SELECTRODE. TO BE COLOR CODED GREEN, OR INSTALL SELECTRODE ACCORDING TO BE CASED TO MAND THE SHALL BE USED TO MAND TO SHALL BE USED WHEN EXPOSED TO CONDUCTORS, INSULATED, SHALL TO SHALL BE A MINIMUM OF #10AWG TO SHALL BE THE SHAUGH OF THE SHALL BE THE SHAUL SHALL TO SHAUL BE THE SHAUL SHALL BE THE SHAUL	PV.3 SCALE: NTS
MODULES	NevTougeent Wax NevTougeent Wellot	NOTES	



MECHANICAL SPECIFICATION



-	38.62' (95: 11.19)	41.5° (1000 m/s)		
	Farra		a N Daire ge toles	(0.5 mm)
\$48.3 (Listame)	(4.6.m)	٥	* 45.3" (1.154 erre)	DETALA (683) (44m)
	4 x decurating poerts #0.177 (4.5 mm)		3	- 126 (32 om)

004	-		330	335	
ER CLASS		TO THE PROPERTY OF THE	MANCE - 6'W / J WY	The state of the s	
MUM PERFORMANCE AT STAILDARD TEST CONDITIONS, STOT POWER TO LEARNING, STOT POW	STCONDITIO	NS, SIC. (POWER I OLER	THE PARTY OF THE P	200	-
Power at MPP:	P _{hpp}	[W]	330	330	-
Short Circuit Curren!	a	[A]	10.41	10.47	1
O com O com in Well acres	Š	>	40.15	40.41	4
Open Circuit Voirage	3	[W]	16.61	9.67	1
Current at MPP	ed/v	[2]			0
Voltage at MPP	V _{NPP}	[٨]	33.29	33.62	
500000000000000000000000000000000000000	-	[%]	>184	>187	~
MILIM PERFORMANCE ATNORMAL OPERATING CONDITIONS, NIMOT	RATING CON	DITIONS NMOT:			
Power at MPP	Pape	[W]	247.0	250.7	2
Short Circuit Carrent	9	[A]	8.39	8.43	
Open Circuit Voltage	V	2	37.86	38.10	3
Current at MPP	ddN	[A]	7.80	7.84	
Voltage at MPP	V	[V]	31.66	31.97	(5)
Surament tolerances P _{Wat} ±3%; I _{3ct} , V _{0ct} ±5% at STC: 1000W/m², 25±2°C, AM 1.5 according to IEC 60904-3+7803 W/m², NMOT, spectrum AM 1.5	STC:1000W/m	2,25:2°C, AM 1.5 according	gto IEC 60904-3-280	DW/m², NMOT, spectrum	AM 1.5
ELLS PERFORM ANCE WARRANTY			PERFORMANCE /	PERFORMANCE AT LOW IRRADIANCE	-
Transition and antique of the state of the s	At least 98 first rear degradatile of nomina least 85 %	At least 98 % of nominal power during first per a Thorestive max, 0.54 % degradation per year. At least 93.1% of nominal power up to 10 years. At least 85 % of nominal power up to	INE ETRICIBINO? [33]		

Warranty Warranty

USA

Q.ANTUM TECHNO.OGY: LOWLEVELIZED COST OF ELECTRICITY Higher yield per surface area, ower BOS costs, higher power classes, and ar efficiency rate of up to 19.5%.

INNOVATIVE ALL-WEATHER TECHNOLOGY excellent low-ligh; and temperature behavior. Optimal yields, whatever the weather with ENDURING HIGH PERFORMANCE

345 10.68 40.92 10.07 34.25 ×19.3

340 10.52 40.66 10.02 33.94 *19.0

VDE Quality Tosted

Q.PEAK DUO BLK-G6+

330-345 ENDURING HIGH PERFORMANCE

Q.ANTUM DUD

254.5 8.48 38.34 7.89 32.27

	YEARS	
The state of the s	8 8	
SELLS SALEY MASSET IN 1048 SALEY MASSET IN 1649	a conpres	STNE
O CELLS Maring binder Maring binder	16 se for the 1GPV ear A supposely in 1914 (TEMPERATURE COEFFICIENTS
	S Company of the last	RECO
/ Sept	Darded lems on the highest	ATU

Long-term yield security with Anti _ID and Anti PID Technology , Hot-Spot Protect and Traceable Quality Tra.Q^{Tu}.

(<u>(</u>)

EXTREME WEATHER RATING High-tech aluminum alloy frame, certified for high snow (5400 Pa) and wind loads (4000 Pa).

inclusive 25-year product warranty and 25-year

linear performance warranty² A RELIABLE INVESTMENT

ordance with a Q CELLS ur respective		Control of the last of the las
All data within measurement to drawler bs. Full warranties in accordance with the warranty terms of the Q CELLS sales organization of your respective	COUNTY.	Charles and the second control of the second
1	YEARS	-
	8 (4)	-
	September 2014)	-

FICIENTS			
int of lsc	0	[%/K]	+0.04
nt of P ₁₆₀	>	[%/K]	-0.36
		PROP	PROPERTIES FO
tage V _{s.c.}	[2]	1000 (IEC	1000 (IEC)/1000 (UL)

OR SYSTEM DESIGN

		ation Manual
113 (5400 Pa) /84 (4000 Pa	[lbs/ft7]	Load, Push/Pull ³
75 (3600 Pa) / 55 (2667 Pa)	[lbs/ft]	gn Load, Push/ Pulk
20	[A DC]	Series Fuse Rating
1000 (EC)/1000 (NL)	[۸]	System Voltage V _{s.s}

STATE OF THE ART MODULE TECHNOLOGY Q.ANTUM DUO combines cutting edge cell separation and innovative wiring with Q.ANTUM Technology.

APT test conditions according to $\rm IEC/TS$ 82894-1-2015, matrod B $(-1500\,V_{\rm c}$ 188 $\eta_{\rm c})$ Soo bata sheet on rear for further information

-40 °F up to +185 °F (-40 °C up to +85 °C)

PACKAGING INFORMATION

109±5.4 (43±3°C

[%/K] [°F]

S





			\bigcirc	ر "	81.E	× Ş	
Horizontal	70.1in	42.5 ir 1080 mm	47.6 in 1208 mm	1485 lbs 674 kg	28 pallets	26 pellets	32 modules
Vertical	71.5in	45.3 ir 1150 mm	48.0in 1220mm	1514 lbs 687kg	28 pellets	24 pellets	32 modules

Hanvha & CELLS Amurica inc. 400 Spectrum Center Crive, Sute 1400, Irvine, CA92613, USA | TEL +1 949 748 89 98 | ENAIL Frquirr®usq-cels.con | WEB www.q-cells.us

CELLS



THE IDEAL SOLUTION FOR:

Engineered in Germany

Enphase Microinverters

Microinverters 1Q 7 and 1Q 7+ Enphase

dramatically simplify the installation process while Enphase IQ 7 Micro" and Enphase IQ 7+ Micro" achieving the highest system efficiency. The high-powered smart grid-ready

IQ Envoy", Enphase IQ Battery", and the Enphase undergo over a million hours of power-on testing, standards set forth by previous generations and IQ 7+ Microinverters integrate with the Enphase enabling Enphase to provide an industry-leading Enlighten" monitoring and analysis software. 1Q Series Microinverters extend the reliability Part of the Enphase IQ System, the IQ 7 and warranty of up to 25 years.

Easy to Install

- · Lightweight and simple
- Faster installation with improved, lighter two-wire cabling
 Built-in rapid shutdown compliant (NEC 2014 & 2017)

Productive and Reliable

- . Optimized for high powered 60-cell and 72-cell* modules . More than a million hours of testing
 - Class II double-insulated enclosure
- . UL listed

Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
 - Remotely updates to respond to changing grid requirements
 - Configurable for varying grid profiles
 - Meets CA Rule 21 (UL 1741-SA)

The IQ 7+ Micro is required to support 72-cell modules



To learn more about Enphase offerings, visit enphase.com



No 88991

STATE OF

ORIDA

ONAL PROMINE

arrings¹ 2 3e 2 2 2 mt (module isc) 1	1Q7-60-2-US / 1Q7-60-B-US 235 W - 350 W +	00-B-03	235 W - 440 W +	235 W - 440 W +	
ule (sc)	35 W - 350 W +	nlu.	235 W - 440 W +	adulas volu	
ule (sc.)		nla.	CC han 100 72	all Divino dillac	
	60-cell PV modules only	diii y	or-cell alla 72.0	ell PV Illocures	
	48 V		V 29		
	27 V - 37 V		27 V - 45 V		
	16 V - 48 V		16 V - 50 V		
	22 V / 48 V		22 V / 60 V		
	15 A		15 A		
Overvoitage class DC port			=		
	0 A		0.4		
PV array configuration	1 x 1 ungrounded array, No additioral DC side protection required; AC side protection requires max 20A per branch circuit	ay, No additior quires max 20	al DC side protect A per branch circu	ion required; lit	
OUTPUT DATA (AC)	IQ 7 Microinverter	***************************************	IQ 7+ Microinverter	verter	
Peak output power	250 VA		295 VA		
ous output power			290 VA	77,000	
	240 V / 20 211-264 V 18	208 V / 183-229 V	240 V / 211-264 V	208 V / 183-229 V	
Maximum continuous output current	1.0 A (240 V) 1.	1.15 A (208 V)	1.21 A (240 V)	1.39 A (208 V)	
Nominal frequency 60	60 Hz		60 HZ		
	ZH RG - / t		5.8 Ams		
	AC) 1	3 (208 VAC)	13 (240 VAC)	11 (208 VAC)	
Maximum units per zo A (E.C.) prancticular			=		
	A C		0 A		
	1.0		1.0		
ablei	J.85 leading 0.85 l	85 lagging	ing	0.85 lagging	***************************************
SERVICE DE LA COMPANION DE LA	@240 V @	@208 V	@240 V	@208 V	
70	6 %9.76	89.76	% 5.7.5	97.3 %	
fficiency	6 % 0.76	97.0%	% 0.7.6	97.0 %	and processors of the contract
MECHANICAL DATA			- Control of the Cont		to an extended and refer speciment of the state of the st
range	40°C to +65°C				
	4% to 100% (condensing)	(Sing)	0	V	
Connector type (IQ7-60-2-US & IQ7PLUS-72-2-US) N Connector type (IQ7-60-B-US & IQ7PLUS-72-B-US) F A	McA (or Ampleane) HATTX with accitorial d-Duc-3 adaptive) Frience 9 yez/ (MC4 internationale) Adaptors for modules with MC4 or UTX connectors: Adaptors for modules with MC4 or UTX connectors: PV2 to MC4. conter ECA-S20-S22 PV2 to MC4. conter ECA-S20-S25	14 UTX with ac itermateable). is with MC4 or ECA-S20-S22 ECA-S20-S25	ditional Q-DCC-5	adapter)	
Dimensions (WxHxD) 2	212 mm x 175 mm x 30.2 mm (without bracket)	30.2 mm (with	outbracket		
	1.08 kg (2.38 lbs)				
Cooling	Natural convection - No fans	No fans			
Approved for wet locations	Yes				
Pollution degree	PD3				
Enclosure	Class II double-insulated, corrosion resistant polymeric enclosure	lated, corrosio	n resistant polyme	sric enclosure	
Environmental category / UV exposure rating h	NEMA Type 6 / outdoor	oor			
FEATURES					
Communication	Power Line Communication (PLC)	nication (PLC)			
Monitoring	Enlighten Manager and MyEnlighten monitoring options. Both options require instalation of an Enphase IQ Envoy.	and MyEnlighte installation o	in monitoring opti an Enphase 10 Er	ons. 1V0y.	se the load-break
Disconnecting means 7	The AC and DC connectors have disconnect required by NEC 690.	by NEC 690.	sen evaluated and	The AC and DC connectors have been evaluated and approved by UL tor use as the local disconnect required by NEC 690.	770 770 770 770 770 770 770 770 770 770
Compliance	CA Rule 21 (UL 1741-SA) UL 62109-1, UL1741/IEEE1547 CAN/CSA-C22.2 NO. 107.1-01 This product is UL Listed as P	-SA) //EEE1547, FCC // 107.1-01 // isted as PV Ra	Part 15 Class E,	CA Rule 21 (UL 1741-SA) LU 657109-1, ULT14/TEET-347, FCC Part 15 Class B, ICES-0003 Class B, CANICSA-CC22 NO. 07-01 This product is UL Listed as PP Pepild Shu. Down Equipment and conforms with NEC 2014 and This product is UL Listed as PP Systems for AC	s with NEC-2014 and PV Systems, for AC
2. 10	VEC-2017 section 6 and DC conductors,	90.12 and UZZ when installed	according manu	NEC-2017 section 690.12 and C22.1-2015 Rule 64-216 Replu Silutuown orr and DC conductors, when installed according manufacturer's instructions.	

No enforced DCAC ratio. See the compatibility calculator at https://emphase.com/embassupport/modulercom/earbility.
 Nominal dugge ange san be extered to bycomminal findency by the interest see banch in your stee.
 Limits may way Refer (scall requirements to deline fits a muchair of micrometers per banch in your stee.

To learn more about Enphase offerings, visit enphase.com

6. 2018 Enphase Energy, All rights, esserved, All tra 2018/11-19





OCALA ELECTRIC UTILITY OCALA, FLORIDA

FIRST REVISED SHEET NO. 20.0 CANCELS ORIGINAL SHEET NO. 20.0

Tri-Party Net-Metering Power Purchase Agreement

This Tri-Party Net-Metering Power Purchase Agreement (this "Agreement") is entered into this 22 day of MARCH, 20 22, by and between the Florida Municipal Power Agency, a governmental joint action agency created and existing under the laws of the State of Florida (hereinafter "FMPA"), the City of Ocala doing business as Ocala Electric Utility, a body politic (hereinafter "OEU"), and ANGEL DANE, a retail electric customer of OEU (hereinafter "Customer").

Section 1. Recitals

- 1.01. OEU and Customer have executed OEU's Standard Interconnection Agreement for a Customer-Owned Renewable Generation System (RGS) pursuant to which OEU has agreed to permit interconnection of Customer's renewable generation to OEU's electric system at Customer's presently-metered location, and Customer has agreed to deliver excess electric energy generated by Customer's Renewable Generation System to OEU's electric distribution system;
- 1.02. The City of Ocala and FMPA have entered into the All-Requirements Power Supply Contract, dated as of May 1, 1986, (hereinafter the "ARP Contract") pursuant to which the City of Ocala has agreed to purchase and receive, and FMPA has agreed to sell and supply OEU with all energy and capacity necessary to operate the OEU electric system, which limits OEU's ability to directly purchase excess energy from customer-owned renewable generation.
- 1.03. In order to promote the development of small customer-owned renewable generation by permitting OEU to allow its customers to interconnect with OEU's electric system and to allow OEU's electric customers to offset their electric consumption with customer-owned renewable generation, FMPA, in accordance with the terms and conditions of this agreement, has agreed to purchase excess customer-owned generation from OEU's electric customers interconnected to OEU's electric system.

NOW THEREFORE, for and in consideration of the mutual covenants and agreements set forth herein, the Parties covenant and agree as follows:

Section 2. Interconnection

2.01. Customer shall not begin parallel operations with the OEU electric distribution system until Customer has executed OEU's electric Standard Interconnection Agreement for Small Customer-Owned Renewable Generation and is in compliance with all terms and conditions

OEU requires that the customer install and operate the RGS in accordance with all applicable safety codes and standards. OEU shall establish and enforce terms and conditions of operation and disconnection of all interconnected customer-owned renewable generation as it relates to the effect of the RGS on OEU's electric distribution system.

(Continued on Sheet No. 20.1)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.0)

FIRST REVISED SHEET NO. 20.1 CANCELS ORIGINAL SHEET NO. 20.1

Section 3. Metering

3.01 In accordance with the OEU's Standard Interconnection Agreement for Customer-Owned Renewable Generation, OEU shall install metering equipment at the point of delivery capable of recording two separate kWh meter readings: (1) the flow of electricity from OEU to the Customer (Delivered), and (2) the flow of excess electricity from the Customer to OEU. OEU shall take meter readings on the same cycle as the otherwise applicable rate schedule.

Section 4. Purchase of Excess Customer-Owned Renewable Generation

- 4.01. Customer-owned renewable generation shall be first used for Customer's own load and shall offset Customer's demand for OEU's electricity. All electric power and energy delivered by OEU to Customer shall be received and paid for by Customer to OEU (Received) pursuant to the terms, conditions and rates of the OEU otherwise applicable rate schedule.
- 4.02. Excess customer-owned renewable generation shall be delivered to the OEU Electric distribution system. For purposes of this Agreement, the term "excess customer-owned renewable generation" means any kWh of electrical energy produced by the customer-owned renewable generation system that is not consumed by Customer and is delivered to the OEU electric distribution system. FMPA agrees to purchase and receive, and Customer agrees to sell and deliver, all excess customer-owned renewable generation at the energy rate established by FMPA, which shall be calculated in accordance with Schedule A. Excess customer-owned renewable generation shall be purchased in the form of a credit on Customer's monthly energy consumption bill from OEU.
- 4.03. In the event that a given monthly credit for excess customer-owned renewable generation exceeds the total billed amount for Customer's consumption in any corresponding month, then the excess credit shall be applied to the subsequent month's bill. Excess energy credits produced pursuant to the preceding sentence shall accumulate and be used to offset Customer's energy consumption bill for a period of not more than twelve (12) months. At the end of each calendar year, any unused excess energy credits shall be paid by OEU to the Customer in accordance with the OEU Electric Net-Metering Service Rate Schedule.

(Continued on Sheet No. 20.2)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.1)

FIRST REVISED SHEET NO. 20.2 CANCELS ORIGINAL SHEET NO. 20.2

- 4.04. FMPA and OEU shall not be required to purchase or receive excess customer-owned renewable generation, and may require Customer to interrupt or reduce production of customer-owned renewable generation, (a) when necessary in order to construct, install, maintain, repair, replace, remove, investigate, or inspect any OEU equipment or part of OEU's system; or (b) if either FMPA or OEU determine, in their sole judgment, that curtailment, interruption, or reduction is necessary because of emergencies, forced outages, force majeure, or compliance with any applicable electric code or standard.
- 4.05. Customer acknowledges that its provision of electricity to OEU hereunder is on a first-offered, first-accepted basis and subject to diminution and/or rejection in the event the total amount of electricity delivered to OEU pursuant to the Net-Metering Service Rate Schedule (as filed with the Florida Public Service Commission), from all participating OEU customers, exceeds two and one-half percent (2.5%) of the aggregate customer peak demand on the OEU electric system.

Section 5. Renewable Energy Credits

- 5.01. Customer shall offer FMPA a first right of refusal before selling or granting to any third party the right to the Green Attributes associated with its customer-owned renewable generation that is interconnected to OEU electric distribution system. The term "Green Attributes" shall include any and all credits, certificates, benefits, environmental attributes, emissions reductions, offsets, and allowances, however entitled, attributable to the generation of electricity from the customer-owned-renewable generation and its displacement of conventional energy generation.
- 5.02. Any additional meter(s) installed to measure total renewable electricity generated by the Customer for the purposes of measuring Green Attributes, including and renewable energy certificates (or similarly titled credits for renewable energy generated), shall be installed at the expense of the Customer, unless determined otherwise during negotiations for the sale of the Customer's credits to FMPA.

Section 6. Term and Termination

- 6.01. This Agreement shall become effective upon execution by all Parties, and shall remain in effect thereafter on a month-to-month basis until terminated by any Party upon thirty (30) days written notice to all other Parties.
- 6.02. This Agreement shall terminate immediately and without notice upon: (a) termination of the electric distribution service by OEU or (b) failure by Customer to comply with any of the terms and conditions of this Agreement or OEU's Standard Interconnection Agreement for Customer-Owned Renewable Generation.

(Continued on Sheet No. 20.3)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.2)

FIRST REVISED SHEET NO. 20.3 CANCELS ORIGINAL SHEET NO. 20.3

Section 7. Miscellaneous Provisions

7.01. <u>Assignment</u>. It is understood and agreed that no party may transfer, sell, mortgage, pledge, hypothecate, convey, designate, or otherwise assign this Agreement, or any interest herein or any rights or obligations hereunder, in whole or in part, either voluntarily or by operation of law, (including, without limitation, by merger, consolidation, or otherwise), without the express written consent of the other parties (and any such attempt shall be void), which consent shall not be unreasonably withheld. Subject to the foregoing, this Agreement shall inure to the benefit of and be binding upon the parties and their respective successors and permitted assigns.

7.02 Amendment. It is understood and agreed that FMPA and OEU reserve the right, on no less than an annual basis, to change any of the terms and conditions, including pricing, in this Agreement on sixty (60) days advance written notice. FMPA and OEU may make such changes on an immediate basis in the event any applicable law, rule, regulation or court order requires them. In such event, FMPA and OEU will give Customer as much notice as reasonably possible under the circumstances.

7.03. <u>Indemnification</u>. To the fullest extent permitted by laws and regulations, and in return for adequate, separate consideration, Customer shall defend, indemnify, and hold harmless FMPA and OEU, their officers, directors, agents, guests, invitees, and employees from and against all claims, damages, losses to persons or property, whether direct, indirect, or consequential (including but not limited to fees and charges of attorneys, and other professionals and court and arbitration costs) arising out of, resulting from, occasioned by, or otherwise caused by the operation or misoperation of the customer-owned renewable generation, or the acts or omissions of any other person or organization directly or indirectly employed by the Customer to install, furnish, repair, replace or maintain the customer-owned renewable generation system, or anyone for whose acts any of them may be liable.

7.04. Governing Law. The validity and interpretation of this Agreement and the rights and obligations of the parties shall be governed and construed in accordance with the laws of the State of Florida without regard for any conflicts of law provisions that might cause the law of other jurisdictions to apply. All controversies, claims, or disputes arising out of or related to this Agreement or any agreement, instrument, or document contemplated hereby, shall be brought exclusively in the County or Circuit Court for Marion County, Florida, or the United States District Court sitting in Marion County, Florida, as appropriate.

(Continued on Sheet No. 20.4)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.3)

FIRST REVISED SHEET NO. 20.4 CANCELS ORIGINAL SHEET NO. 20.4

- 7.05. <u>Enforcement of Agreement</u>. In the event that either party is required to enforce this Agreement by court proceedings or otherwise, the prevailing party shall be entitled to recover all fees and costs incurred, including reasonable attorney's fees and costs for trial, alternative dispute resolution, and/or appellate proceedings.
- 7.06. Severability. To the extent any provision of this Agreement is prohibited by or invalid under applicable law, such provision shall be ineffective to the extent of such prohibition or invalidity, without invalidating the remainder of such provision or the remaining provisions of this Agreement.
- 7.07. Third Party Beneficiaries and Sovereign Immunity. This Agreement is solely for the benefit of FMPA, OEU, and Customer and no right nor shall any cause of action accrue upon or by reason, to or for the benefit of any third party not a formal party to this Agreement. Nothing in this Agreement, expressed or implied, is intended or shall be construed to confer upon any person or corporation other than FMPA, OEU, or Customer, any right, remedy, or claim under or by reason of this Agreement or any of the provisions or conditions of this Agreement; and, all provisions, representations, covenants, and conditions contained in this Agreement shall inure to the sole benefit of and be binding upon FMPA, OEU, and Customer and their respective representatives, successors, and assigns. Further, no term or condition contained in this Agreement shall be construed in any way as a waiver by either FMPA or OEU of the sovereign immunity applicable to either or both of them as established by Florida Statutes, 768.28.

(Continued on Sheet No. 20.5)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.4)

FIRST REVISED SHEET NO. 20.5 CANCELS ORIGINAL SHEET NO. 20.5

IN WITNESS WHEREOF, Customer and OEU have executed this Agreement the day and year first above written.

By: Ken Whitehead By	1:
7	
Title: Asst. City Manager Tit	tle: Bus Dev & Sys Ops Director
	ate: 07 / 11 / 2022
Customer By: ANGEL DANE Date: (Print Name) (Signature) Customer's City of Ocala Electric Utility Account Nur	mber: 527518-226006

Approved as to form and legality:

Robert W. Batsel, Jr.

Robert W. Batsel, Jr. Assistant City Attorney

(Continued on Sheet No. 20.6)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 20.5)

FIRST REVISED SHEET NO. 20.6 CANCELS ORIGINAL SHEET NO. 20.6

Tri-Party Net-Metering Power Purchase Agreement Schedule A

I. All-Requirements Project Calculation of Excess Customer-Owned Renewable Generation Credit

a) FMPA shall pay OEU for the excess kWh energy delivered by customer-owned renewable generation to OEU's electric system. Every month, OEU shall determine the total kWh of customer-owned renewable generation that is delivered to OEU's electric system, and shall send the information to FMPA as soon as it becomes available, but no later than the second working day of every month. FMPA will then provide a monthly payment to OEU in the form of a credit on the ARP power bill for the excess energy delivered to the distribution grid. The ARP Renewable Generation Credit will be calculated as follows:

ARP Renewable Generation Credit = Quarterly Energy Rate * Monthly kWh of excess customer-owned renewable generation

Quarterly Energy Rate = 3 month average of ARP energy rate. FMPA will update the Quarterly Energy Rate every April 1, July 1, October 1 and January 1.

b) As part of the monthly bill adjustment, FMPA will also increase OEU's kWh billing amount by the same kWh amount as the customer-owned renewable generation purchased by FMPA. This adjustment is necessary because excess customer generation that flows onto OEU's electric system has been purchased by FMPA, but will remain on OEU's electric system and be used by OEU to meet its other customers' electric needs. As a result, OEU's monthly ARP bill will be adjusted accordingly to reflect FMPA's subsequent sale of this energy to OEU.

II. Payment for Unused Excess Energy Credits

- a) Monthly excess energy credits shall accumulate and be used to offset the Customer's following month energy consumption bill for a period of not more than twelve (12) months.
- b) At the end of each calendar year, OEU shall pay the Customer for any unused excess energy credits in accordance with the OEU Electric Net-Metering Service Rate Schedule.

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA

FIRST REVISED SHEET NO. 21.0 CANCELS ORIGINAL SHEET NO. 21.0

Tier 1 – Standard Interconnection Agreement Customer-Owned Renewable Generation System

This Agreement is made and	d entered into this	22 day of MARCH	t, 20 <u>22</u>	, by and
between ANGEL DANE		, (hereinafter cal	led "Customer")	
4885 NE 27TH CT, in	n OCALA		and the City of	
business as Ocala Electric U	Itility (hereinafter	called OEU), a boo	ly politic. Custor	mer and OEU
shall collectively be called th	e "Parties". The	physical location/pre	mise where the in	terconnection
is taking place: 4885 NE 27TH	CT, OCALA FL 3447	79		

WITNESSETH

Whereas, a Tier 1 Renewable Generation System (RGS) is an electric generating system that uses one or more of the following fuels or energy sources: hydrogen, biomass, solar energy, geothermal energy, wind energy, ocean energy, waste heat, or hydroelectric power as defined in Section 377.803, Florida Statutes, rated at no more than ten (10) kilowatts (10 kW) alternating current (AC) power output and is primarily intended to offset part or all of the Customer's current electric requirements; and

Whereas, OEU operates an electric system serving the City of Ocala; and

Whereas, Customer has made a written Application to OEU, a copy being attached hereto, to interconnect its RGS with OEU' electrical supply grid at the location identified above; and

Whereas, the City of Ocala and the Florida Municipal Power Agency (hereinafter called "FMPA") have entered into the All-Requirements Power Supply Contract pursuant to which the City of Ocala has agreed to purchase and receive, and FMPA has agreed to sell and supply OEU with all energy and capacity necessary to operate the OEU electric system, which limits OEU' ability to directly purchase excess energy from customer-owned renewable generation; and

Whereas, in order to promote the development of small customer-owned renewable generation by permitting OEU to allow its customers to interconnect with OEU's electric system and to allow OEU customers to offset their electric consumption with customer-owned renewable generation, FMPA, in accordance with the terms and conditions of this agreement, has agreed to purchase excess customer-owned generation from OEU customers interconnected to OEU's electric system; and

Whereas, the OEU desires to provide interconnection of a RGS under conditions which will insure the safety of OEU customers and employees, reliability and integrity of its distribution system;

NOW, THEREFORE, for and in consideration of the mutual covenants and agreements herein set forth, the parties hereto covenant and agree as follows:

(Continued on Sheet No. 21.1)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.0)

FIRST REVISED SHEET NO. 21.1 CANCELS ORIGINAL SHEET NO. 21.1

- 1. The Customer shall be required to enter into a Tri-Party Net-Metering Purchase Power Agreement with FMPA and the City of Ocala Electric Utility (OEU).
- 2. "Gross power rating" (GPR) means the total manufacturer's AC nameplate generating capacity of an on-site customer-owned renewable generation system that will be interconnected to and operate in parallel with OEU's distribution facilities. For inverter-based systems, the GPR shall be calculated by multiplying the total installed DC nameplate generating capacity by 0.85 in order to account for losses during the conversion from DC to AC.
- 3. This agreement is strictly limited to cover a Tier 1 RGS as defined above. It is the Customer's responsibility to notify OEU of any change to the GPR of the RGS by submitting a new application for interconnection specifying the modifications at least 30 days prior to making the modifications. Increase in GPR above the ten kilowatt (10 kW) limit would necessitate entering into a new agreement at either Tier 2 or Tier 3 which may impose additional requirements on the Customer. In no case does the Tier 1, Tier 2 or Tier 3 agreement cover increases in GPR above two megawatts (2MW).
- 4. The RGS GPR must not exceed 90 percent (90%) of the Customer's OEU calculated distribution service rating at the Customer's location (including shared electric facilities). If the GPR does exceed the 90 percent (90%) limit, the Customer shall be responsible to pay the cost of upgrades to the distribution facilities required to accommodate the GPR capacity and ensure the 90 percent (90%) threshold is not breached. OEU will not allow a RGS GPR greater than required to offset the customer's annual kWh energy consumption (based on customer's historical consumption data or by means of estimated usage of similar type of service as determined by OEU).
- 5. The Customer shall not be required to pay any special fees due solely to the installation of the RGS.
- 6. The Customer shall fully comply with OEU's Design Standards following NEC standards as those documents may be amended or revised by OUS from time to time.
- 7. The Customer certifies that its installation, its operation and its maintenance shall be in compliance with the following standards (or most current version at time of inspection approval):
 - a. IEEE-1547 (2018) Standard for Interconnecting Distributed Resources with Electric Power System;
 - b. IEEE-1547.1 (2005) Standard Conformance Test Procedures for Equipment Interconnection Distributed Resources with Electric Power Systems;
 - c. UL-1741 (2010) Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed *Energy Resources*.
 - d. The National Electric Code, state and/or local building codes, mechanical codes and/or electrical codes;
 - e. The manufacturer's installation, operation and maintenance instructions.

(Continued to Sheet No. 21.2)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.1)

FIRST REVISED SHEET NO. 21.2 CANCELS ORIGINAL SHEET NO. 21.2

- 8. The Customer is not precluded from contracting for the lease, operation or maintenance of the RGS with a third party. Such lease may not provide terms or conditions that provide for any payments under the agreement to any way indicate or reflect the purchase of energy produced by the RGS. Customer shall not enter into any lease agreement that results in the retail purchase of electricity; or the retail sale of electricity from the customer-owned renewable generation. Notwithstanding this restriction, in the event that Customer is determined to have engaged in the retail purchase of electricity from a party other than OEU, then Customer shall be in breach of this Agreement and may be subject to the jurisdiction of the Florida Public Service Commission and to fines/penalties.
- 9. The Customer shall provide a copy of the manufacturer's installation, operation and maintenance instructions to OEU. If the RGS is leased to the Customer by a third party, or if the operation or maintenance of the RGS is to be performed by a third party, the lease and/or maintenance agreements and any pertinent documents related to these agreements shall be provided to OEU.
- 10. Prior to commencing parallel operation with OEU's electric system, Customer shall have the RGS inspected and approved by the appropriate code authorities having jurisdiction. Customer shall provide a copy of this inspection and approval to OEU.
- 11. The Customer agrees to permit OEU, if it should so choose, to inspect the RGS and its component equipment and the documents necessary to ensure compliance with this Agreement both before and after the RGS goes into service and to witness the initial testing of the RGS equipment and protective apparatus. OEU will provide Customer with as much notice as reasonably possible, either in writing, email, facsimile or by phone as to when OEU may conduct inspections and or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, Customer agrees to provide OEU access to the Customer's premises for any purpose in connection with the performance of the obligations required by this Agreement or, if necessary, to meet OEU's legal obligation to provide service to its customers. At least ten (10) business days prior to initially placing the customer-owned renewable generation system in service, Customer shall provide written notification to OEU advising of the date and time at which Customer intends to place the system in service, and OEU shall have the right to have personnel present on the in-service date in order to ensure compliance with the requirements of this Agreement.

(Continued on Sheet No. 21.3)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.2)

FIRST REVISED SHEET NO. 21.3 CANCELS ORIGINAL SHEET NO. 21.3

- 12. The Customer's RGS must have an appropriately sized grid-tie inverter system that includes applicable protective systems. Customer certifies that the RGS equipment includes an OEU interactive inverter or interconnection system equipment that ceases to interconnect with the OEU system upon a loss of OEU's electric power. The inverter shall be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing laboratory (NRTL) to comply with UL 1741. The NRTL shall be approved by the Occupational Safety & Health Administration (OSHA).
- 13. If Customer adds another RGS that (i) utilizes the same OEU interactive inverter for both systems, or (ii) utilizes a separate OEU interactive inverter for each system, Customer shall provide OEU with sixty (60) days advance written notice of the addition.
- 14. The Customer shall not energize the OEU system when OEU's system is deenergized. The Customer shall cease to energize the OEU system during a faulted condition on the OEU system and/or upon any notice from OEU that the deenergizing of Customer's RGS equipment is necessary. The Customer shall cease to energize the OEU system prior to automatic or non-automatic reclosing of OEU's protective devices. There shall be no intentional islanding, as described in IEEE 1547, between the Customer's and OEU' systems.
- 15. The Customer is responsible for the protection of its generation equipment, inverters, protection devices, and other system components from damage from the normal and abnormal operations that occur on OEU system in delivering and restoring system power. Customer agrees that any damage to any of its property, including, without limitation, all components and related accessories of its RGS system, due to the normal or abnormal operation of OEU system, is at Customer's sole risk and expense. Customer is also responsible for ensuring that the customerowned renewable generation equipment is inspected, maintained, and tested regularly in accordance with the manufacturer's instructions to ensure that it is operating correctly and safely.
- 16. The Customer must install, at their expense, a manual disconnect switch of the visible load break type to provide a separation point between the AC power output of the customer-owned renewable generation system and any Customer wiring connected to OEU's system, such that back feed from the customer-owned renewable generation system to OEU's system cannot occur when the switch is in the open position. The manual disconnect switch shall be mounted separate from the meter socket on an exterior surface adjacent to the meter. The switch shall be readily accessible to OEU and capable of being locked in the open position with an OEU padlock. When locked and tagged in the open position by OEU, this switch will be under the control of OEU.

(Continued on Sheet No. 21.4)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.3)

FIRST REVISED SHEET NO. 21.4 CANCELS ORIGINAL SHEET NO. 21.4

- 17. Subject to an approved inspection, including installation of acceptable disconnect switch, this Agreement shall be executed by OEU within thirty (30) calendar days of receipt of a completed application. Customer must execute this Agreement and return it to OEU at least thirty (30) calendar days prior to beginning parallel operations with OEU's electric system, subject to the requirements of Section 18, below, and within one (1) year after OEU executes this Agreement.
- 18. Once OEU has received Customer's written documentation that the requirements of this Agreement have been met, all agreements and documentation have been received and the correct operation of the manual switch has been demonstrated to an OEU representative, OEU will, within fifteen (15) business days, send written notice that parallel operation of the RGS may commence.
- 19. OEU requires the Customer to maintain general liability insurance for personal injury and property damage in the amount of not less than one hundred thousand dollars (\$100,000.00).
- 20. OEU will furnish, install, own and maintain metering equipment capable of measuring the flow of kilowatt-hours (kWh) of energy. The Customer's service associated with the RGS will be metered to measure the energy delivered by OEU to Customer, and measure the energy delivered by Customer to OEU. Customer agrees to provide safe and reasonable access to the premises for installation, maintenance and reading of the metering and related equipment. The Customer shall not be responsible for the cost of the installation and maintenance of the metering equipment necessary to measure the energy delivered by the Customer to OEU.
- 21. The Customer shall be solely responsible for all legal and financial obligations arising from the design, construction, installation, operation, maintenance and ownership of the RGS.
- 22. The Customer must obtain all permits, inspections and approvals required by applicable jurisdictions with respect to the generating system and must use a licensed, bonded and insured contractor to design and install the generating system. The Customer agrees to provide OEU with a copy of the local building code official inspection and certification of installation. The certification shall reflect that the local code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.

(Continued on Sheet No. 21.5)

Issued by: Michael Poucher, P.E.

Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.4)

- 23. In no event shall any statement, representation, or lack thereof, either express or implied, by OEU, relieve the Customer of exclusive responsibility for the Customer's system. Specifically, any OEU inspection of the RGS shall not be construed as confirming or endorsing the system design or its operating or maintenance procedures or as a warranty or guarantee as to the safety, reliability, or durability of the RGS. OEU's inspection, acceptance, or its failure to inspect shall not be deemed an endorsement of any RGS equipment or procedure. Further, as set forth in Sections 15 and 26 of this Agreement, Customer shall remain solely responsible for any and all losses, claims, damages and/or expenses related in any way to the operation or misoperation of its RGS equipment.
- 24. Notwithstanding any other provision of this Interconnection Agreement, OEU, at its sole and absolute discretion, may isolate the Customer's system from the distribution grid by whatever means necessary, without prior notice to the Customer. To the extent practical, however, prior notice shall be given. The system will be reconnected as soon as practical once the conditions causing the disconnection cease to exist. OEU shall have no obligation to compensate the Customer for any loss of energy during any and all periods when Customer's RGS is operating at reduced capacity or is disconnected from OEU' electrical distribution system pursuant to this Interconnection Agreement. Typical conditions which may require the disconnection of the Customer's system include, but are not limited to, the following:
 - a. OEU system emergencies, forced outages, uncontrollable forces or compliance with prudent electric OEU practice.
 - b. When necessary to investigate, inspect, construct, install, maintain, repair, replace or remove any OEU equipment, any part of OEU's electrical distribution system or Customer's generating system.
 - c. Hazardous conditions existing on OEU's system due to the operation of the Customer's generation or protective equipment as determined by OEU.
 - d. Adverse electrical affects (such as power quality problems) on the electrical equipment of OEU's other electric consumers caused by the Customer's generation as determined by OEU.
 - e. When Customer is in breach of any of its obligations under this Interconnection Agreement or any other applicable policies and procedures of OEU.
 - f. When the Customer fails to make any payments due to OEU by the due date thereof.
- 25. Upon termination of services pursuant to this Agreement, OEU shall open and padlock the manual disconnect switch and remove any additional metering equipment related to this Agreement. At the Customer's expense, within thirty (30) working days following the termination, the Customer shall permanently isolate the RGS and any associated equipment from OEU's electric supply system, notify OEU that the isolation is complete, and coordinate with OEU for return of OEU's lock.

(Continued to Sheet No. 21.6)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.5)

FIRST REVISED SHEET NO. 21.6 CANCELS ORIGINAL SHEET NO. 21.6

- 26. To the fullest extent permitted by law, and in return for adequate, separate consideration, Customer shall indemnify, defend and hold harmless OEU, any and all of their members of its governing bodies, and its officers, agents, and employees for, from and against any and all claims, demands, suits, costs of defense, attorneys fees, witness fees of any type, losses, damages, expenses, and liabilities, whether direct, indirect or consequential, related to, arising from, or in any way connected with:
 - a. Customer's design, construction, installation, inspection, maintenance, testing or operation of Customer's generating system or equipment used in connection with this Interconnection Agreement, irrespective of any fault on the part of OEU.
 - b. The interconnection of Customer's generating system with, and delivery of energy from the generating system to, OEU's electrical distribution system, irrespective of any fault on the part of OEU.
 - c. The performance or nonperformance of Customer's obligations under this Interconnection Agreement or the obligations of any and all of the members of Customer's governing bodies and its officers, agents, contractors (and any subcontractor or material supplier thereof) and employees.

Customer's obligations under this Section shall survive the termination of this Interconnection Agreement.

- 27. Customer shall not have the right to assign its benefits or obligations under this Agreement without OEU's prior written consent and such consent shall not be unreasonably withheld. If there is a change in ownership of the RGS, Customer shall provide written notice to OEU at least thirty (30) days prior to the change in ownership. The new owner will be required to assume, in writing, the Customer's rights and duties under this Agreement, or execute a new Standard Interconnection Agreement. The new owner shall not be permitted to net meter or begin parallel operations until the new owner assumes this Agreement or executes a new Agreement.
- 28. This Agreement supersedes all previous agreements and representations either written or verbal heretofore made between OEU and Customer with respect to matters herein contained. This Agreement, when duly executed, constitutes the only Agreement between parties hereto relative to the matters herein described. This Agreement shall continue in effect from year to year until either party gives sixty (60) days' notice of its intent to terminate this Agreement.

(Continued on Sheet No. 21.7)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.6)

FIRST REVISED SHEET NO. 21.7 CANCELS ORIGINAL SHEET NO. 21.7

29. This Agreement shall be governed by and construed and enforced in accordance with the laws, rules and regulations of the State of Florida and OEU's tariff as it may be modified, changed, or amended from time to time, including any amendments modification or changes to OEU's Net-Metering Service Rate Schedule, the schedule applicable to this Agreement. The Customer and OEU agree that any action, suit, or proceeding arising out of or relating to this Interconnection Agreement shall be initiated and prosecuted in the state court of competent jurisdiction located in Marion County, Florida, and OEU and the Customer irrevocably submit to the jurisdiction and venue of such court. To the fullest extent permitted by law, each Party hereby irrevocably waives any and all rights to a trial by jury and covenants and agrees that it will not request a trial by jury with respect to any legal proceeding arising out of or relating to this Interconnection Agreement.

None of the provisions of this Interconnection Agreement shall be considered waived by either Party except when such waiver is given in writing. No waiver by either Party of any one or more defaults in the performance of the provisions of this Interconnection Agreement shall operate or be construed as a waiver of any other existing or future default or defaults. If any one or more of the provisions of this Interconnection Agreement or the applicability of any provision to a specific situation is held invalid or unenforceable, the provision shall be modified to the minimum extent necessary to make it or its application valid and enforceable, and the validity and enforceability of all other provisions of this Interconnection Agreement and all other applications of such provisions shall not be affected by any such invalidity or unenforceability. This Interconnection Agreement does not govern the terms and conditions for the delivery of power and energy to non-generating retail customers of OEU's electrical distribution system.

- 30. This Agreement incorporates by reference the terms of the tariff filed with the Florida Public Service Commission by OEU, including OEU's Net-Metering Service Rate Schedule, and associated technical terms and abbreviations, general rules and regulations and standard electric service requirements (as may be applicable) are incorporated by reference, as amended from time to time. To the extent of any conflict between this Agreement and such tariff, the tariff shall control.
- 31. OEU and Customer recognize that the Florida Statutes and/or the Florida Public Service Commission Rules, including those directly addressing the subject of this Agreement, may be amended from time to time. In the event that such statutes and/or rules are amended that affect the terms and conditions of this Agreement, OEU and Customer agree to supersede and replace this Agreement with a new Interconnection Agreement, which complies with the amended statutes/rules.

(Continued on Sheet No. 21.8)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.7)

FIRST REVISED SHEET NO. 21.8 CANCELS ORIGINAL SHEET NO. 21.8

- 32. Customer acknowledges that its provision of electricity to OEU hereunder is on a first-offered, first-accepted basis and subject to diminution and/or rejection in the event the total amount of electricity delivered to OEU pursuant to the OEU's Net-Metering Service Rate Schedule, (as filed with the Florida Public Service Commission), from all participating OEU customers, exceeds two and one-half percent (2.5%) of the aggregate customer peak demand on the OEU system.
- 33. This Agreement is solely for the benefit of OEU and Customer and no right nor any cause of action shall accrue upon or by reason, to or for the benefit of any third party not a formal party to this Agreement. Nothing in this Agreement, expressed or implied, is intended or shall be construed to confer upon any person or corporation other than OEU or Customer, any right, remedy, or claim under or by reason of this Agreement or any of the provisions or conditions of this Agreement; and, all provisions, representations, covenants, and conditions contained in this Agreement shall inure to the sole benefit of and be binding upon OEU and Customer and their respective representatives, successors, and assigns. Further, no term or condition contained in this Agreement shall be construed in any way as a waiver by OEU of the sovereign immunity applicable to OEU as established by Florida Statutes, 768.28.

(Continued on Sheet No. 21.9)

Issued by: Michael Poucher, P.E. Electric Utility Director

OCALA ELECTRIC UTILITY OCALA, FLORIDA (Continued from Sheet No. 21.8)

FIRST REVISED SHEET NO. 21.9 CANCELS ORIGINAL SHEET NO. 21.9

IN WITNESS WHEREOF, Customer and OEU have executed this Agreement the day and year first above written.

City of Ocala Electric Utility:	Customer:
By: Ken Whitehead	By:ANGEL DANE
Title: Asst. City Manager	(Print Name)
Date: 07 / 10 / 2022	(Signature) 03/27/22.
	City of Ocala Electric Utility Account Number
	527518-226006

Approved as to form and legality:

Robert W. Batsel, Jr.

Robert W. Batsel, Jr. Assistant City Attorney

Issued by: Michael Poucher, P.E. Electric Utility Director



TITLE ELE-220615 - Net Metering Agreement Angel Dane

FILE NAME ELE-220615 - Net ...nt Angel Dane.pdf

DOCUMENT ID 115b15107b7c0fc5615f8189d77d87c7234156af

AUDIT TRAIL DATE FORMAT MM / DD / YYYY

STATUS • Signed

Document History

07 / 06 / 2022	Sent for signature to Robert W. Batsel, Jr.
12:12:35 UTC-4	(rbatsel@lawyersocala.com), Ken Whitehead

(kwhitehead@ocalafl.org) and Florida Municipal Power Agency

(chris.gowder@fmpa.com) from mcarroccia@ocalafl.org

IP: 216.255.240.104

\odot	07 / 10 / 2022	Viewed by Robert W. Batsel, Jr. (rbatsel@lawyersocala.com)
VIEWED	11:04:47 UTC-4	IP: 216.255.247.55

r	07 / 10 / 2022	Signed by Robert W. Batsel, Jr. (rbatsel@lawyersocala.com)
SIGNED	11:05:22 UTC-4	IP: 216.255.247.55

(a)	07 / 10 / 2022	Viewed by Ken Whitehead (kwhitehead@ocalafl.org)
VIEWED	19:34:34 UTC-4	IP: 216.255.240.104

p	07 / 10 / 2022	Signed by Ken Whitehead (kwhitehead@ocalafl.org)
SIGNED	19:36:09 UTC-4	IP: 216.255.240.104



TITLE ELE-220615 - Net Metering Agreement Angel Dane

FILE NAME ELE-220615 - Net ...nt Angel Dane.pdf

DOCUMENT ID 115b15107b7c0fc5615f8189d77d87c7234156af

AUDIT TRAIL DATE FORMAT MM / DD / YYYY

STATUS • Signed

Document History

O7 / 11 / 2022 Viewed by Florida Municipal Power Agency

VIEWED 08:01:04 UTC-4 (chris.gowder@fmpa.com)

IP: 38.77.131.2

11 / 2022 Signed by Florida Municipal Power Agency

SIGNED 08:01:14 UTC-4 (chris.gowder@fmpa.com)

IP: 38.77.131.2

7 The document has been completed.

COMPLETED 08:01:14 UTC-4