



Ocala

110 SE Watula Avenue
Ocala, FL 34471

www.ocalafl.gov

Item Details

File Number: 2024-0711

ID #: 2024-0711

Type: Agenda Item

Status: Passed

Version: 1

Placement: 8

In Control: City Council

File Created: 01/31/2024

Presented By: :

Final Action: 02/20/2024

Formal Title: Approve a two-year agreement with Art Walker Construction, Inc. for lime sludge hauling services at Water Treatment Plant No. 1 with an aggregate expenditure not to exceed \$146,700.

Internal Notes:

Target Meeting: 02/20/2024

Agenda Number: 8e.

Sponsors:

Enactment Date:

Attachments: FOR COUNCIL- Agreement for Lime Sludge Hauling and Removal Services - Art Walker Construction, Inc (WRS 240102) (2), BID TABULATION

Enactment Number:

Recommendation:

Hearing Date:

Entered by: mfriehauf@ocalafl.gov

Effective Date:

History of Legislative File

Version:	Acting Body:	Date:	Action:	Sent To:	Due Date:	Return Date:	Result:
----------	--------------	-------	---------	----------	-----------	--------------	---------

1	City Council	02/20/2024	Approved				Pass
---	--------------	------------	----------	--	--	--	------

Action Text:

Notes:

City Engineer & Director of Water Resources explained the process for hauling lime sludge with Council President Mansfield.

There being no further discussion the motion carried by roll call vote.

Aye: 5 Pro Tem Dreyer, Council Member Bethea Sr, Council Member Hilty Sr, Council Member Musleh, and Council President Mansfield

Text of Legislative File 2024-0711

Approve a two-year agreement with Art Walker Construction, Inc. for lime sludge hauling services at Water Treatment Plant No. 1 with an aggregate expenditure not to exceed \$146,700.

BACKGROUND:

The Water Resources Department is requesting approval of Contract No. WRS/240102 utilizing Art Walker Construction, Inc. to provide lime sludge hauling services at Water Treatment Plant No. 1 (WTP #1). Excess lime sludge is the product of the conventional lime softening process used at WTP #1 and approximately 9,000 cubic yards is generated annually. This product accumulates at WTP #1 and requires disposal. It is typically applied to agricultural pastures to adjust pH levels.

FINDINGS AND CONCLUSIONS:

On November 29, 2023, the City of Ocala issued Invitation to Bid (“ITB”) No. WRS/240102. Two firms responded. Art Walker Construction, Inc. was the low bidder. The price of lime sludge removal is \$ 8.15 per cubic yard. The total bid amount for one year is \$73,350.

Presentation By: Sean Lanier