

**From:** [City of Ocala - Contracting Officer](#)  
**To:** [Lisa M. Crouthamel](#); [Tiffany Kimball](#); [Corrin M. Fitsemoms](#)  
**Subject:** Your policy exception has been approved.  
**Date:** Monday, May 9, 2022 11:26:05 AM



Your policy exception has been **approved**.

**Approval Comments:** This is approved as the best solution. Equipment is made in USA.

### Procurement/Contract/P-Card Exception

**Select exception type:**

Procurement

**Reason for procurement exception:**

Standardization

**Enter a brief description of your exception request:**

Attached is another quote for R-Mag breakers. We are standardizing all the substations with the R-Mag breakers due to we cannot obtain parts for the existing breakers that are in service. Only ABB makes the magnetic actuator breakers that we are installing in our substations now. This will be the third time purchasing these breakers and I wanted to make sure they are standardized but I do not know where the "standardized" products are listed. I attached a quote that will need to be on 5/17 council due to the expiration of the quote so I need an answer asap please . We would be purchasing 5 R-Mag breakers and 1 control panel. Four breakers will be installed at Dearmin substation and 1 will be a spare. May I move forward?

**Attach all documents related to the exception that can assist the Contracting Officer's decision.**

[QT-22-02041229 Ocala Electric 125VDC for Dearmin.docx](#)

**Department**

Electric

**Name**

Lisa Crouthamel

**Email**

lcrouthamel@ocalafl.org

**Phone number**

(352) 351-6646

**Who authorized requesting this exception?**

Lisa Crouthamel

