



Monday, May 2, 2022

Approval Status

Approved

Procurement/Contracting/P-Card Policy Exception Request Form

Select exception type:

Procurement

Reason for procurement exception:

Standardization

Enter a brief description of your exception request:

Attached is another quote for R-Mag breakers. We are standardizing all the substations with the R-Mag breakers due to we cannot obtain parts for the existing breakers that are in service. Only ABB makes the magnetic actuator breakers that we are installing in our substations now. This will be the third time purchasing these breakers and I wanted to make sure they are standardized but I do not know where the "standardized" products are listed. I attached a quote that will need to be on 5/17 council due to the expiration of the quote so I need an answer asap please 😊. We would be purchasing 5 R-Mag breakers and I control panel. Four breakers will be installed at Dearmin substation and 1 will be a spare. May I move forward?

Attach all documents related to the exception that can assist the Contracting Officer's decision.



QT-22-02041229 Ocala Elec... .docx

Department

(ELE) ELECTRIC

Requestor Name

Lisa Crouthamel

Requestor Email

lcrouthamel@ocalafl.org

Phone number

(352) 351-6646

Who authorized requesting this exception?

Lisa Crouthamel

Approval Activity History

Actor	Actions	Date
 Tiffany Kimball tkimball@ocalafl.org	<div style="background-color: #28a745; color: white; padding: 2px 10px; border-radius: 10px; text-align: center;">Approve</div> <p>This is approved as the best solution. Equipment is made in USA.</p>	Monday, May 9, 2022
 Notification	Email sent. (Your policy exception has been approved.) lcrouthamel@ocalafl.org,tkimball@ocalafl.org,cmfitsemons@ocalafl.org	Monday, May 9, 2022